



| DIMENSIONS | | | | | |
|---------------------------|-----------|------------|------------|-----------|------------|
| LIQUID CAPACITY (GALLONS) | WIDTH "A" | LENGTH "B" | HEIGHT "C" | INLET "D" | OUTLET "E" |
| 2000 | 4'-11" | 15'-11" | 6'-0" | 5'-0" | 4'-9" |
| 2500 | 5'-9" | 16'-10" | 6'-0" | 5'-0" | 4'-9" |
| 3000 | 5'-9" | 16'-10" | 6'-9" | 5'-9" | 5'-6" |
| 4000 | 7'-8" | 16'-7" | 6'-9" | 5'-6" | 5'-3" |
| 5000 | 7'-8" | 16'-7" | 7'-11" | 6'-9" | 6'-6" |

NOTES

- TANK SHALL BE DESIGNED FOR H-20 TRAFFIC WHEEL LOAD WITH DRY SOIL CONDITIONS (WATER TABLE BELOW TANK).
- SUITABLE NATIVE SOIL OR CRUSHED AGGREGATE BASE SHALL BE COMPACTED TO 90% RELATIVE COMPACTION AND LEVELED.

CITY OF REDLANDS MUNICIPAL UTILITIES AND ENGINEERING DEPARTMENT

**GREASE INTERCEPTOR
2000-5000 GALLONS**

STD. DWG. NUMBER
227

APPROVED: *Michael Pool* DATE 6/24/19

REV. BY DATE

Michael Pool, Assistant City Engineer RCE 49585

SHEET 1 OF 1