



## Redlands Fire Department Fire Protection Standard

**Title:** Smoke Alarm Notice

**Number:** FS-103

**Revision:** A

**Date:** 10-15-2015

**Scope:** To provide documentation that working smoke alarms are installed and operating in each occupied dwelling/unit.

**Description:** The California Building Code requires that all residences must have working smoke alarms installed. A residence includes all dwelling units, hotels, lodging such as guest rooms and group homes as well as any other living spaces that are utilized for sleeping. Smoke alarms must be installed according to manufacturer's instructions and approved wiring and installation standards.

All smoke alarms installed in California must be approved by the California State Fire Marshal and bear the approval label.

The property owner or legal representative shall complete the Smoke Alarm Notice attesting that all occupied/dwelling units have working smoke alarms and that they are maintained in an operable condition.



Redlands Fire Department  
Fire Protection Standard

**SMOKE ALARM NOTICE**

Date:

Owner:

Address:

Dear Owner:

This letter shall serve as Notice advising that you shall **AT ALL TIMES** provide and maintain an **OPERABLE** smoke alarm in each unit/dwelling that you own.

The California Fire Code stipulates that smoke alarms shall be provided in every dwelling, guest room, and motel or lodging house used for sleeping purposes. Each smoke alarm shall be a California State Fire Marshal approved and listed device.

Immediate compliance of this requirement is necessary in order for your property to meet this City's life safety standards. It is required that the bottom portion of this NOTICE be completed by you and returned to this department for file.

Failure to return this verification by 5:00 p.m. on day of inspection could result in additional enforcement action in accordance with the California Fire Code and Redlands Municipal Code.

A reinspection to note compliance will be conducted on or around [date]

The premises located at [physical address], City of Redlands, California has smoke detectors installed and operating in each occupied dwelling/unit.

\_\_\_\_\_  
Print name:

\_\_\_\_\_  
Signed:

\_\_\_\_\_  
Date:

**Return form to:**  
**Redlands Fire Department**  
**Attn: Fire Prevention**  
**35 Cajon St., Ste. 12**  
**Post Office Box 3005**  
**Redlands, CA 92373**