



Redlands Fire Department Fire Protection Standard

Title: Fire System Addressing and Labeling

Number: FS-105

Revision: A

Date: 11-09-15

Scope: Labeling and addressing of all fire system appliances.

Description: To provide a standard for all labeling of fire systems and equipment.

Field Devices , Appliances and Equipment

- All field devices shall indicate where and what it serves, by address
- Purpose and location shall be indicated where applicable
- All signage shall be metal and permanently affixed with metallic type hardware
- All lettering shall be white on red background
- All doors, hatches and access ways shall be a minimum of 3 inch height 3/4 inch stroke
- All field appliances shall be a minimum of 2 inch height 1/2 inch stroke