

The “**SAMPLE**” directory shown below is to be installed on or adjacent to the Main Service Disconnect when the Photovoltaic Disconnect is at a remote location or is not visible from the Main Electrical Service Disconnect. Walls and fences are some examples of visual barriers where a Directory such as shown below will need to be installed at the Main Electrical Service Disconnect.

CAUTION

POWER TO THIS BUILDING IS ALSO SUPPLIED FROM THE FOLLOWING SOURCES WITH DISCONNECTS LOCATED AS SHOWN.

