


SECTION A-A



PLAN VIEW

DIMENSIONS		
LIQUID CAPACITY (GALLONS)	WIDTH "A"	LENGTH "B"
750	4'-0"	8'-1"
1000	5'-1"	8'-2"
1200	5'-9"	8'-6"
1500	5'-7"	10'-8"

NOTES

1. TANK SHALL BE DESIGNED FOR H-20 TRAFFIC WHEEL LOAD WITH DRY SOIL CONDITIONS (WATER TABLE BELOW TANK).
2. SUITABLE NATIVE SOIL OR CRUSHED AGGREGATE BASE SHALL BE COMPACTED TO 90% RELATIVE COMPACTION AND LEVELED.

CITY OF REDLANDS MUNICIPAL UTILITIES AND ENGINEERING DEPARTMENT

**GREASE INTERCEPTORS
750-1500 GALLONS**

STD. DWG. NUMBER
226

APPROVED: *Michael Pool* DATE 6/24/19

Michael Pool, Assistant City Engineer RCE 49585

SHEET 1 OF 1