



**NOTES**

1. TANK SHALL BE DESIGNED FOR H-20 TRAFFIC WHEEL LOAD WITH DRY SOIL CONDITIONS (WATER TABLE BELOW TANK).
2. SUITABLE NATIVE SOIL OR CRUSHED AGGREGATE BASE SHALL BE COMPACTED TO 90% RELATIVE COMPACTION AND LEVELED.

**CITY OF REDLANDS MUNICIPAL UTILITIES AND ENGINEERING DEPARTMENT**

**SAMPLE BOX**

STD. DWG. NUMBER

**228**

APPROVED:

*Michael Pool*

DATE

6/24/19

SHEET 1 OF 1

REV.	BY	DATE

Michael Pool, Assistant City Engineer RCE 49585