Water Systems Master Plan (DRAFT)



August 2, 2022



TABLE OF CONTENTS

EXECUT		1
Introdu	ction	
Section	1 – General Info	rmation1
Section	2 - Existing Infra	structure
Section	3 - Historic Wate	er Use1
Section	4 - Water Supply	y1
Section	5 - Design Criter	ia1
Section	6 - Existing Syste	em Analysis2
Section	7 - Future Syste	m2
Section	8 - Water Qualit	y Analysis
Section	9 - Water Syster	n Operation and Maintenance
Section	10 - Capital Imp	rovement Program2
1		RMATION
1.1		RIPTION
1.2		
1.3	WATER SERVICE	E AREA
1.4	POPULATION	
		ASTRUCTURE
2		
2.1	GENERAL DESCR	RIPTION
	2.1.1	POTABLE WATER SYSTEM
	2.1.2	NON-POTABLE WATER SYSTEM
	2.1.3	RECYCLED WATER SYSTEM
2.2	PRESSURE ZONE	ES
	POTABLE WATE	R PRESSURE ZONES11
	2.2.1	ZONE 1350
	2.2.2	ZONE 1570
	2.2.3	ZONE 1750
	2.2.4	ZONE 1900
		ZONE 2100
	2.2.6	ZONE 2340



	2.2.7	ZONE 2600	13
	NON-POTABLE	WATER SYSTEMS	13
	2.2.8	SYSTEM 1	13
	2.2.9	SYSTEM 2	13
	2.2.10	SYSTEM 3	13
	2.2.11	SYSTEM 4	13
	2.2.12	SYSTEM 5	13
	2.2.13	SYSTEM 6	
	2.2.14	SYSTEM 7	
	2.2.15	SYSTEM 8	
	RECYCLED WAT	TER PRESSURE ZONES	14
	2.2.16	ZONE 1	14
2.3	STORAGE RESE	RVOIRS	16
	POTABLE WAT	ER SYSTEM	16
	NON-POTABLE	WATER SYSTEM	17
	2.3.1	SYSTEM 1	17
	2.3.2	SYSTEM 2	17
	2.3.3	SYSTEM 3	17
	2.3.4	SYSTEM 4	17
	2.3.5	SYSTEM 5	17
	2.3.6	SYSTEM 6	17
	2.3.7	SYSTEM 7	17
	2.3.8	SYSTEM 8	
	RECYCLED WAT	TER SYSTEM	17
2.4	WELLS		17
	POTABLE WAT	ER SYSTEM WELLS	17
	NON-POTABLE	WATER SYSTEM WELLS	18
2.5	BOOSTER PUM	PS	19
	POTABLE WAT	ER SYSTEM	19
	NON-POTABLE	WATER SYSTEM	20
	RECYCLED WAT	FER SYSTEM	20
2.6	WATER TREAT	MENT PLANTS	21
	2.6.1	HORACE P. HINCKLEY WATER TREATMENT PLANT	21
	2.6.2	HENRY TATE WATER TREATMENT PLANT	21
	2.6.3	WASTEWATER TREATMENT PLANT	21
2.7	FACILITY SEISM	IIC ANALYSIS	22



3	WATER USE		.24
3.1	GENERAL DESCRIPTION2		
3.2	WATER DEMAN	ID	. 24
	POTABLE WATE	R SYSTEM	. 24
	NON-POTABLE	WATER SYSTEM	. 25
	RECYCLED WAT	ER SYSTEM	. 26
3.3	FIRE FLOW		.26
3.4	CONSERVATION	N MEASURES	.27
	3.4.1	WATER SHORTAGE CONTINGENCY PLAN	. 27
	3.4.2	DEMAND MANAGEMENT MEASURES	. 28
3.5	FUTURE WATER	R USE	. 28
	POTABLE WATE	R SYSTEM	. 28
	NON-POTABLE	WATER/RECYCLED WATER SYSTEMS	. 29
	3.5.1	AREA-BASED DEMAND FACTORS	. 30
	3.5.2	CONNECTION-BASED DEMAND FACTORS	. 31
4	WATER SUPPLY	/	.32
4.1	GENERAL DESC	RIPTION	. 32
	POTABLE WATE	R SYSTEM	. 32
	NON-POTABLE	WATER SYSTEM	. 32
	RECYCLED WAT	ER SYSTEM	. 32
4.2	WATER PRODU	CTION	. 32
	POTABLE WATE	R SYSTEM	. 32
	NON-POTABLE	WATER SYSTEM & RECYCLED WATER SYSTEM	. 34
4.3	DEMAND VARIA	ATION	.36
	4.3.1	AVERAGE DAY DEMAND	. 36
	POTABLE WATE	R SYSTEM	. 36
	NON-POTABLE	WATER SYSTEM	. 36
	RECYCLED WAT	ER SYSTEM	. 36
	4.3.2	MAXIMUM DAY DEMAND	. 37
	-	R SYSTEM	-
		WATER SYSTEM	
		ER SYSTEM	
	4.3.3	PEAK HOUR DEMAND	
	POTABLE WATER SYSTEM		
	NON-POTABLE	WATER SYSTEM	. 38



	RECYCLED WA	TER SYSTEM	
4.4	EMERGENCY (CONNECTIONS	
4.5	PRODUCTION-	-DEMAND PROJECTION	
	4.5.1	PROJECTION	
	POTABLE WAT	FER SYSTEM	
	NON-POTABLE	E WATER SYSTEM	
5	DESIGN CRITE	RIA	41
5.1	GENERAL DES	CRIPTION	41
5.2	DESIGN CRITE	RIA	41
	5.2.1	DEMAND	41
	POTABLE WAT	TER SYSTEM	
	5.2.2	SUPPLY	
	POTABLE WAT	FER SYSTEM	
	NON-POTABLE	E WATER SYSTEM & RECYCLED WATER SYSTEM	
	5.2.3	STORAGE VOLUME	
	POTABLE WAT	FER SYSTEM	41
	NON-POTABLE	E WATER SYSTEM	
	RECYCLED WA	TER SYSTEM	
	5.2.4	PUMP STATIONS	
	POTABLE WAT	TER SYSTEM	
		E WATER SYSTEM	
	RECYCLED WA	TER SYSTEM	
	5.2.5	WATER TREATMENT	
	5.2.6	SYSTEM PRESSURE	
	POTABLE WAT	TER SYSTEM	
	NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM		
	5.2.7	PIPE VELOCITY	
	5.2.8	PIPELINE REDUNDANCY	
	5.2.9	SUMMARY OF DESIGN CRITERIA	
	POTABLE WATER SYSTEM		
	NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM		45
5.3	PLANNING CR	ITERIA	
	5.3.1	METHODOLOGY	
	5.3.2	AVERAGE SERVICE LIFE	
	5.3.3	PERFORMANCE INDICATORS	



6		EM ANALYSIS
6.1	GENERAL DESC	CRIPTION
6.2	METHODOLOG	
6.3	HYDRAULIC M	ODEL CALIBRATION
6.4	EXISTING SUPPLY ANALYSIS – POTABLE WATER SYSTEM	
	6.4.1	SCENARIO 1: EXISTING SYSTEM, ADD, EPS, MAX PRESSURE OVER 24 HOURS 54
	6.4.2	SCENARIO 2: EXISTING SYSTEM, MDD, EPS, MAX PRESSURE OVER 24 HOURS 54
	6.4.3	SCENARIO 3: EXISTING SYSTEM, MDD, EPS, MAX VELOCITY OVER 24 HOURS 54
	6.4.4 FIRE EVENT (St	SCENARIO 4: EXISTING SYSTEM, MDD, FIRE FLOW, RESIDUAL PRESSURE DURING eady State)
	6.4.5	SCENARIO 5: EXISTING SYSTEM, PHD, STEADY-STATE SCENARIO, MIN PRESSURE 54
	6.4.6	SCENARIO 6: EXISTING SYSTEM, PHD, STEADY-STATE SCENARIO, MAX VELOCITY 54
6.5	EXISTING SUPP	PLY ANALYSIS – NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM 61
	6.5.1	ZONE 1 SUPPLY
	6.5.2	SYSTEM 2 SUPPLY
	6.5.3	SYSTEM 3 SUPPLY61
	6.5.4	DETACHED SYSTEMS
	6.5.5	SCENARIO 1, EXISTING SYSTEM, ADD, EPS, MAX PRESSURE OVER 24 HOURS 61
	6.5.6	SCENARIO 2, EXISTING SYSTEM, MDD, EPS, MAX PIPE VELOCITY OVER 24 HOURS 61
	6.5.7	OTHER AGENCIES
7		M66
7.1	GENERAL DESC	CRIPTION
7.2	FUTURE SUPPL	Y ANALYSIS – POTABLE WATER SYSTEM
	7.2.1 RESIDUAL PRES	SCENARIO 1 FUTURE DEMAND, EXISTING SYSTEM, MDD, FIRE FLOW SCENARIO, SSURE DURING FIRE HOURS
	7.2.2 PRESSURE OVE	SCENARIO 2 FUTURE DEMAND, EXISTING SYSTEM, MDD, EPS SCENARIO, MAX ER 24 HOURS
	7.2.3 HOURS	SCENARIO 3 FUTURE DEMAND, ADD, EPS SCENARIO, MAX PRESSURE OVER 24 66
	7.2.4 HOURS	SCENARIO 4 FUTURE DEMAND, MDD, EPS SCENARIO, MIN PRESSURE OVER 24 66
	7.2.5 HOURS	SCENARIO 5 FUTURE DEMAND, MDD, EPS SCENARIO, MAX VELOCITY OVER 24 67



	7.2.6 RESIDUAL PRE	SCENARIO 6 FUTURE DEMAND, FUTURE SYSTEM, MDD, FIRE FLOW SCEN, SSURE DURING FIRE HOURS.	
7.3	FUTURE SUPPL	LY ANALYSIS – NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM	74
	7.3.1	SCENARIO 1, FUTURE SYSTEM, ADD, EPS, MAX PRESSURE OVER 24 HOURS	74
	7.3.2	SCENARIO 2, FUTURE SYSTEM, ADD, EPS, MAX PIPE VELOCITY OVER 24 H	OURS
	7.3.3	SCENARIO 3, FUTURE SYSTEM, MDD, EPS, MAX PRESSURE OVER 24 HOURS.	74
	7.3.4	SCENARIO 4, FUTURE SYSTEM, MDD, EPS, MAX PIPE VELOCITY OVER 24 H0 74	OURS
7.4	SUMMARY OF	DEFICIENCIES	79
	7.4.1	POTABLE WATER SYSTEM	79
	7.4.2	NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM	79
7.5	MITIGATION C	OF DEFICIENCIES	
	7.5.1	METHODOLOGY	80
	7.5.2	PROJECTS FOR FUTURE CONDITIONS – POTABLE WATER SYSTEM	80
	7.5.3 RECYCLED WA	PROJECTS FOR FUTURE CONDITIONS – NON-POTABLE WATER SYSTE TER SYSTEM	
8	-	ITY	
8.1		5Y	
8.2	REGULATORY	REQUIREMENTS	85
8.3	GOALS AND PF	REFERENCES	85
8.4	ASBESTOS		
8.4 8.5		ER QUALITY	86
			86 86
	GROUNDWAT	ER QUALITY	86 86 86
8.5	GROUNDWATH 8.5.1 SOURCE WATE	ER QUALITY BUNKER HILL SUBBASIN/SBB	86 86 86 86
8.5 8.6	GROUNDWATH 8.5.1 SOURCE WATE DISINFECTION	ER QUALITY BUNKER HILL SUBBASIN/SBB ER QUALITY	86 86 86 86 87
8.5 8.6 8.7	GROUNDWATH 8.5.1 SOURCE WATE DISINFECTION WATER AGE	ER QUALITY BUNKER HILL SUBBASIN/SBB ER QUALITY	86 86 86 86 87 87
8.58.68.78.8	GROUNDWATH 8.5.1 SOURCE WATE DISINFECTION WATER AGE PO	ER QUALITY BUNKER HILL SUBBASIN/SBB ER QUALITY	86 86 86 86 87 87 87
 8.5 8.6 8.7 8.8 8.9 	GROUNDWATH 8.5.1 SOURCE WATE DISINFECTION WATER AGE WATER AGE PO WATER AGE D	ER QUALITY BUNKER HILL SUBBASIN/SBB ER QUALITY OTENTIAL HEALTH IMPACTS	86 86 86 87 87 87 88
 8.5 8.6 8.7 8.8 8.9 8.10 	GROUNDWATH 8.5.1 SOURCE WATE DISINFECTION WATER AGE MATER WATER AGE PO WATER AGE DO CITY OF REDLA	ER QUALITY BUNKER HILL SUBBASIN/SBB ER QUALITY OTENTIAL HEALTH IMPACTS ETERMINATION	86 86 86 87 87 87 88 88
 8.5 8.6 8.7 8.8 8.9 8.10 8.11 	GROUNDWATH 8.5.1 SOURCE WATH DISINFECTION WATER AGE IN WATER AGE DI CITY OF REDLA INDICATORS O	ER QUALITY BUNKER HILL SUBBASIN/SBB ER QUALITY OTENTIAL HEALTH IMPACTS ETERMINATION ANDS WATER SUPPLY SYSTEM AGE	86 86 86 87 87 87 88 88 89
 8.5 8.6 8.7 8.8 8.9 8.10 8.11 8.12 	GROUNDWATH 8.5.1 SOURCE WATH DISINFECTION WATER AGE PO WATER AGE DO CITY OF REDLA INDICATORS OF WATER SYSTER GENERAL DESC	ER QUALITY BUNKER HILL SUBBASIN/SBB ER QUALITY OTENTIAL HEALTH IMPACTS ETERMINATION ANDS WATER SUPPLY SYSTEM AGE DF HIGH WATER AGE	86 86 86 87



9.3	WORK ORE	DER PROCESS	91
9.4	INSPECTIO	N AND MAINTENANCE	91
9.5	WATER SYS	STEM STAFF AND MANAGEMENT	91
10	CAPITAL IN	MPROVEMENT PROGRAM	94
10.1	GENERAL [DESCRIPTION	94
	10.1.1	APPROACH TO PLANNING LEVEL COSTS	94
10.2	OPINION C	DF PROBABLE COST	96
	10.2.1	CIP ITEM W1: POTABLE WATER DISTRIBUTION SYSTEM	96
	10.2.2	CIP ITEM W2: HINCKLEY TREATMENT PLANT	96
	10.2.3	CIP ITEM W3: TATE TREATMENT PLANT	96
	10.2.4	CIP ITEM W4: POTABLE WATER BOOSTER PUMP STATIONS	97
	10.2.5	CIP ITEM W5: POTABLE WATER STORAGE RESERVOIRS	97
	10.2.6	CIP ITEM W6: GROUNDWATER WELLS	97
	10.2.7	FUTURE WATER SUPPLY PLANNING	98
	10.2.8	CIP NP1: NON-POTABLE WATER SYSTEM IMPROVEMENTS	98
	10.2.9	CIP NP2: RECYCLED WATER SYSTEM IMPROVEMENTS	98
10.3	PROJECTS	AND COSTS	98
	10.3.1	POTABLE WATER SYSTEM CIP PROJECT RECOMMENDATIONS	
	10.3.2	NON-POTABLE WATER SYSTEM CIP PROJECT RECOMMENDATIONS	103
10.4	THE CAPITAL IMPROVEMENT PROJECTS		
	10.4.1	POTABLE WATER SYSTEM CIP PROJECT DESCRIPTIONS	105
	10.4.2	NON-POTABLE WATER SYSTEM CIP PROJECT DESCRIPTIONS	113
11	LIST OF AP	PENDICES	
12	REFERENC	ES	



LIST OF TABLES

Table 1-1: City of Redlands Land Use	
Table 1-2: Redlands Population Growth (1960-2045)	9
Table 1-3: Water Service Area Predicted Population Growth	.10
Table 2-1: Existing Potable Water System Storage Reservoirs	. 16
Table 2-2: Potable Water System Wells	
Table 2-3: Non-Potable Water System Wells	.18
Table 2-4: Booster Pump Data	. 19
Table 2-5: City of Redlands Typical Tertiary Treated Title 22 Recycled Water	.22
Table 3-1: Historical Water Production and Demand (AF/Year)	.24
Table 3-2: Historical Non-Potable Water Demand (AF/Year)	. 25
Table 3-3: 2021 Non-Potable Water Users	
Table 3-4: Fire Flow Criteria	
Table 3-5: Potable Water Demand Projection (AF/Year)	. 29
Table 3-6: Potential Non-Potable Water Users	
Table 3-7: Potential Non-Potable Water Users	.30
Table 3-8: Future Water Use Projections by Land Use (AF/Year)	. 30
Table 3-9: Future Water Projections by Connection	
Table 4-1: Potable Water Production Sources (AF/Year)	. 32
Table 4-2: Monthly Potable Water Production	
Table 4-3: Monthly Non-Potable Water & Recycled Water Production/Distribution (MGD)	.34
Table 4-4: Non-Potable Groundwater Well Production (MGD)	
Table 4-5: Non-Potable Water System Losses	. 36
Table 4-6: Active Potable Water Production Facility Capacity	. 38
Table 4-7: Potable Water Demand Projections (MGD)	. 39
Table 4-8: Projected Production Demands Assuming Optional Expansion	.40
Table 5-1: Storage Volume by Zone	
Table 5-2: Design Criteria Summary – Potable Water System	.44
Table 5-3: Design Criteria Summary - Non-potable & Recycled Water System	
Table 5-4: Water Facility Average Service Life	.47
Table 5-5: Water Pipeline Average Service Life	.48
Table 6-1: Model Calibration Accuracy	.53
Table 6-2: Undersized Non-Potable Water System Pipelines	. 62
Table 6-3: City-Owned Citrus Groves	
Table 7-1: Potable Water System Deficiencies	.79
Table 7-2: Recommended CIP to Correct Deficiencies	. 80
Table 8-1: Water Age Recommendations	.87
Table 8-2: Potential Water Age Issues	.87
Table 8-3: Storage Reservoir Water Age	
Table 10-1: CIP Project Recommendation OPC Assumptions	.94
Table 10-2: AACE Construction Cost Classes	.95



Table 10-3: 5-Year Potable Water CIP Recommendations	99
Table 10-4: 20-Year Potable Water CIP Recommendations	
Table 10-5: 5-Year Non-Potable Water CIP Recommendations	
Table 10-6: 20-Year Non-Potable Water CIP Recommendations	103
Table 10-7: Pipeline Replacement	105
Table 10-8: Meter Replacement	106
Table 10-9: Meter Retro-Fit	107
Table 10-10: Booster Pump Stations Rehabilitation	109
Table 10-11: Storage Tank Reservoirs	110
Table 10-12: Replacement per Seismic Study	111
Table 10-13: Groundwater Wells	
Table 10-14: Well Study and Treatment	112
Table 10-15: Non-Potable Pipeline Replacement	113
Table 10-16: Ground Water Well CIP list with the Cost Opinion	114

LIST OF FIGURES

Figure 1-1: City of Redlands City Limits	4
Figure 1-2: 2017 General Plan Land Use	
Figure 2-1: Existing Conditions	
Figure 2-2: Potable Water System Hydraulic Profile	
Figure 6-1: Hydraulic Model Scenario 1 Results	
Figure 6-2: Hydraulic Model Scenario 2 Results	
Figure 6-3: Hydraulic Model Scenario 3 Results	
Figure 6-4: Hydraulic Model Scenario 4 Results	
Figure 6-5: Hydraulic Results Scenario 5 Results	
Figure 6-6: Hydraulic Model Scenario 6 Results	
Figure 6-7: Existing System, ADD, EPS, Maximum Pressure Over 24 Hours	64
Figure 6-8: Existing System, MDD, EPS, Maximum Pipe Velocity Over 24 Hours	65
Figure 7-1: Hydraulic Model Future Scenario 1 Results	
Figure 7-2: Hydraulic Model Future Scenario 2 Results	
Figure 7-3: Hydraulic Model Future Scenario 3 Results	
Figure 7-4: Hydraulic Model Future Scenario 4 Results	
Figure 7-5: Hydraulic Model Future Scenario 5 Results	
Figure 7-6: Hydraulic Model Future Scenario 6 Results	73
Figure 7-7: Future System, ADD, EPS, Maximum Pressure Over 24 Hours	75
Figure 7-8: Future System, ADD, EPS, Maximum Pipe Velocity Over 24 Hours	76
Figure 7-9: Future System, MDD, EPS, Maximum Pressure Over 24 Hours	77
Figure 7-10: Future System, MDD, EPS, Maximum Pipe Velocity Over 24 Hours	78
Figure 7-11: Capital Improvement Locations	82
Figure 7-12: Future Conditions with Corrections, Velocity	83
Figure 7-13: Future Conditions with Corrections, Pressure	84



Figure 8-1: Water Age Analysis	90
Figure 10-1: Remaining Pipe Service Life	102
Figure 10-2: Remaining Pipe Service Life	104

LIST OF CHARTS

Chart 1-1: Land Use Areas	6
Chart 3-1: Historical Potable Water Use by Category	25
Chart 4-1: Water Production by Source	33
Chart 4-2: Historic Potable Water Production	34
Chart 4-3: MDD Diurnal Curve for Potable Water, August 2019	37
Chart 6-1: Composite Time-of-Day Demand Curve	51
Chart 6-2: Calibration Results for 1350 PZ Tank Levels – 1	52
Chart 6-3: Calibration Results for 1350 PZ Tank Levels – 2	53
Chart 9-1: Maintenance and Operations Organization Chart	93
Chart 10-1: Potable Water System 5-Year CIP Cost Summary	99
Chart 10-2: Potable Water System 20-Year CIP Cost Summary	101
Chart 10-3: Potable Water Pipeline Remaining Service Life	106
Chart 10-4: Recycled/Non-potable Water Pipeline Remaining Service Life	115



ABBREVIATIONS

2020 UWMP	2020 Urban Water Management Plan
2021 WSCP	2021 Water Shortage Contingency Plan
2022 WSMP	2022 Water System Master Plan
AACE	Association for the Advancement of Cost Engineering
AF	Acre-Feet
Acre-ft/d	Acre-Feet per Day
Acre-ft/yr.	Acre-Feet per Year
ADD	Average Day Demand
AMI	Advanced Metering Infrastructure
AMR	Automated Meter Reader
ASL	Above Sea Level
AWWA	American Water Works Association
BOD	Biological Oxygen Demand
Brady	Richard Brady and Associates, Inc.
BVMWC	Bear Valley Mutual Water Company
CalOSHA	California Division of Occupational Safety and Health Agency
CalWARN	California's Water/Wastewater Agency Response Network
CCR	Consumer Confidence Report
CIP	Capital Improvement Program
City	City of Redlands Municipal Utilities and Engineering Department
CWC	Crafton Water Company
DU	Dwelling Unit
EPA	Environmental Protection Agency
EPS	Extended Period Simulation
ERNIE	Emergency Response Network of the Inland Empire
ES	Equalizing Storage
Fps	Feet Per Second
FSS	Fire Suppression Storage
FY	Fiscal Year
GIS	Geographical Information System
Gpcd	Gallons per capita day
GPD	Gallons per day
GPM	Gallons per minute
HAA5	Haloacedic Acid
Hinckley	Horace P. Hinckley Water Treatment Plant
HP	Horsepower
I-10	Interstate 10
I-210	Interstate 210
MCL	Maximum Contaminate Level
MDD	Maximum Day Demand
MBI	Michael Baker International



ABLISHED .	
MG	Million Gallons
MGD	Million Gallons per day
mg/L	Milligrams per Liter
MUED	Municipal Utilities and Engineering Department
NPW	Non-Potable Water
NPWMP	2005 Non-Potable Water System Master Plan
NTU	Nephelometric Turbidity Unit
0&M	Operations and Maintenance
OPC	Opinion of Probable Cost
OS	Operational Storage
PHD	Peak Hour Demand
PPM	Parts Per Million
PRS	Pressure Reducing Stations
PSI	Pounds per Square Inch
PW	Potable Water
PWMP	1998 Potable Water System Master Plan
RW	Recycled Water
SAR	Santa Ana River
SB	Stand-by Storage
SBBA	San Bernardino Basin Area
SCADA	Supervisor Control and Data Acquisition
SCE	Southern California Edison
SOC	Synthetic Organic Compounds
SOP	Standard Operating Procedure
SWP	State Water Project
SWRCB-DDW	State Water Resources Control Board – Division of Drinking Water
Tate	Henry Tate Water Treatment Plant
TBD	To be determined
TDS	Total Dissolved Solids
TSS	Total Suspended Solids
ттнм	Trihalomethanes
U.S.	United States
VOC	Volatile Organic Compounds
WD	Water Distribution
WP	Water Production
WTP	Water Treatment Plant
WWTP	Wastewater Treatment Plan



EXECUTIVE SUMMARY

Introduction

In 2021, the City of Redlands (City) partnered with Michael Baker International (MBI) to prepare an update to the 1998 Potable Water System Master Plan (PWMP) and the 2005 Non-Potable Water System Master Plan (NPWMP). Both the PWMP and NPWMP, as well as other relevant documents were reviewed and referenced to prepare the 2022 Water System Master Plan (2022 WSMP). The 2022 WSMP includes the City's three (3) water systems: Non-Potable Water (NPW), Potable Water (PW), and Recycled Water (RW) Systems. The most critical outcome of the 2022 WSMP is the development of comprehensive five-year and twenty-year capital improvement program (CIP) recommendations to improve distribution efficiency, reduce non-revenue water, and accommodate growth within the City water service areas. A hydraulic model using Innovyze InfoWater software was developed to analyze existing systems, as well as the impacts of various system improvements. The City's Water Distribution and Water Production staff supplemented these efforts with decades of relative historic knowledge.

The ultimate goal for all three (3) water production and distribution systems is to ensure long-range sustainability for each of these water resources. The City intends to use recommendations developed and identified through this Master Planning process to reduce non-revenue water in each system, maximize the use of non-potable wells to extract contaminants from groundwater resources, and eventually hopes to serve all significant users with non-potable and/or recycled water for landscape irrigation and industrial uses.

The 2022 WSMP is divided into ten (10) Sections, each of which is summarized below.

Section 1 – General Information

This Section provides general information about the City and its water service area.

Section 2 - Existing Infrastructure

This Section details the City's existing NPW, PW, and RW Systems.

Section 3 - Historic Water Use

This Section quantifies and characterizes annual and seasonal water use patterns based on demand data included in the City's 2020 Urban Water Management Plan (2020 UWMP). This information was used to calibrate each hydraulic model, with particular emphasis on maintaining minimum fire protection pressure and flow under several modeling scenarios. It was also used to validate the positive impact of water conservation programs. Water demand projections through the 2045 planning horizon are provided as well.

Section 4 - Water Supply

This Section describes and quantifies the water sources for each system, and identifies various threats and production challenges associated with each system.

Section 5 - Design Criteria

This Section identifies specific water infrastructure planning and design criteria used to evaluate existing infrastructure and to develop CIP project recommendations. These include minimum storage requirements, pumping capacity, and system hydraulics for various demand scenarios.



Section 6 - Existing System Analysis

This Section summarizes development, calibration, and use of the hydraulic model to analyze the existing systems. Scenarios including historic Average Day Demands (ADD), Maximum Day Demands (MDD) with and without fire flow, and Peak Hour Demands (PHD) were modeled to identify deficiencies within each system.

Section 7 - Future System

This Section summarizes additional hydraulic modeling to identify deficiencies as project demands within each system are applied through the planning horizon. The results were used to develop CIP project recommendations for each system.

Section 8 - Water Quality Analysis

This Section summarizes regulatory requirements relative to each system, and identifies potential contamination sources, groundwater basin characteristics, and imported water quality. A distribution system water age analysis was hydraulically modeled to evaluate the potential for taste and odor complaints related to the reduction of disinfection residual over time.

Section 9 - Water System Operation and Maintenance

This Section summarizes findings of an Operation and Maintenance (O&M) practices analysis for each system, and includes recommended improvements.

Section 10 - Capital Improvement Program

This Section identifies recommended short-term (5-Years) and long-term (20-Years) CIP projects based on discussions with City staff and 2022 WSMP analyses. An Opinion of Probable Cost (OPC), in current year dollars, is provided for each CIP project recommendation. Each OPC is developed based on estimated construction quantities, actual construction costs for regional projects of similar scope and size, and vendor quotes. Finally, the OPC for each CIP project was adjusted to account for specific site conditions.



1 GENERAL INFORMATION

1.1 GENERAL DESCRIPTION

The City of Redlands is located in Southern California in the southwestern portion of the County of San Bernardino, and includes approximately 37.5 square miles of land area. The City is approximately sixty (60) miles east of the City of Los Angeles, adjacent to the eastern borders of the cities of San Bernardino and Loma Linda, adjacent to the southern border of the City of Highlands, and adjacent to the western border of the City of Yucaipa. The unincorporated areas of Mentone and Crafton, located just east of the City. The City limits are shown in Figure 1-1.

Several major transportation corridors transverse the City: Interstate 210 (I-210) crosses the western portion of the City, Interstate 10 (I-10) transverses east/west through the middle of the City, and State Route 38 begins within the City limits and transverses east through the City. The Santa Ana River and Mill Creek watersheds are located in the northern and eastern sections of the City, respectively. These watersheds are the source of approximately half of the City's total water supply.

The topography of the City generally slopes downward in the northwesterly direction. The San Bernardino Mountain range is situated to the northeast, Zanja Peak to the east, and the San Jacinto Mountain range to the south. Elevations within the City limits varies between 1,100 feet above sea level (ASL) in the northwest, to 3,300 feet ASL in the east. The City's water service area reaches 2,500 feet ASL. This broad variation in elevation requires multiple pressure zones to distribute water within accepted industry standards throughout each system.

1.2 LAND USES

Although the City is home to large employers such as ESRI, Redlands Community Hospital, and the University of Redlands, the south and east portions of the City are primarily residential communities, with undeveloped land and recreational areas in the San Jacinto foothills. The City's northwestern area is primarily comprised of industrial, commercial, and office developments. The center of the City is primarily residential communities, with small agricultural areas to the east. Most undeveloped areas are in the southern portion of the City and south of the Santa Ana River.

The City's current General Plan (2017) was developed to responsibly manage residential, industrial, and commercial growth. The General Plan also considers the City's "Sphere of Influence," which includes the unincorporated areas of Crafton and Mentone, including large Rural Living and agricultural tracts. Of the two (2), Mentone is more heavily developed, with residential communities and light industrial uses in the west, and agricultural regions in the northwest. It should be noted that the City's sphere of influence includes small portions in the cities of San Bernardino, Loma Linda, Yucaipa, and the County of San Bernardino and are within Redlands' water service area.

The City provides potable and non-potable water to a retail sales area, commonly referred to as the "Donut Hole", northwest of the intersection of I-10 and I-210. This area is not within the City of Redlands jurisdiction, but is an unincorporated part of the County of San Bernardino. This area is primarily developed for commercial and industrial use.






Table 1-1 shows land use designations by area as identified in the General Plan. The comparative use of each category is shown graphically in Chart 1-1. The land use from the City's General Plan is shown in Figure 1-2.

Table 1-1: City of Redlands Land Use								
Land Use	City of Redlands (Acres)	Sphere of Influence (Acres)	Total					
Residential	6,343	4,042	10,385					
Rural Living	9	2,115	2,124					
Very Low Density Residential	2,694	861	3,555					
Low Density Residential	2,643	574	3,217					
Low Medium Density Residential	63	469	532					
Medium Density Residential	520	23	543					
High-Density Residential	414	-	414					
Office, Commercial, Industrial	2,626	147	2,773					
Office	206	-	206					
Commercial	866	55	921					
Commercial/Industrial	1,249	-	1,249					
Light Industrial	305	92	397					
Agricultural and Hillside	5,122	1,322	6,444					
Agricultural	308	220	528					
Hillside Conservation	23	1,102	1,125					
Resource Preservation	4,791	-	4,791					
Public/Institutional	1,271	130	1,401					
Open Space	5,111	510	5,621					
Parks & Golf Courses	600	-	600					
Open Space	4,511	510	5,021					
City ROW	2,881	418	3,299					
	42,556	12,590	55,146					






Chart 1-1: Land Use Areas

Residential development areas comprise approximately thirty-five percent (35%) of the City's total land use, and is divided into six (6) sub-categories: Rural Living, Very Low-Density Residential, Low-Density Residential, Low-Medium Density Residential, Medium-Density Residential, and High-Density Residential. Most Rural Living areas are within Crafton and allow a maximum of one (1) dwelling unit (DU) per five (5) acres of land area. These areas offer an opportunity to expand non-potable water service for agricultural uses, thereby reducing demand for potable water resources.

Office, Commercial and Industrial development areas are consolidated into a single category, and comprise approximately nine percent (9%) of the City's total land use. The General Plan considers maintenance and growth of these areas as essential to striking a balance between residential and employment areas. Office land uses include traditional office spaces and medical offices. Commercial land uses include neighborhood-serving convenience stores, retail centers, and commercial recreational areas. Industrial land use ranges from light industries such as automotive services, to research and development and heavy industry manufacturing facilities. These areas offer an opportunity to expand non-potable and recycled water service, thereby reducing demand for potable water resources.

Agricultural land uses include traditional agricultural areas, as well as areas designed for preservation and conservation of natural resources. This category comprises approximately twenty-one percent (21%) of the City's total land use. Most of this category is in mountain areas and is designated as Resource Preservation, which includes wildlife preservation and activities such as water conservation, open space recreation, and agriculture. These areas offer an opportunity to expand non-potable water service for agricultural uses, thereby reducing demand for potable water resources.


Public/Institutional land uses include developments used for public services, schools, government facilities, airports, public utilities, and facilities used or owned by the City. This category comprises approximately five percent (5%) of the City's total land use.



Open Space land uses comprise approximately nineteen percent (19%) of the City's total land use. This category is divided into parks or miscellaneous open spaces that are primarily unimproved with no immediate plans for development. These areas offer an opportunity to expand non-potable and recycled water service for outdoor irrigation, thereby reducing demand for potable water resources.

City Rights-of-Way (ROW) category is predominantly public streets, and comprises approximately eleven percent (11%) of the City's total land use.

It is important to note that there appear to be some exceptions to the generalization of the categories. For example, the City owns and maintains approximately 184 acres of Citrus Groves. These groves are surrounded by industrial and residential areas and appear to be considered in the nearby corresponding category and are not included in the Open Space category. Additionally, most of the Rural Living subcategorized land is used for agriculture, but is classified as residential.





Legend

2017 (2017 General Plan Land Use						
	Agriculture						
	Rural Living						
	Very Low Density Residential						
	Low Density Residential						
	Low Medium Density Residential						
	Medium Density Residential						
	High Density Residential						
	Office						
	Commercial						
	Commercial/Industrial						
	Light Industrial						
	Public/Institutional						
	Parks/Golf Courses						
	Resourcce Conservation						
	Conservation Preservation						
	Flood Control/Construction Aggregates						
	Vacant						



October 22, 2021

2,250 4,500

Feet

CITY OF REDLANDS WATER MASTER PLAN

Source: City of Redlands, ArcGIS Online

2017 General Plan Land Use

Figure 1.2



1.3 WATER SERVICE AREA

The City's water system serves multiple areas within and beyond the City limits, which includes eastern portions of the cities of San Bernardino and Loma Linda, western portions of the City of Yucaipa, and the unincorporated areas of Mentone, Crafton, and the "Donut Hole". The City distributes potable water within seven (7) pressure zones, non-potable water within three (3) pressure zones, and recycled water within one (1) pressure zone to provide appropriate water pressure throughout each system. These pressure zones are detailed in Section 2. Although the recycled water distribution system is currently limited to a small area in the northwest portion of the City, the non-potable water distribution provides service to a much larger portion of the City and is separated into eight (8) detached systems.

1.4 POPULATION

The City's population has grown at a consistent pace for the last twenty (20) years. In 2020, the City population was 73,168 (2020 Unites States Census data). The General Plan predicts the population will rise to 79,000 by 2035, when the City expects to reach built-out conditions. Table 1-2 provides reported population data and growth rates since 1960.

Year	Population	Annual Growth Rate
1960	27,000	
1970	35,000	3.0%
1980	42,000	2.0%
1990	61,000	4.5%
2000	63,591	0.4%
2005	66,342	0.9%
2010	68,747	0.7%
2015	70,112	0.4%
2020	73,168	0.9%
Note: Based on C	Chart 3-1 from the	2017 General Plan

Table 1-2: Redlands Population Growth (1960-2045)

The water service area extends beyond the City limits to serve residents and businesses within the municipalities and unincorporated areas described in Section 1.3. The 2020 UWMP estimates that the portions of the water service area beyond the City limits serve an additional 10,000 residents currently, and is anticipated to increase to 16,000 by 2045 when these areas are built out. At that time, the City will serve a total population of 95,000. This projection anticipates uniform population growth. Table 1-3 shows the projected population growth of the total water service area through 2045.



Year	2020	2025	2030	2035	2040	2045		
Population Served	83,000	85,400	87,900	90,300	92,700	95,153		
Note: From Table 4-1 in the 2020 Urban Water Management Plan								

Table 1-3: Water Service Area Predicted Population Growth



2 EXISTING INFRASTRUCTURE

2.1 GENERAL DESCRIPTION

2.1.1 POTABLE WATER SYSTEM

The City receives surface water and groundwater from several sources. Two (2) surface water treatment plants, the Horace P. Hinckley Water Treatment Plant (Hinckley) and Henry Tate Water Treatment Plant (Tate), receive surface water primarily from the Santa Ana River (Hinckley) and Mill Creek (Tate). Both sources can also be supplemented by the State Water Project (SWP). Additionally, seventeen (17) active groundwater wells that include four (4) active wellhead treatment systems are strategically located throughout the service area to diversify the City's potable water production sources. Historically, surface water treatment accounts for approximately fifty-one percent (51%) of total annual potable water production.

Potable water is stored in eighteen (18) reservoirs, and is distributed through approximately 450 miles of pipelines within seven (7) pressure zones to provide uniform service pressures. Thirty-eight (38) booster pumps and thirty (30) zone transfer control valves distribute water throughout the system while maintaining each zone's desired hydraulic grade line.

2.1.2 NON-POTABLE WATER SYSTEM

The non-potable water distribution system is limited in service area, and provides untreated groundwater primarily for outdoor landscape irrigation.

2.1.3 RECYCLED WATER SYSTEM

The recycled water distribution system is limited in service area, and provides treated effluent from the City Wastewater Treatment Plant (WWTP) to customers within a small area in the northwest portion of the City. The largest recycled water customer is the Southern California Edison (SCE) Mountain View Power Plant, which uses recycled water through a "Take-or-Pay" agreement to cool equipment. The recycled water volume in this agreement is 3,000 AF/Year.

2.2 PRESSURE ZONES

POTABLE WATER PRESSURE ZONES

The City's potable water pressure zone distribution system was first developed in 1975 and later updated in 1981. Figure 2-1 shows the seven potable water pressure zones and the locations of existing reservoirs, wells, booster pumps, and water treatment plants. The overall system hydraulic profile is shown in Figure 2-2. Each pressure zone is described in detail below.

2.2.1 ZONE 1350

Pressure Zone 1350 serves the western portion of the City's water service area. It is located west of Alabama Street, north and south of the I-10 Freeway, and west of New Jersey Street. The terrain slopes downward northwesterly, and its elevation ranges from 1,050 feet to 1,250 feet. Two (2) reservoirs are used to service this zone: Texas Street and Texas Grove Reservoirs. In addition, two (2) potable wells supply water to this pressure zone: Orange Street 1 and Orange Street 2. These wells provide groundwater directly into the Texas Street and Texas Grove Reservoirs. In addition, four (4) booster pumps labeled



1550, 1551, 1552, and 1553 are located at the Texas Street reservoir site to lift water from Zone 1350 to Zone 1570.

2.2.2 ZONE 1570

Pressure Zone 1570 is bounded by the I-10 Freeway between Alabama Street and University Street and south of I-10 Freeway between New Jersey Street and Cypress Avenue. The terrain slopes downward northwesterly, and its elevation ranges from 1,190 feet to 1,470 feet. Three (3) reservoirs are used to service this zone: Dearborn, Highland Avenue, and Smiley Heights Reservoirs. Six (6) groundwater wells supply water to this pressure zone: Well No. 10, Well No. 13, Well No. 38, Well No. 39, Church Street Well, and Orange Street Well. Well No. 10 and Well No. 13 are able to supply groundwater directly into the Highland Avenue Reservoir. However, both have been idle over the last five (5) years. Ten (10) booster pumps are used to service this zone. Two (2) booster pumps, 1783 and 1784, are located at the Smiley Reservoir and lift water into Zone 1750. Pumps 1761 and 1931 are located at the Dearborn Reservoir, where Pump 1761 lifts water to Zone 1750 and Pump 1931 lifts water to Zone 1900. Booster pumps 1720, 1721, 1722, 2174, 2176, and 2177 are located at the Highland Reservoir and lift water to Zones 1750 and 2100.

2.2.3 ZONE 1750

Pressure Zone 1750 serves the downtown area of the City of Redlands. It is bounded on the southwest by Cypress Avenue, on the northwest by University Street, and on the northeast by Bear Valley Canal and Wabash Avenue. Highland Avenue and adjoining streets cover the southeast boundary of this pressure zone. The terrain slopes downward in a northwesterly direction, and its elevation ranges from 1,390 feet to 1,661 feet. Three (3) reservoirs are used to service this zone: Agate Avenue, South Avenue, and Arroyo Reservoirs. The Hinckley Water Treatment Plant (WTP) supplies water directly into the Agate Reservoir. In addition, six (6) groundwater wells provide water to this zone: Agate 2 Well, Airport 1 Well, Airport 2 Well, Mentone Acres 2 Well, Rees Well, and Muni Well. There are ten (10) booster pumps that are located within this zone. Situated at South Reservoir, booster pumps 1927 and 1928 lift water to Zone 1900 and booster pumps 2124, 2125, and 2126 lift water to Zone 2100. Located at Agate Reservoir, booster pumps 1951, 1952, and 1953 lift water to Zone 1900. Booster pumps 1723 and 1724 are used to move water within this zone.

2.2.4 ZONE 1900

Pressure Zone 1900 is bounded to the west by Highland Avenue and Wabash Avenue, King Street south of Colton Avenue, and Crafton Avenue north of Colton Avenue on the north side of the I-10 Freeway. South of the I-10 Freeway, the zone is bordered by Highland Avenue, Sunset Drive, Center Street, Elizabeth Street, Sunridge Way, Lynne Court, and Ford Street. The terrain slopes downward in a northwesterly direction, and its elevation ranges from 1,470 feet to 1,800 feet. Two (2) reservoirs are used to service this zone: Fifth Avenue and Margarita Reservoirs. In addition, one (1) groundwater well, the Madeira Well, supplies water to this pressure zone. Booster pumps 2131, 2132, 2310, and 2311 are located at the Fifth Avenue Reservoir. Pumps 2131 and 2132 are used to lift water to Zone 2100. Pumps 2310 and 2311 are used to lift water to Zone 2340.

2.2.5 ZONE 2100

Pressure Zone 2100 is bounded by King Street south of Colton Avenue, Crafton Avenue north of Colton Avenue, Reservoir Road, and Highland Avenue, and extends southwesterly towards the I-10 Freeway. South of the I-10 Freeway, the zone is bordered by Center Street, Elizabeth Street, Sunridge Way, Lynne



Court, Ford Street, Wabash Avenue, and the Redlands Country Club. The terrain slopes downward northwesterly, and its elevation ranges from 1,640 feet to 2,060 feet. Three (3) reservoirs are used to service this zone: County Club 1, Country Club 2, and Ward Way Reservoirs. Three (3) wells supply groundwater to this pressure zone: Lugonia 3 Well, Lugonia 6 Well, and Maguet 2 Well. Booster pumps 2384, 2385, 2386, and 2387 are located at the Country Club Reservoir and lift water to Zone 2340. Booster pumps 2381 and 2382 are situated at the Ward Way Reservoir and lift water to Zone 2600.

2.2.6 ZONE 2340

Pressure Zone 2340 is bounded by Sunset Drive, the Redlands Country Club, and Wabash Avenue, south of I-10 Freeway. North of the I-10 Freeway, Zone 2340 extends southeast along Sand Canyon Road from Crafton Avenue to Colorado Street and extends along Mill Creek Road, east of Orange Lane. The terrain slopes downward northwesterly, ranging from about 1,890 feet to 2,340 feet in elevation. Two (2) reservoirs are used to service this zone: Sand Canyon and Sunset Reservoirs. The Tate WTP is located within this zone and supplies water into the Ward Way Reservoir in Zone 2100. Pumps 2610 and 2611 are located at the Sand Canyon Reservoir and lift water to Zone 2600.

2.2.7 ZONE 2600

Pressure Zone 2600 extends along Mill Creek Road, east of the Mill Creek Reservoir and Crafton Hills Reservoir, to Crafton Hills College. The terrain slopes downward northwesterly, and its elevation ranges from 2,270 feet to 2,480 feet. The Crafton, Mill Creek 1, and Mill Creek 2 Reservoirs are located in this pressure zone. Booster Pumps 2510 and 2511 A/B are situated at the Mill Creek Reservoir and transfer water within Zone 2600.

NON-POTABLE WATER SYSTEMS

2.2.8 SYSTEM 1

This non-potable water system is located in the 1350 pressure zone. The system receives recycled water from the WWTP and untreated groundwater from the California Street Well hydro pneumatic system.

2.2.9 SYSTEM 2

This non-potable water system is located in the 1570 pressure zone. Well No. 30A, Well No. 31A, and Well No. 32 provide untreated groundwater to this system. System pressure is maintained by two (2) package skid booster pumps.

2.2.10 SYSTEM 3

This non-potable water system is a gravity fed located in the 1570 pressure zone. Well No. 41 and New York Street Well provide untreated groundwater to this system. This system is a weir box gravity fed system also known as the "B" Contract system.

2.2.11 SYSTEM 4

This non-potable water system is located in the 1570 pressure zone. Well No. 11 provides untreated groundwater for landscape irrigation to Ford Park. System pressure is maintained by a hydro pneumatic tank.

2.2.12 SYSTEM 5

This non-potable water system is located in the 1570 pressure zone. Well No. 16 is a gravity fed system that provides untreated groundwater to Bear Valley Mutual Water Company (BVMWC) for non-potable deliveries within their distribution network.



2.2.13 SYSTEM 6

This non-potable water system is located in the 1750 pressure zone. Agate Well No. 1 and Crafton Well is a gravity fed system that provides untreated groundwater to BVMWC for non-potable deliveries within their distribution network.

2.2.14 SYSTEM 7

This non-potable water system is located in the 1900 pressure zone. Redland Heights Well is a gravity fed system that provides untreated groundwater for landscape irrigation to Redlands Country Club.


2.2.15 SYSTEM 8

This non-potable water system is located in the 1900 pressure zone. Well No. 36 is a closed loop system that provides untreated groundwater for landscape irrigation to Hillside Memorial Park.

RECYCLED WATER PRESSURE ZONES

2.2.16 ZONE 1

This recycled water pressure zone is bounded by the Santa Ana River to the north, Mountain View Avenue to the west, Citrus Avenue and I-10 to the south, and Alabama Street and New Jersey Street to the east. Treated effluent from the City WWTP is provided to customers within this small area in the northwest portion of the City. The largest recycled water customer is the SCE Mountain View Power Plant, which uses recycled water through a "Take-or-Pay" agreement to cool equipment. Although this system is capable of blending flow with untreated groundwater provided by the California Street Well, only recycled water can serve the SCE Mountain View Avenue power plant. Mountain View Power Plant has their own well that can make up to fifty percent (50%) of their cooling water needs.






Figure 2.1

Existing Conditions



2.3 STORAGE RESERVOIRS

POTABLE WATER SYSTEM

The current storage system includes eighteen (18) potable reservoirs. Treated surface water from Hinckley and Tate is supplemented by treated groundwater to supply the potable water reservoirs through a series of booster pumps. These reservoirs can store a cumulative maximum of 54.3 million gallons (MG). Table 2-1 provides the storage capacity, pressure zone served, material type, construction year, minimum water surface elevation, and maximum water surface elevation for each potable water reservoir.

No.	Designation	Capacity (MG) (1)	Primary Zone Served (2)	Type of Construction (2)	Year Installed (2)	Min. Water Elev. (FT) ⁽²⁾	Max. Water Elev. (FT) (2)
1	Texas Grove	3.9	1350	Steel	2004	1331	1350
2	Texas Street	1	1350	Steel	1956	1315.25	1350
	Zone 1350 Total	4.9					
3	Dearborn	10.6	1570	Concrete	1972	1552.5	1578
4	Highland	10	1570	Concrete	1976	1556.9	1584.83
5	Smiley	3	1570	Steel	1964	1538	1570
	Zone 1570 Total	23.6					
6	Agate	3	1750	Steel	1968	1725	1746.83
7	Arroyo	0.5	1750	Steel	1965	1710	1750
8	South	2	1750	Steel	1964	1724	1750
	Zone 1750 Total	5.5					
9	Fifth Avenue	5	1900	Concrete	1974	1882.5	1905
10	Margarita	2.4	1900	Concrete	1964	1878.62	1895
	Zone 1900 Total	7.4					
11	Country Club 1	1	2100	Steel Inside	2010	2096.67	2111
				Concrete			
12	Country Club 2	2	2100	Concrete	1969	2101.37	2120
13	Ward Way	2	2100	Steel	1958	2068.5	2100
	Zone 2100 Total	5					
14	Sand Canyon	3.5	2340	Steel	1973	2314	2353.62
15	Sunset	3	2340	Steel	1967	2277	2340
	Zone 2340 Total	6.5					
16	Mill Creek 1	0.2	2600	Steel	1962	2375	2390
17	Mill Creek 2	0.2	2600	Steel	1987	2375	2390
18	Crafton	1	2600	Steel	1970	2560.25	2590
	Zone 2600 Total	1.4					
	Total Storage	54.3					
	Capacity						
Note:	(1) Reservoir Data In	formation 20	18-2021; (2) F <mark>aci</mark>	lities Data Informa	tion 2018-202	21	

Table 2-1: Existing Potable Water System Storage Reservoirs



NON-POTABLE WATER SYSTEM

The current storage system includes two (2) small poly tanks and three (3) cement lined open air reservoir throughout the distribution system.

2.3.1 SYSTEM 1

This non-potable system provides no storage.

2.3.2 SYSTEM 2

This non-potable system utilizes two (2) 12,150 gallon, poly storage tanks located at the Texas St. Reservoir site used to supply the on-site booster pump station.

2.3.3 SYSTEM 3

This non-potable system provides no storage.

2.3.4 SYSTEM 4

This non-potable system utilizes two (2) cement lined open air reservoir used for recreation within Ford Park.

2.3.5 SYSTEM 5

This non-potable system provides no storage.

2.3.6 SYSTEM 6

This non-potable system provides no storage.

2.3.7 SYSTEM 7

This non-potable system utilizes one (1) cement lined, open air reservoir used as a water feature within the Redlands Country Club golf course.

2.3.8 SYSTEM 8

This non-potable system provides no storage.

RECYCLED WATER SYSTEM

Currently, no recycled water storage reservoirs exist, which prevents the City from expanding the recycled water distribution system beyond the existing customer base. However, two (2) 1.5 MG recycled water storage reservoirs are currently being engineered for construction in the future at the City WWTP.

2.4 WELLS

POTABLE WATER SYSTEM WELLS

The City operates seventeen (17) active groundwater wells that supply treated water to the potable water distribution system. Five (5) of these wells operate seasonally during peak demand periods. Well No. 10 and Well No. 13 have not been used for several years due to elevated levels of Nitrate, Perchlorate and 1,2 Dibromo-3chloropropane. Both wells are scheduled for rehabilitation within the next three (3) years.

Table 2-2 provides the discharge zone, capacity, ground elevation, and water surface elevation for each potable water system well.



Discharge to Canasity Cround Flow Mater Surface									
	Well Name	Discharge to	Capacity	Ground Elev.	Water Surface				
No.	(1)	Zone	(GPM)	(FT)	Elev. (FT)				
	(-)	(1)	(1)	(1)	(1)				
1	North Orange Street 1	1350	2900	3050	293				
2	North Orange Street 2	1350	2900	3105	288				
3	10	1570	1400	1650	80				
4	13	1570	3000	1630	62				
5	38	1570	1600	1634	520				
6	39	1570	1250	1255	535				
7	Church Street	1570	2000	2136	485				
8	Orange Street	1570	1500	1165	459				
9	Airport 1	1750	1500	1316	498				
10	Airport 2	1750	1000	119	545				
11	Mentone Acres 2	1750	1600	1787	491				
12	Rees	1750	550	1964	544				
13	Muni	1750	2200	1570	335				
14	Madeira	1900	600	697	399				
15	Lugonia 3	2100	250	500	35				
16	Lugonia 6	2100	250	1970	59				
17	Maguet 2	2100	400	249	253				
Note:	Note: (1) Facilities Data Information from SCE pump efficiency tests dated 2018 - 2020								

Table 2-2: Potable Water System Wells

NON-POTABLE WATER SYSTEM WELLS

The City operates twelve (12) wells that supply untreated groundwater to the non-potable water distribution systems, although the Agate 1 Well and Well No. 41 have not been used for several years. Additionally, untreated groundwater from the Crafton Well can be used to supplement the non-potable water system. Table 2-3 provides the discharge pressure system, flow rate, head, pumping efficiency, and most recent pump efficiency testing date for each non-potable well.

No.	Name	Discharge System	Flow (GPM)	Head (ft)	Efficiency (%)	Testing Date
1	California	1	1,344	462.8	52%	3/4/2016
2	30A	2	1,296	295.4	57%	5/18/2018
3	31A	2	878	258.6	32%	4/20/2016
4	32	2	1,555	285.7	55%	5/18/2018

 Table 2-3:
 Non-Potable Water System Wells



No.	Name	Discharge System	Flow (GPM)	Head (ft)	Efficiency (%)	Testing Date		
5	New York Street	3	575	230	57%	3/4/2016		
6	41	3	1,575	N/A	N/A	N/A		
7	11	4	345	176.7	54%	6/25/2018		
8	16	5	680	84.7	39%	6/11/2018		
9	Agate 1	6	1,075	160.1	78%	5/18/2018		
10	Crafton	6	1,841	254.6	60%	10/30/2018		
11	Redlands Heights	7	468	394.6	57%	6/18/2018		
12	36	8	648	N/A	N/A	N/A		
Note: Information from 2016-2018 Testing Data								

2.5 BOOSTER PUMPS

POTABLE WATER SYSTEM

The potable water distribution system includes twelve (12) pump stations with thirty-eight (38) individual booster pumps that transfer water between pressure zones. Table 2-4 provides the pump name, pump station, approximate elevation, pump design head, and pump design flow, and source (suction) and destination (discharge) pressure zones for each booster pump.

			Pump	Design	Design	Z	one (1)
No.	Pump Name (1)	Pump Station (1)	Elevation (FT) (1)	Head (FT) (1)	Flow (GPM) (1)	Source	Destination
1	1550	Texas	1320	325	2000	1350	1570
2	1551	Texas	1320	325	2000	1350	1570
3	1552	Texas	1320	280	1800	1350	1570
4	1553	Texas	1320	320	2000	1350	1570
5	1761	Dearborn	1570	150	1200	1570	1750
6	1931	Dearborn	1570	447	860	1570	1900
7	2174	HAWC	1572	810	700	1570	2100
8	2176	HAWC	1572	575	740	1570	2100
9	2177	HAWC	1572	550	700	1570	2100
10	1720	HAWC	1572	230	170	1570	1750
11	1721	HAWC	1572	150	1250	1570	1750
12	1722	HAWC	1572	230	2300	1570	1750
13	1783	Smiley Heights	1548	230	300	1570	1750

Table 2-4: Booster Pump Data



			Pump	Design	Design	Z	one (1)
No.	Pump Name ⁽¹⁾	Pump Station (1)	Elevation (FT) (1)	Head (FT) (1)	Flow (GPM) (1)	Source	Destination
14	1784	Smiley Heights	1552	245	420	1570	1750
15	1927	South	1748	185	2050	1750	1900
16	1928	South	1748	196	1750	1750	1900
17	2124	South	1748	550	980	1750	2100
18	2125	South	1749	410	1050	1750	2100
19	2126	South	1749	425	766	1750	2100
20	1951	Agate	1732	180	1010	1750	1900
21	1952	Agate	1732	193	960	1750	1900
22	1953	Agate	1732	191	1623	1750	1900
23	1724	Ford Park	1555	N/A	N/A	1750	1750
24	1723	Ford Park	1555	N/A	N/A	1750	1750
25	2131	Fifth Avenue	1905	250	890	1900	2100
26	2132	Fifth Avenue	1905	246	850	1900	2100
27	2310	Fifth Avenue	1909	257	463	2100	2340
28	2311	Fifth Avenue	1909	260	1580	2100	2340
29	2384	Country Club	2100	231	1038	2100	2340
30	2385	Country Club	2100	340	800	2100	2340
31	2386	Country Club	2105	290	357	2100	2340
32	2387	Country Club	2105	241	1232	2100	2340
33	2381	Ward Way	2076	394	150	2100	2340
34	2382	Ward Way	2076	420	160	2100	2340
35	2610	Sand Canyon	2332	284	513	2340	2600
36	2611	Sand Canyon	2332	260	1093	2340	2600
37	2510	Mill Creek	2375	N/A	N/A	2600	2600
38	2511	Mill Creek	2375	N/A	N/A	2600	2600
Note	: (1) Booster Pump	o Data: Information fr	om SCE pump e	fficiency tests d	ated 2018 to 20	20	

NON-POTABLE WATER SYSTEM

Non-potable system 2 utilizes two (2) small package skid booster pump systems to maintain system pressure within the zone.

RECYCLED WATER SYSTEM

The recycled water system is treated water through the City's WWTP Membrane Bioreactor (MBR) System and is permitted for six (6) million gallons per day (MGD) with future plans in the WWTP Phase 2 improvement project to take the total to 9.1 MGD. This system has limits imposed on phosphate levels for the SCE Mountain View Power Plant and has to maintain a minimum of 0.5 parts per million (ppm) chlorine residual. There are three (3) booster pumps that pump from the chlorine contact basin at the



WWTP. The pumps are seventy five (75) horsepower (hp) with a flow of 1,500 gallon per minute (GPM) each at 154 feet head that operate on a variable frequency drive based on demand.

2.6 WATER TREATMENT PLANTS

Hinckley and Tate WTP are both conventional treatment plants. Tate treats water from Mill Creek, while Hinckley treats water primarily from the Santa Ana River. Both can blend treated effluent with water from potable groundwater wells when necessary to meet drinking water standards and system demands. Tate is permitted for maximum daily potable water production of twenty (20) MGD, while Hinckley is permitted for maximum daily potable water production of 14.5 MGD. MBI visited both sites on July 7, 2021 to evaluate O&M practices and identify infrastructure needs. Site visit summary information is provided below, and a detailed field report with the associated photo log is included in Appendix A.

2.6.1 HORACE P. HINCKLEY WATER TREATMENT PLANT

Hinckley is a conventional WTP utilizing continuous rapid mix flocculation, sedimentation, filtration, and disinfection. The nominal plant treatment capacity is twelve (12) MGD, which is sustainable even with one (1) filter out of service. The peak flow rate through the plant is limited to 14.5 MGD, as permitted by California State Water Resource Control Board Division of Drinking Water (SWRCB-DDW). The treatment plant capacity is expandable to a maximum ultimate capacity of thirty-six (36) MGD. Hinckley primarily treats raw water from the Santa Ana River (SAR) and is capable of receiving and treating water from the SWP. Up to 100 percent (100%) of the plant's raw water can be supplied from the SAR, when available, during the winter. During hot-weather periods in the summer, twenty to forty percent (20%-40%) of the Hinckley's raw water can be supplemented with water from the SWP.

2.6.2 HENRY TATE WATER TREATMENT PLANT

The Tate WTP is a conventional WTP utilizing continuous rapid mix flocculation, sedimentation, filtration, and disinfection. The nominal plant treatment capacity is twenty (20) MGD. The peak flow rate through the plant is limited to twenty (20) MGD, as permitted by SWRCB-DDW. Tate was initially commissioned in 1967 to treat surface water from Mill Creek, and has received several process upgrades, the latest of which installed upgrades to the chemical feed applications, clarifier, filter, backwash and sludge processes (2005). Historically, Tate received raw water exclusively from Mill Creek. However, the Mill Creek source is not typically reliable during drought periods and high turbidity events. Therefore, to increase the raw water supply reliability, the City obtained a permit amendment from the SWRCB-DDW to treat SWP and SAR source-water at Tate.

2.6.3 WASTEWATER TREATMENT PLANT

Approximately 4,480 AF of recycled water is produced annually at the City WWTP, however approximately 1,835 AF of recycled water is delivered to customers annually. This facility was constructed in 1960 to produce 9.5 MGD of secondary wastewater treatment, and was upgraded with Membrane Bioreactor (MBR) technology in early 2000 to produce six (6) MGD of high-quality recycled water. WWTP influent is screened, clarified, and settled before being divided between the MBR and the conventional treatment systems. The treated effluent typically contains less than five (5) milligrams per liter (mg/l) of biological oxygen demand (BOD), less than five (5) mg/l of total suspended solids (TSS), less than ten (10) mg/l of total nitrogen, and less than 0.2 nephelometric turbidity unit (NTU) for turbidity. Table 2-5 provides the typical tertiary treated wastewater result.




Parameter	Influent	Effluent
BOD (mg/L)	160	<5
TSS (mg/L)	130	<5
Total Nitrogen (mg/L)	24	<10
Turbidity (NTU)	NA	<0.2
Note: Data from Water Recycling/F	ower Generation R	Reuse Project

Table 2-5: City of Redlands Typical Tertiary Treated Title 22 Recycled Water

2.7 FACILITY SEISMIC ANALYSIS

Due to the potential for seismic activity in southern California, it is essential for water facilities to be designed, equipped, and prepared for potential seismic movement. Richard Brady and Associates, Inc. (Brady) completed a Condition, Seismic, and Structural Assessment of all essential water facilities to identify potential facility risks, located in Appendix F.







3 WATER USE

3.1 GENERAL DESCRIPTION

This section reviews the water use characteristics for the City's water systems. The information presented in this section was used in the hydraulic models to evaluate system reliability and the ability of each system to provide sustainable water delivery service to customers. This information was also used to project future water demands and requirements to predict future operational needs.


3.2 WATER DEMAND


POTABLE WATER SYSTEM

From 2016 to 2020, the City produced an average of 22,821 AF of potable water and delivered an average of 20,770 AF of potable water each year (2020 UWMP). Table 3-1 provides annual and summary demand data within several use categories. In the table below, if the meter service does not fit in any of the general categories, it is defined as "Other". Average annual system water loss, calculated as the percentage of water delivered to water produced, was relatively high (nearly 9%) during this period. This is likely caused by system leaks and meter inaccuracies. Approximately seventy-three percent (73%) of the total demand was from residential customers, and the average per capita water usage was approximately 222.9 gallons per capita per day (gpcd) (18.5 MGD/83,000 capita). This demand data was used for water accounting and calibration of the hydraulic model, which was used to project future potable water demands through the planning horizon. The comparative use of each category is shown graphically in Chart 3-1.

Category	2016	2017	2018	2019	2020	Average
Single Family Residential	11,340	12,275	12,866	11,624	12,949	12,211
Multi-Family Residential	2,835	2,913	2,934	2,750	2,901	2,867
Commercial/Industrial	3,180	3,142	3,159	2,705	2,640	2,965
Landscape Irrigation	1,924	2,155	2,340	2,228	2,220	2,173
Agriculture	556	387	326	283	276	366
Other	183	253	179	174	151	188
Total Demand	20,018	21,125	21,804	19,764	21,137	20,770
Total Production	20,919	23,303	23,442	21,975	24,464	22,821
Water Loss (AF)	837	2178	1638	2211	3227	2051
Water Loss (%)	4.0%	9.3%	7.0%	10.1%	13.6%	9.0%
Note: Based on Table 4-3 in 2020	Urban Water I	Management	Plan			

Table 3-1: Historical Water Production and Demand (AF/Year)





NON-POTABLE WATER SYSTEM

The City of Redlands produces and distributes approximately 1,868 AF of non-potable water annually. Table 3-2 provides non-potable water demands for the previous four (4) years. The non-potable water system primarily serves warehouses and commercial facilities in the northwest portion of the City. Table 3-3 provides non-potable water demand for several larger customers. Water demand for Ford Park and Hillside Memorial Park are provided as municipal use references.

Table 5-2. Historical Non-Polable Water Demanu (AP/Tear)						
	2017	2018	2019	2020	Average	
Commercial/Industrial	1,456.5	2,512.9	1,051.6	2,212.2	1,808.3	
Landscape Irrigation	81.2	179.4	89.7	185.1	133.9	
Agriculture	193.2	16.1	74.5	3.7	71.9	
Non-Potable Demand	1,730.9	2,708.4	1,215.8	2,400.8	2,014.0	

Table 3-2: Historical Non-Potable Water Demand (AE/Year)

Table 3-3: 2021 Non-Potable Water Users

Users	GPD			
Warehouses	396,731			
Commercial Plazas	96,850			
Crafton College	67,397			
Park Irrigation	44,324			



Users	GPD
Redlands Country Club	35,893
Agricultural	31,479
Kaiser Permanente Medical Center	15,258
Ford Park	2,167
Hillside Memorial Park	40
Note: Data Analyzed with Meter Information Provide	d by the City

RECYCLED WATER SYSTEM

Recycled water is treated effluent from the City WWTP and is primarily used for equipment cooling at the SCE Mountain View Power Plant, dust control at the City landfill, and for landscape irrigation customers. The power plant generates approximately 1,056 megawatts of power, and uses a 50:50 blend of recycled and non-potable water produced by their own non-potable well. This blending is necessary because of a "Take-or-Pay" agreement that requires the power plant to use or pay for 3,000 AF of water. Currently, the City WWTP is only capable of producing approximately 4,480 AF of recycled water. Actual power plant demand varies with energy production, and averaged approximately one (1) MGD annually between 2017 and 2019. A small amount of recycled water is also used for dust control at the landfill site adjacent to the WWTP. It is anticipated that the WWTP will be able to produce approximately 6,720 AF recycled water when plant improvements are constructed in the near future and be permitted to treat up to 10,193 AF. Annual recycled water demand from 2017 through 2020 was 2,427.5 AF, 1,976 AF, 1,905.2 AF, and 1,806 AF, with an annual average of 2,028.7 AF.

3.3 FIRE FLOW

The Fire Marshall establishes minimum fire protection water requirements, including storage, pressure, and flow, within the City. These requirements were used as minimum standards when analyzing the potable water distribution system. Table 3-4 shows the minimum fire flow requirements for water delivery pressure and duration based on a Type V building construction type. These requirements vary based on the total size of the facility and the building construction type, as defined by the California Fire Code. The storage for the highest single fire event is expected to be two (2) MG. This storage volume assumption was used to develop design criteria for the City's storage requirements.

Land Use	Criteria	Minimum Fire Flow (GPM)	Minimum Pressure (PSI)	Duration (HR)
Residential	Less than 3600 SqFt	1,000	20	2
Residential	Greater than 3600 SqFt	1,500	20	2
Commercial/ Industrial	Less than 11,300	1,500 – 2,750	20	2
Commercial/ Industrial	11,301 SqFt - 20,601 SqFt	3,000 – 3,750	20	4
Commercial/ Industrial	20,601 SqFt – 85,100 SqFt	4,000 – 7,750	20	4

Table 2 4, Eira Elovy Critoria



Land Use	Criteria	Minimum Fire Flow (GPM)	Minimum Pressure (PSI)	Duration (HR)	
Commercial/ Industrial	Greater than 85,101 SqFt	8,000	20	4	
Note: Data provided in 2021 by the City of Redlands Fire Marshal for Type V Construction					

3.4 CONSERVATION MEASURES

The 2021 Water Shortage Contingency Plan (2021 WSCP) was developed to ensure long term sustainability of water resources.

3.4.1 WATER SHORTAGE CONTINGENCY PLAN

The City encourages and incentivizes year-round water conservation practices. Voluntary and mandatory water conservation measures for various water shortage conditions, which may be caused by climate change, infrastructure failure, source contamination, or other supply issues, are identified in 2021 WSCP, and comply with minimum California Water Code requirements. The 2021 WSCP is codified by ordinance, and includes six (6) stages, each corresponding to a specific supply shortage condition. These stages are:

Stage I: Voluntary Conservation Measures

Issued when a slight decrease in the water supply is expected

Stage II: Mandatory Compliance; Water Alert

Issued when a moderate decrease in the water supply is expected

Stage III: Mandatory Compliance; Water Warning

Issued when a significant decrease in the water supply is expected

Stage IV: Mandatory Compliance; Water Emergency

Issued when a forty percent (40%) decrease in the water supply is expected

Stage V: Mandatory Compliance; Water Emergency

Issued when a fifty percent (50%) decrease in the water supply is expected

Stage VI: Mandatory Compliance; Water Emergency

Issued when water supplies are in danger of being depleted to a point where uses such as human consumption, sanitation, and fire protection would be endangered. This would be in response to a more than fifty percent (50%) decrease in supply, most likely associated with a natural disaster.

Implementation of each stage is declared by the City Council when water demands cannot be satisfied without depleting the water supply for consumption, sanitation, and fire protection. If the City Council is unable to meet, the City Manager or his/her designee can implement the plan on an emergency basis. This implementation will be reviewed and ratified or revoked by the City Council at its next scheduled



meeting. In case of a catastrophic interruption, such as an earthquake, fire, and other emergency, the City Municipal Utilities and Engineering Department (MUED) will implement an existing emergency plan, which requires designated personnel to meet at a predefined reporting time and location for task assignments. Those who cannot reach their designated area are to offer their services to other local water providers if they are also experiencing an emergency.

3.4.2 DEMAND MANAGEMENT MEASURES

The City has achieved its 2020 water use reduction targets, and will continue efforts to reduce water waste. To minimize water waste, the City has implemented water waste prevention programs, metering programs, conservative pricing, assessed and managed distribution losses, and has increased both public education and outreach. In addition to the 2021 WSCP water use restrictions for various water supply shortage conditions, the City manages several other water conservation programs.

The City's water systems are metered to ensure accurate demand measurement. Meters are maintained routinely, and a replacement schedule was developed in 2008. Meters smaller than two inches (2") are replaced every fifteen (15) to twenty (20) years, while larger meters are periodically calibrated to ensure accuracy. In 2021, the first year of a five (5) year project to replace all water meters was initiated.

The City prices water using a tiered rate structure. This tiered system includes two (2) pricing components. The first component is a fixed service charge based on the meter size, and the second is a variable commodity charge based on the amount of water delivered. The commodity charge unit rate increases at specific use thresholds.

The City also manages comprehensive public education and outreach programs, focusing on customer accountability while incentivizing water conservation practices. Examples include:

- 1. Water Efficiency Rebate Program Financial Incentives:
 - a. Weather-Based Irrigation Controllers
 - b. Drought Tolerant Lawn Conversions
 - c. Synthetic Turf Replacement
 - d. Water Efficient Clothes Washers
 - e. High-Efficiency Sprinkler Nozzles
 - f. Low Flow Toilets
- 2. Design and Construction of four (4) demonstration gardens;
- 3. Participation in regional marketing campaign;
- 4. Educational outreach events;
- 5. Offering free water-saving products including hose nozzles, toilet leak detection tablets, lawn/plant moisture meters, low water use plants, shower timers, faucet aerators, and water efficiency educational materials.

3.5 FUTURE WATER USE

POTABLE WATER SYSTEM

The 2020 UWMP projected future potable water demand, based on expected population growth, land use development, and new connections, to be 21.53 MGD in 2040 and 22.17 MGD in 2045. These demand increases are expected to be primarily from new development within the unincorporated portions of the City water service area. Table 3-5 provides potable water demand projections through 2045 for each land



use category. Potable water demand is projected to increase by three to four percent (3%-4%) annually through 2045.

Land Use	2025	2030	2035	2040	2045
Single Family Residential	12,943	13,470	13,997	14,461	14,925
Multi-Family Residential	3,036	3,160	3,284	3,393	3,501
Commercial/Industrial	3,081	3,145	3,209	3,265	3,321
Landscape Irrigation	2,292	2,385	2,478	2,560	2,643
Agriculture	206	206	206	206	206
Other	206	214	223	230	238
Total Demand	21,764	22,580	23,397	24,115	24,834
Total Demand (MGD)	19.42	20.14	20.87	21.51	22.16
Demand Increase (%), 2020 base	3.0%	3.7%	3.6%	3.1%	3.0%

NON-POTABLE WATER/RECYCLED WATER SYSTEMS

The most likely opportunity to expand the non-potable water and recycled water systems is to consolidate them into a single system capable of putting approximately four (4) MGD of excess recycled water to beneficial use. This would require the construction of additional storage reservoirs and booster pumps to convey water efficiently throughout the system. Approximately forty-five (45) water meters within pressure system 1 that include commercial areas, parks, agricultural areas, schools, and residential areas with heavy irrigation use could be connected to this expanded system. Another 200-300 water meters within pressure system 2 could also be connected to this expanded system.

Table 3-6 provides use data for various water meter billing classifications, and shows the potential for relieving pressure from the potable water system by transitioning customers to the expanded non-potable/recycled water system where possible. The residential classification includes rural agricultural areas within Crafton. Transitioning these areas to the expanded system would be difficult due to the distance from the expanded system. It is recommended that the City focuses on commercial and industrial customers clustered in pressure systems 1 and 2 to maximize the benefit of the expanded system. Selective parks and City-owned citrus groves with significant water use should also be prioritized for connection to the expanded system.

Land Use	Water Use (GPD)		
Residential	638,636		
Commercial	416,113		

Table 3-6: Potential Non-Potable Water Users



Land Use	Water Use (GPD)		
Parks	281,336		
Agricultural	172,025		
Public Institutions	145,143		
Other	55,604		
Note: Data Analyzed with Meter Inform	nation Provided by the City		

Table 3-7 provides typical water use within each system. System 1 and 2 are the most developed and are located close to the wastewater treatment facility, and transitioning customers within pressure system 2 offers the greatest opportunity to relieve pressure from the potable water system. Most of these customers are located north of Fern Avenue and south of I-10.

System	Water Use (GPD)	Number of Meters
1	79,865	114
2	762,176	211
3	346,777	77
5 through 8	520,039	91
Total	1,708,857	413
Note: Data Analyzed with	Meter Information Pro	vided by the City

Table 3-7: Potential Non-Potable Water Users

It is likely that water demand within the expanded system will nearly double from 2.2 MGD to 3.9 MGD. The demand can be supplied from the WWTP recycled water system and non-potable water groundwater wells when customers are transitioned from the potable water system, and non-potable groundwater could supplement demand during peak periods. Expanding and improving this system could reduce potable water use by as much as 2,606 AF each year, with annual cost savings of \$1M-\$2M. Future developments within these pressure zones could be served by this system as well.

3.5.1 AREA-BASED DEMAND FACTORS

Table 3-8 provides the 5-year average water demand and projected potable water demand through 2045 by land use category. Assuming the demand remains constant, the City can anticipate total annual demand of approximately 25,547 AFY (22.7 MGD).

Table 3-8: Future Water Use Projections by Land Use (AF/Year)					
Land Use	5-year avg (AFY)	Area in 2017 (Acre)	AFY/Acre	Area in 2045 (Acre)	2045 Water Demand
Single Family Residential	12,211	8,332	1.466	9,428	13,821



Land Use	5-year avg (AFY)	Area in 2017 (Acre)	AFY/Acre	Area in 2045 (Acre)	2045 Water Demand		
Multi-Family Residential	2,867	681	4.210	958	4,033		
Commercial/Industrial	2,965	2,017	1.470	2,773	4,076		
Landscape Irrigation	2,173	4,138	0.525	5,622	2,952		
Agriculture	366	2,180	0.168	2,180	366		
Other	188	2,004	0.094	2,441	229		
Total	20,770	19,352	8	23,402	25,477		
Note: Information based on 2020 Urban Water Management Plan & 2017 General Plan							

3.5.2 CONNECTION-BASED DEMAND FACTORS

The City's potable water system currently includes approximately 23,545 connections. Table 3-9 provides potable water demand by connections in each land use category, and projects total system demand in year 2045. Landscape irrigation and agriculture are the most intensive uses, with 4.077 AFY per connection and 21.53 AFY per connection, respectively. The 2045 potable water system demand is projected based on linear growth projections identified in the 2020 UWMP and 2017 General Plan, and is estimated to be 23,996 AFY (21.4 MGD).

Land Use	5-Year Average (AFY)	2020 Connections	Connection Demand (AFY)	2045 Connections	2045 Demand (AFY)
Single Family Residential	12,211	19,922	0.613	22,922	14,050
Multi-Family Residential	2,867	980	2.926	1,180	3,452
Commercial/Industrial	2,965	1,397	2.122	1,647	3,496
Landscape Irrigation	2,173	533	4.077	573	2,336
Agriculture	366	17	21.53	17	366
Other	188	696	0.270	1,096	296
Total	20,770	23,545	32	27,435	23,996
Note: Information based on 2020) Urhan Water N	lanaaement Plan &	2 2017 General P	lan	

Table 3-9: Future Water Projections by Connection

Note: Information based on 2020 Urban Water Management Plan & 2017 General Plan



4 WATER SUPPLY

4.1 GENERAL DESCRIPTION

POTABLE WATER SYSTEM

The primary sources of potable water supply to the City of Redlands are groundwater (48.8%) and treated surface water (51.1%). The City may also receive raw water (0.1%) from the SWP, when it is available, and blend it with SAR and Mill Creek surface water if additional raw water is needed to meet demands. The City operates two (2) surface treatment plants that could be expanded to meet future demands. Current annual potable water production from all sources is 22,907 AF (20.45 MGD). Potable water production during the summer months is approximately three (3) times higher than in the winter months.

Potable water demand was calculated using Supervisor Control and Data Acquisition (SCADA) system data to calibrate the water model and provide a basis for future planning. The MDD is 1.7 times the ADD, and the PHD is 2.75 times the ADD. Currently, the average demand of the City's potable water system is 18.5 MGD, with a peak hour demand of almost fifty-two (52) MGD.

NON-POTABLE WATER SYSTEM

The primary non-potable water source is groundwater extracted from the Bunker Hill Basin.

RECYCLED WATER SYSTEM

The City WWTP produces approximately six (6) MGD of treated effluent through a MBR system that supplies the recycled water system.


4.2 WATER PRODUCTION

POTABLE WATER SYSTEM

Table 4-1 provides potable water production by source from 2017 to 2020. The comparative production of each source is shown graphically in Chart 4-1.

Potable Water	2017	2018	2019	2020	Average	
Source	(AFY)	(AFY)	(AFY)	(AFY)	(AFY)	
Groundwater	11,214	12,468	9,900	12,088	11,418	
Santa Ana River	4,634	6,367	5,038	5,796	5,796	
Mill Creek	7,455	4,607	7,003	6,045	6,045	
State Water Project	-	-	35	535	285	
Total Production 23,303 23,442 21,976 24,464 23,544						
Note: Data from 2017-2020 Annual Production Report						

Table 4-1: Potable Water Production Sources (AF/Year)








Table 4-2 provides monthly potable water production data from the 2017-2020 Annual Production Reports. The comparative production of each month and year is shown graphically in Chart 4-2. During that period, production averaged approximately 20.8 MGD from all sources. Monthly production varies seasonally, with summer season production of approximately thirty (30) MGD, and winter season production of approximately eleven (11) MGD. Annual potable water demand averages approximately 18.5 MGD. Reducing potable water system losses by replacing aging and leaking pipelines, replacing and repairing aging water meters, and implementing other improvements is a City priority.

Month	2017 (MGD)	2018 (MGD)	2019 (MGD)	2020 (MGD)	Average (MGD)	
January	8.2	14.0	11.4	13.1	11.7	
February	8.6	16.1	8.6	16.8	12.5	
March	14.7	11.8	10.4	11.4	12.1	
April	21.8	20.2	20.7	13.4	19.0	
May	22.9	21.4	17.9	24.6	21.7	
June	26.8	25.9	25.1	27.2	26.3	
July	29.4	29.7	28.8	29.8	29.4	
August	27.4	29.9	29.8	31.2	29.6	
September	26.0	27.5	28.4	29.4	27.8	
October	24.5	22.1	24.5	26.2	24.3	
November	20.0	19.9	19.4	20.1	19.9	
December	18.5	12.6	9.8	18.0	14.7	
Average	20.7	20.9	19.6	21.8	20.8	
Note: Data from the 2017-2020 Annual Production Report						





NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM

Table 4-3 provides monthly non-potable water and recycled water production in 2020. Although the WWTP produces approximately 4.5 – 5.0 MGD of recycled water, only 1.6 MGD is being sent to customers, which could be tripled with system improvements. Similar to potable water production, non-potable water production varies significantly during the summer season (2.57 MGD) and winter season (1.11 MGD). The combined annual production average is approximately three (3) MGD, and varies seasonally from 1.5 MGD in January to 4.5 MGD in July.

Table 4-3: Monthly Non-Potable Water & Recycled Water Production/Distribution (MGD)

Month	2017-2020 Average Well Production (MGD)	Average Recycled Water Production/ Distributed to Customers (MGD)	TOTAL Average Production (MGD)
January	0.5	1.0	1.5
February	0.6	1.2	1.8
March	0.6	1.4	2.0
April	1.6	1.3	2.9
May	1.8	1.2	2.0
June	2.6	1.3	3.9
July	2.7	1.8	4.5
August	2.6	1.8	4.4



Month	2017-2020 Average Well Production (MGD)	Average Recycled Water Production/ Distributed to Customers (MGD)	TOTAL Average Production (MGD)
September	2.4	1.6	4.0
October	2.2	1.7	3.9
November	1.5	1.3	2.8
December	0.8	1.0	1.8
Average	1.7	1.4	3.0

Table 4-4 provides annual average production from each non-potable groundwater well from 2017-2020. The City's non-potable groundwater wells produce a combined average of 7.3 MGD. The two (2) highest producing wells, Well No. 30A and the New York Street Well serve Systems 2 and 3. These systems account for approximately thirty percent (30%) of total groundwater extractions.

Groundwater Well	Average Water Production (GPD)	Average Water Production (MGD)
Agate 1	0	0
California	85,301	0.085
Crafton	51,779	0.052
New York	282,329.9	0.282
Redlands Heights	32,792.7	0.033
Well 11	92,912.2	0.093
Well 16	65,593.3	0.066
Well 30 A	572,337.2	0.572
Well 31A	0	0
Well 32	11,025	0.011
Well 36	134,380.1	0.134
Well 41	21,961.5	0.022
Total Non-Potable	1,350,412	1.350
ote: Data from the 2017 – 2	2020 Annual Production Re	eports

Table 4-4: Non-Potable Groundwater Well Production (MGD)



This production data was compared to demand data for 2017-2020 to identify significant water losses of approximately forty percent (40%) within the non-potable water system. Table 4-5 summarizes that analysis.

	2017	2018	2019	2020	Average
Average Production (MGD)	4.2	3.6	3.2	3.2	3.6
Average Demand (MGD)	1.6	2.4	1.1	2.1	2.1
Water Loss (MGD)	2.6	1.2	2.1	1.1	1.4
Water Loss (%)	62%	33%	66%	34%	39%

Table 4-5:	Non-Potable	Water Sys	stem Losses

The design on the City's non-potable water system does not alleviate the water loss issue. The non-potable water wells operate on pressure using a ClaValve. Since the non-potable water system does not include storage tanks, the excess water releases into the storm drain system when the pressure exceeds a set point. The need for the system to be operated this way results in loss of water.

It is recommended that the City investigate other potential causes of this water loss, which may include a review of record drawings and specifications, analysis of operations, site visits, and interviews with the maintenance staff before CIP projects are implemented. The City should target system water losses of approximately four to six percent (4%-6%) annually. It is estimated that reducing water losses within the non-potable water system could increase revenues by approximately \$750,000 to \$ 1.5M annually.

The non-potable water meters are in the process of being replaced, which is expected to be completed by June 30, 2022. Resolving this issue will further reduce water loss and contribute to the targeted system water loss.

4.3 DEMAND VARIATION

4.3.1 AVERAGE DAY DEMAND

POTABLE WATER SYSTEM

Based on 2021 meter-data provided by the City, the potable water system ADD is approximately 18.5 MGD. When accounting for losses in the system, the production needed to supply this demand is approximately 20.4 MGD.

NON-POTABLE WATER SYSTEM

The ADD from non-potable groundwater wells is approximately 2.1 MGD. Approximately ninety percent (90%) of this demand is for outdoor landscape irrigation. The remainder is used for agricultural irrigation and commercial/industrial uses.

RECYCLED WATER SYSTEM

The ADD for the recycled water system, which is exclusively used by the SCE Mountain View Power Plant, for landfill dust control adjacent to the WWTP, and irrigation customers is 1.64 MGD, and can increase periodically to 2.2 MGD. Unused recycled water is blended with non-potable water produced by the California Street Well, to supplement the non-potable water distribution system.



4.3.2 MAXIMUM DAY DEMAND

POTABLE WATER SYSTEM

The potable water system MDD was determined using 2019 SCADA information provided by the City, and was found to be 1.7 times the ADD, with a peak of approximately 2.75 times the ADD. Chart 4-3 shows the diurnal curve for the MDD case. The maximum day typically occurs in mid-August, with peak hour demands occurring at approximately 5:30 a.m. and 11:00 p.m.




Chart 4-3: MDD Diurnal Curve for Potable Water, August 2019

NON-POTABLE WATER SYSTEM

Based on 2021 meter-data provided by the City, the non-potable water system ADD is approximately 2.1 MGD. When accounting for losses in the system, the production needed to supply this demand is approximately 3.2 MGD. The maximum day typically occurs between June and October, with peak hour demands occurring at approximately 4:30 a.m. to 7:30 a.m. when irrigation is typically applied.

RECYCLED WATER SYSTEM

Based on 2021 meter-data provided by the City, the recycled water system ADD is approximately 1.67 MGD. The maximum day of 2.2 MGD, typically occurs between June and October, with peak hour demands occurring at approximately 4:30 a.m. to 7:30 a.m. when irrigation is typically applied.

4.3.3 PEAK HOUR DEMAND

POTABLE WATER SYSTEM

Understanding the PHD is critical for sizing water mains and other facilities. During PHD, the system experiences high velocities and low service pressures in areas with undersized mains or areas that lack looped distribution pipelines. The PHD was determined using the peak water use during the peak hour of the MDD, and was found to be approximately 2.75 times the ADD, or approximately 50.9 MGD. Hinckley and Tate have a combined maximum treatment capacity of 34.5 MGD. In addition, the City's fourteen (14) active groundwater wells can produce approximately 18,350 GPM (26.4 MGD) of potable water. Therefore, the maximum potable water production capacity from all sources is approximately 58.4 MGD, which exceeds the PHD. However, existing potable water production facilities are not capable of meeting



the projected 2045 PHD of sixty-one (61) MGD. It is likely that this will not become an issue until the early 2030s, and the City is currently rehabilitating several potable groundwater wells, including six (6) that are inactive due to water quality issues. Bringing these wells back into service will increase potable water production capacity to 67.2 MGD, which will provide sufficient water to meet the projected 2045 PHD and provide additional capacity as reserve production. The inactive wells include Agate 2, Lugonia 4, Well No. 10, Well No. 13, and the Crafton Well. Table 4-6 provides the maximum potable water production capacity for each facility.

Well	Capacity (GPM)	Capacity (MGD)
Airport 1	1500	2.2
Airport 2	1000	1.4
Church Street	2000	2.9
Lugonia 3	250	0.4
Lugonia 6	250	0.4
Madeira	900	1.3
Maguet 2	325	0.5
Mentone Acres 2	1600	2.3
Muni	1700	2,4
North Orange Street 1	2900	4.2
North Orange Street 2	2900	4.2
Orange Street	1500	2.2
Rees	1200	1.7
38	1500	2.2
39	1250	1.8
10	1400	2.0
13	3300	4.8
Hinckley WTP	10,070	14.5
Tate WTP	13,888	20
Total	49,158	70.8

Table 4-6: Active Potable Water Production Facility Capacity

NON-POTABLE WATER SYSTEM

Understanding the PHD is critical for sizing water mains and other facilities. During PHD, the system experiences high velocities and low service pressures in areas with undersized mains or areas that lack looped distribution pipelines. The PHD was determined using the peak water use during the peak hour of the MDD, and was found to be approximately 5.3 times the ADD, or approximately 11.2 MGD.

RECYCLED WATER SYSTEM

Understanding the PHD is critical for sizing water mains and other facilities. During PHD, the system experiences high velocities and low service pressures in areas with undersized mains or areas that lack



looped distribution pipelines. The PHD was determined using the peak water use during the peak hour of the MDD, and was found to be approximately 6.1 times the ADD, or approximately 10.2 MGD.

4.4 EMERGENCY CONNECTIONS

The City maintains emergency water connections with the City of Loma Linda and Western Heights Water Company. In addition, the City is a member of the Emergency Response Network of the Inland Empire (ERNIE) and California's Water/Wastewater Agency Response Network (CalWARN). The intent of these programs and connections is to ensure that the City is able to provide water service to its customers during emergencies.

4.5 PRODUCTION-DEMAND PROJECTION

4.5.1 PROJECTION

POTABLE WATER SYSTEM

Table 4-7 provides projected potable water system demands (ADD, MDD, and PHD) through year 2042. The current peaking factors identified in Section 4.3.3 are assumed to remain constant through the planning horizon. The ADD is expected to increase by 3.2 MG to 21.7 MGD, MDD will increase by approximately 5.5 MGD to thirty-seven (37) MGD, and the PHD will increase by 9.3 MGD to 60.2 MGD. The projected daily production is determined by the daily demand and anticipated system water loss, which was 12.8% in 2020. This is relatively high for a typical water distribution system. Reducing water loss within the distribution system will reduce the difference between water produced and water distributed, resulting in significant cost savings, estimated to be approximately \$2M-\$3M each year. This savings over the planning horizon will significantly offset CIP expenditures.

Table 4-7: Potable water Demand Projections (MGD)						
	2022	2027	2032	2037	2042	
Projected ADD	18.5	19.2	20	20.8	21.7	
Projected MDD	31.5	33.5	34.8	35.9	37.0	
Projected PHD	50.9	54.2	56.3	58.1	60.2	
Expected Inefficiencies	12.8%	8%	6%	4%	4%	
Projected Average Daily Production						
Demand	20.7	20.7	21.2	21.6	22.5	
Note: Projected ADD was interpolated using Table 3.3: Projected Demand for Potable Water. 2022 potable water						

Table 4-7: Potable Water Demand Projections (MGD)

Note: Projected ADD was interpolated using Table 3.3: Projected Demand for Potable Water. 2022 potable water demand was assumed to be equal to the 2020 potable water demand.

NON-POTABLE WATER SYSTEM

As demand increases, the City will need to expand, and perhaps consolidate, the non-potable water and recycled water systems. Transitioning potable water connections to this expanded system will reduce potable water system demands by approximately 1.7 MGD. Table 4-8 shows how the decreasing water loss within the system over time reduces production necessary to meet increasing demands. This table assumes expansion and consolidation of the non-potable water and recycled water systems.



	2022	2027	2032	2042
Average Projected Demand (MGD)	2.2	2.5	2.8	3.1
Assumed Water Loss (%)	40%	28%	16%	5%
Projected Average Production (MGD)	3.7	3.5	3.3	3.3

Table 4-8: Projected Production Demands Assuming Optional Expansion



5 DESIGN CRITERIA

5.1 GENERAL DESCRIPTION

This section presents industry-standard guidelines for water infrastructure used to determine replacement or repair needs for the City's water distribution systems. The design criteria also outlines recommendations for the design and construction of infrastructure to ensure reliability, safety, and functionality. In addition, the criteria establish conditions that include but are not limited to water supply, treatment facilities, storage capacity, pressure, pipe velocity, and other hydraulic parameters. These criteria served as a benchmark to evaluate the City's existing infrastructure and identify potential projects for the City's future CIP projects. Data from previous sections including demand factors, water supply, existing infrastructure, and industry standards were evaluated against the design criteria to identify recommended infrastructure upgrades in the CIP. System pressures, pipeline flow velocity, and age were primary criteria of concern.

5.2 DESIGN CRITERIA

5.2.1 DEMAND

POTABLE WATER SYSTEM

Three important demand factors were used when evaluating the City's water system: ADD, MDD, and PHD. The City's potable water ADD is approximately 18.5 MGD, or approximately 222.9 gpcd, which is typical for this region. Due to very effective conservation measures, the current consumption per capita has been reduced from approximately 285 to 222.9 gpcd in the past ten (10) years. The MDD is estimated to be 1.7 times the ADD, or 31.5 MGD. The PHD is estimated to be 2.75 times ADD, or 50.9 MGD. The 1.7 MDD and 2.75 PHD peaking factors are calculated from the City's 2017-2021 SCADA information.

5.2.2 SUPPLY

POTABLE WATER SYSTEM

The City relies on groundwater wells and surface WTP for potable water production. The City supplies approximately half of its demand through groundwater wells. The other half is supplied through its surface WTP. Collectively, these facilities can meet the PHD. However, demand is expected to increase over the next few decades due to growth and further development. As the service areas and demands grow, the City may need an additional five to six (5 - 6) MGD of supply capacity to meet sixty-one (61) MGD of peak hour demand in 2045.

NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM

The City relies on groundwater wells and it's WWTP to supply non-potable and recycled water. However, the City does not utilize the entirety of its WWTP effluent. Therefore, any expansion of the recycled/non-potable water system should use this excess water. The groundwater wells are also used to supply non-potable water to small, detached systems throughout the City. These areas are primarily large parks and open spaces within the City.

5.2.3 STORAGE VOLUME

POTABLE WATER SYSTEM

Fire flow during peak demands was modeled, and water storage was found to be adequate for existing and future hydraulic conditions. Based on the EPA's Effect of Water Age on Distribution System Water Quality Report, Office of Water (4601M), the water distribution system requires enough operational



storage (OS) for variation in demand, equalizing storage (ES), stand by and/or fire suppression storage (SB and FSS) and dead storage. The emergency outage storage is evaluated based on the MDD and fire flow requirements. The currently available storage of 54.3 MG is higher than the 2022 storage requirement of 38.9 MG and 2042 storage requirement of forty-five (45) MG. Since current storage is larger than the current and future emergency demand, fire protection and diurnal fluctuations can be met during the emergencies.

For operational variation during emergencies, it is recommended that the City have enough storage to store the MDD (31.5 MG) to allow fluctuating demands throughout the day. Each zone will also need to maintain fire flow capacity to fight fires. California's Fire Code Fire Flow Requirements table was used to estimate the fire flow requirements. The City's maximum fire demand is 8,000 GPM for 4 hours for one zone. This is equivalent to 1.92 MG of storage capacity. Due to the commercial/industrial areas in Zones 1350 and 1570, the required fire flow storage demand is 1.92 MG. Zones 1750, 1900, and 2100 have several large commercial sites that would require approximately 4,000 GPM for 4 hours (0.96 MG). The remaining zones are primarily residential areas with some commercial zoning. These zones require 3,000 GPM for 3 hours (0.54 MG). Emergency Storage will vary by region as it depends on the possible disaster to each water agency. Table 5-1 shows the operation and fire flow and/or emergency storage required for each zone. The overall required storage is sufficient for the City's current production.

	Storage Volume (MG)	2022 Operational Storage (MG)	Fire Flow Required (MG)
Zone 1350	4.9	2.46	1.92
Zone 1570	23.6	12.14	1.92
Zone 1750	5.5	7.24	0.96
Zone 1900	7.4	5.40	0.96
Zone 2100	5.0	3.14	0.96
Zone 2340	6.5	1.02	0.54
Zone 2600	1.4	0.10	0.54
Total	54.3	31.50	7.38

Table 5-1: Storage Volume by Zone

Also, it is essential to note that during emergencies, water could be brought from the WTP, wells, emergency connections with other systems, allowable supply that can be taken from nearby lakes and canals during the fire, and fire trucks from the Fire Department supply. Therefore, it may be difficult to estimate all emergency supply sources accurately. However, with the two (2) emergency interconnections, two (2) WTP, and natural water storage reservoirs, the 54.3 MG of total reservoir capacity is sufficient storage capacity for the planning horizon.

NON-POTABLE WATER SYSTEM

The current storage system includes two (2) small poly tanks and three (3) cement lined open air reservoir throughout the distribution system.



RECYCLED WATER SYSTEM

The City does not have any storage capacity for recycled water, but is currently engineering two (2) 1.5 MG reservoirs to be constructed at the WWTP in the future. This will allow the WWTP to store water until needed, instead of the demand-based system operation that is currently in place. The capacity of the reservoirs will be needed to maintain the operational variations that will exist as demand increases. The recycled water system only services two (2) fire hydrants located at the SCE Mountain View Power Plant and at California Street Well. Since the recycled water system does not service any other fire hydrants for firefighting or require emergency storage in case of a natural disaster, the City will only need storage capacity for its operational flow. The storage capacity is recommended to be equal to the ADD of the recycled water system, which is approximately 2.1 MG for the existing system and three (3) MG for future storage. This excludes the recycled water storage needed for the Mountain View Power Plant.

5.2.4 PUMP STATIONS

POTABLE WATER SYSTEM

Pump Stations are an essential component of the City's potable water distribution system and are required to lift water and maintain the hydraulic grade. The City must maintain emergency power equipment, capacity, and redundancy for the pump stations within the system. The list of booster stations can be found in Table 2-4. The City must maintain a flow capacity equivalent or greater than the MDD, with a three (3)-day fire flow recharge for its system. It is also recommended that the system's redundancy be able to supply the PHD when a pump station has its largest pump offline. In case of a power outage, it is recommended that there is standby power for all pumping stations.

NON-POTABLE WATER SYSTEM

Non-potable system 2 utilizes two (2) small package skid booster pump systems to maintain system pressure within the zone.

RECYCLED WATER SYSTEM

Booster pumps pump recycled water from the wastewater treatment plant's chlorine contact basin into the recycled water system. There are no booster pumps in the City's recycled water systems. The WWTP is constructed in the lowest area of the City in Zone 1. If the City expands and consolidates the non-potable water and recycled water systems, booster pumps will be necessary to transfer water to higher pressure zones. Each pump stations should provide the MDD for the zone it serves. Backup pumps must replace the single largest pump within a pump station facility. Backup power is suggested for each pump station.

5.2.5 WATER TREATMENT

Potable water must meet maximum contaminate level (MCL) standards mandated by the United States (U.S.) Environmental Protection Agency (EPA) and California's Department of Water Resources. The surface water the City utilizes needs to be treated for potential contaminants at the City's treatment plants. Groundwater wells meeting the same MCL standards can also supply potable water. Otherwise, the groundwater must be treated through onsite treatment facilities, or by blending the water with water from other sources to meet the MCL standard. Specific requirements for WTP are dependent on the purpose of the facility. The City owns and operates two surface WTP, Hinckley and Tate. The field report attached in Appendix A provides a detailed description of these facilities.



5.2.6 SYSTEM PRESSURE

POTABLE WATER SYSTEM

Based on American Water Works Association (AWWA) standards, the pressure for the water system is recommended to be between forty (40) and 150 pounds per square inch (psi). The variation within a pressure zone should be no more than twenty (20) psi, as a significant variation in pressure could lead to fatigue within the system due to repeated cycles in hydraulic stress. For example, the residual pressure for a fire hydrant is required to be at twenty (20) psi for effective firefighting. Pressure-reducing valves are required between pressure zones to maintain reliable pressure between each zone.

NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM

Pressure within the non-potable water system should remain between forty (40) psi and 150 psi with a target range between forty five (45) psi to eighty (80) psi. The variation within each pressure zone should not vary by more than twenty (20) psi.

5.2.7 PIPE VELOCITY

Based on AWWA standards, the pipe velocity for the water system should not exceed ten (10) feet per second (fps) under all conditions with a desirable velocity of five (5) fps during normal operations. Pipelines should be sized to provide head losses that do not exceed 3.5 feet per 1,000 feet of pipeline under PHD or five (5) feet per 1,000 of pipeline under MDD conditions. This criteria applies to all three (3) water systems.

5.2.8 PIPELINE REDUNDANCY

Pipeline redundancy involves both avoiding dead-end pipelines and avoiding disruption in the entire system if a pipeline segment needs to be shut down. Avoiding dead ends also helps prevent water stagnation, deterioration, corrosion, and may improve water quality. In some cases, dead ends may be the best or only option to service some areas due to the cost of constructing and maintaining redundant pipelines. Therefore, it is recommended that dead-ends be looped whenever possible, or flushed annually. New water mains must be installed ten feet (10') horizontally and one foot (1') vertically from treated and untreated sewage, and recycled water, as outlined in the State of California Code of Regulations: Title 22, Division 4, Chapter 16 Article 4 Section § 64572, Water Main Separation. The City can request an exemption to this standard if a condition meets specific requirements outlined in the same sections. Distribution system pipelines should be a minimum diameter of eight inches (8") and sized appropriately. Fire hydrant laterals should be six inches (6") in diameter. This criteria applies to all three (3) water systems.

5.2.9 SUMMARY OF DESIGN CRITERIA

POTABLE WATER SYSTEM

A summary of the potable water system design criteria is provided in Table 5-2, including typical industry standards and current City standards.

Demand	Typical Industry Standards	City Standard		
Maximum Day Demand ^{1,2}	Typical 1.5-2 times ADD	1.7 times ADD		
Peak Hour Demand ^{1,2}	Typical 2-4 times ADD	2.75 times ADD		
Storage				

Table 5-2: Design Criteria Summary – Potable Water System



Demand	Typical Industry Standards	City Standard	
Reservoir Capacity ¹	Combined Operational, Fire, and Emergency Storage	Combined Operational, Fire, an Emergency Storage	
Operational Capacity ²	Maintain operation during peak demands through the day 50% of MDD	50% of MDD	
Fire Storage ¹	Largest Single Fire Flow event	Largest Single Fire Flow event	
Emergency Storage ¹	Dependent on Region, Typically 0.5 to 2 times the MDD	50% of MDD, with emergency connection the City maintains	
Pump Station			
Pump Station Capacity ¹	Pump Station must supply MDD Booster Pumps must supply MDD and Fire Flow		
Pump Station Configuration ¹	Stand-by pump equal in size to the largest duty pump		
Pump Station Backup Power ¹	Previsions for emergency Power at all Stations		
Pipelines	Industry Standards		
Minimum Diameter Pipe	N/A	8" Diameter for Mainline 6" for hydrant laterals.	
Maximum Pipe Velocities ¹	10 fps under all Conditions	10 fps under all Conditions	
Maximum Pipe Head Loss ¹	3.5 ft per 1000 ft at PHD 5 ft per 1000 ft at MDD		
System Pressure			
Minimum Static Pressure ¹	40 psi at PHD	40 psi at PHD	
Maximum Static Pressure ¹	150 psi at PHD	150 psi at PHD	
Minimum Fire Hydrant Residual Pressure ¹	20 psi	20 psi	
Maximum Dynamic 20 psi Pressure Variation ¹		20 psi	

Note: ¹ Industry Standards are based on the AWWA manuals for water distribution systems that include but are not limited to M22 Sizing Water Service Lines and Meters, M31 Distribution System Requirements for Fire Protection and M42 Steel Water Storage Tanks

² Analysis of Eastern Municipal Water District: Water System Planning & Design, and Western Municipal Water District: Design Criteria for Water Distribution Systems were used for comparison to City Standards, due to limited information provided in AWWA manuals

NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM

A summary of the non-potable water system and recycled water system design criteria is provided in Table 5-3, including recommended City standards for these water systems.

Table 5-3: Design Criteria Summary - Non-potable & Recycled Water System



Storage	Recommended City Standards
Operational Storage	Equal to ADD
Fire Flow Storage	N/A
Emergency Storage	N/A
Pump Station	Recommended City Standards
Pump Station Capacity	Pump Station must supply MDD
Pump Station Configuration	Stand-by pump equal in size to the largest duty pump
Pump Station Backup Power	Previsions for emergency Power at all Stations
Pipelines	Recommended City Standards
Maximum Velocity	10 fps peak
Preferred Maximum Velocity	5 fps under ADD and MDD
Maximum Distribution Pipe Velocity	5 fps under all Conditions
System Pressure	Recommended City Standards
Minimum Static Pressure	40 psi at PHD
Maximum Static Pressure	150 psi at ADD
Maximum Dynamic Pressure Variation	20 psi

Fire Protection and M42 Steel Water Storage Tanks

5.3 PLANNING CRITERIA

5.3.1 METHODOLOGY

The design criteria outlined in this section will be used in determining what facilities need to be repaired, replaced, or constructed. The CIP also considers the age of the City's facilities and includes those facilities that exceed the average service life. Age is not necessarily an indication of current performance issues, but is an indicator that the asset's future performance is expected to deteriorate.

5.3.2 AVERAGE SERVICE LIFE

The age of each pipeline and facility was considered when evaluating service life replacement schedules. The typical service life for various water facilities and pipeline materials are provided in 5-4 and Table 5-5. This information was used to develop CIP recommendations for each water system. If a structure exceeds its average service life, it is expected to deteriorate and increase the chance of failure. The State



of California Water Board recommends replacing mainline pipelines every forty (40) years. However, pipeline service life can vary depending on the pipeline material.

Equipment	State of California Water Board ¹	NMT Asset Management
Source of Supply		
Wells	25 – 35	
Intake Structures	35 – 45	
Transmission Mains	35 – 40	65 - 95
Pumping Plants		
Pumping Equipment	10 - 15	15 - 25
Structures	30 – 60	50 - 100
Treatment Plants		
Chlorination Equipment	10 - 15	
Equipment	10 - 15	15 - 25
Structures	30 - 60	60 - 70
Transmission/Distribution		
Structures	30 - 60	50
Reservoirs and Tanks	30 - 60	50 - 80
Main & Distribution Pipes	35 – 40	65 - 95
Services	30 – 50	
Valves	35 – 40	
Backflow Prevention Valves	35 - 40	
Blow-off Valves	35 – 40	
Meters	10-15	
Hydrants	40 - 60	
General		
Structures	30 - 40	50
Electrical Systems	7 – 10	15 - 25
Equipment	10 - 15	15 - 25
Transportation Equipment	10	
Computers	5	5 - 10
Store Equipment	10	
Lab/Monitoring Equipment	5 – 7	
Tools and Shop Equipment	10 – 15	
Landscaping/Grading	40 - 60	
Power Operated Equipment	10 – 15	
Communication Equipment	10	

. . .

The life expectancy of mechanical equipment and pumps is assumed to be 20 years, and the Electrical equipment 15 years for CIP purposes



Standard Abbreviation	Material	Service Life (Years)	
ACP	Asbestos Concrete Pipe	70	
CIP	Cast Iron Pipe	120	
CMLC	Cement Mortar Lined and Coated	100	
CMLDIP	Cement Mortar Lined Ductile Iron Pipe	100	
CMLSTL	Cement Mortar Lined Steel Pipe	100	
CON	Concrete	100	
DIP	Ductile Iron Pipe		
DW	Dipped and Wrapped	40	
PVC	Polyvinyl Chloride	70	
RCP	Reinforced Concrete Pipe		
STL	STL Steel 100		
Note: Based on MASC Life Expectancy of Water Distribution Lines			

Table 5-5: Water Pipeline Average Service Life

5.3.3 PERFORMANCE INDICATORS

The primary performance indicators used for pipelines are the flow velocities and pressures predicted by the hydraulic model. The updated hydraulic model was used to identify pipe segments and conveyance facilities that require upgrades to meet the performance metrics presented in Section 5.2.9. Additional repair and replacement considerations include the age of water facilities and whether the City has indicated a performance issue with a specific facility.



6 EXISTING SYSTEM ANALYSIS

6.1 GENERAL DESCRIPTION

This Section discusses the hydraulic model development and calibration for the existing water systems to meet the current and future needs of the City's service area. The hydraulic model runs inside of a computer Geographic Information System (GIS) that manages and maps the individual components of the City's water infrastructure. The physical components of the hydraulic model include water pipelines, valves, storage tanks, pumping facilities, source water supplies, and water demands.

The model was calibrated with operational data used to set boundary conditions. Extended period simulations were performed using demand and supply data, along with demand patterns developed in previous sections. Settings were adjusted to calibrate the model to a reasonable representation of the system performance, and the model was considered calibrated when its output matched the collected instrumentation data.

Once calibrated, several scenarios were analyzed to evaluate operating pressure and pipeline flow velocity. Each scenario was chosen to represent the different operational conditions of the system. These scenarios included:

- Existing System operating under Average Day Demands
- Existing System operating under Maximum Day Demands with and without Fire Flow
- Existing System operating under Peak Hour Demands

Because the size of the non-potable water system and recycled water system is small, with only a well pump into the distribution pipe, the existing system will not be modeled. However, since the City is planning to construct recycled water reservoirs at the WWTP, the current system was modeled with these future reservoirs.

The results of these scenario analyses are presented in subsection 6.4. The results are summarized in color-coded maps to identify out-of-range pressure nodes and/or pipeline segments quickly. In addition, the results of these analyses are used to identify improvements to the system that will become recommended capital improvement projects.

6.2 METHODOLOGY

A detailed hydraulic model is a valuable tool used to analyze the complex operation of a water system. The general steps of a model formulation are:

- 1. Inputting the system's physical data in GIS format
- 2. Obtaining meter data to set boundary conditions in the model
- 3. Translating the physical data into a network of nodes and links
- 4. Inputting accurate water demands
- 5. Calibrating the model to simulate actual field conditions and system performance
- 6. Performing model runs based on current and future system conditions to predict performance.

The physical data required for a hydraulic model includes the geographic network of pipes, nodes, tanks, pump stations, valves, and supply sources representing the City's potable water system. The connectivity



of the pipes and nodes in GIS allows the system components in the model to be hydraulically linked. Pipe information includes the pipe diameter, length, pipe material, and associated roughness coefficient. The roughness coefficient function, known as the Hazen-Williams "C" factor (when the Hazen-Williams head loss formula is used), estimates friction losses in the system. The "C" factor is assigned based on the diameter, material, and when known, pipe age. However, "C" factors are subjective, and also based on industry best practices and operations input. Node information contains the node elevation and water demand or supply at that point in the system.

Initial hydraulic boundary conditions must be entered into the model database. Of particular importance is the initial water level for tanks and the initial open/closed setting for control valves. City water supply sources, such as pumped sources from groundwater wells and treatment plants, can be modeled as either varied or constant supplies into the water system. Understanding and adequately simulating these boundary conditions is critical to the successful calibration of the model.

Determining accurate water demands is crucial to developing an accurate hydraulic model. Metered demands, water supplies, pumped flows, and changes in tank volumes are reviewed over a given period to determine actual daily demand patterns. Annual consumption by metered account provides a spatial distribution of demand and average system usage.

Node elevations were updated using current topographic maps. Where available, as-built information was used to update the model to match existing conditions. Storage tanks were annotated with ground elevation, diameter, and height. Operational settings in the model were verified during workshops with the City staff and through a detailed review of SCADA operational data. These settings were updated in the hydraulic model. The locations of normally closed valves were also confirmed and identified in the model.

The current operational status and functionality for the City's potable water system pressure reducing stations (PRS) were obtained from City staff and updated in the hydraulic model. Settings provided by City staff represent typical conditions and may vary depending on the season, system demands, and storage conditions. For example, operations staff may change the settings to allow more water into a particular system to fill a tank or less water to turn over the tank.

6.3 HYDRAULIC MODEL CALIBRATION

The final step in developing a reliable hydraulic model is calibration. For the 2021 Master Plan, SCADA information was evaluated to provide the City with a reliable and accurate overview of its potable water system. This was necessary to analyze the water distribution system correctly. A properly calibrated model provides the confidence needed to make significant capital planning decisions and delivers a planning tool to guide operational decisions.

Macro-level calibration procedures use continuous monitoring to obtain data points to simulate system operations over an extended period. Actual field data can be obtained using SCADA records or by placing monitoring equipment in the system. For the City's potable model calibration, a week of data from August 2019 was obtained from SCADA for tank levels, pump station flows and/or status, and pressures, where available. The data was used to establish boundary conditions for the calibration period.

The hydraulic model was calibrated for an extended period simulation (EPS). EPS calibration was performed to ensure the model accurately reflects how the overall system operates over time concerning



transmission mains, pumps, tanks, and reservoir operations under normal operating conditions. A preliminary review of the model data was conducted before EPS calibration. It was believed to provide a reasonably accurate representation of actual system characteristics in water main geometry, spatial demand allocation, and pipe roughness. Precise duplication of the data recorded at all locations within the water distribution system during extended period calibration is not realistic due to many factors influencing the results. Model calibration aims to minimize the error between the SCADA and the model simulations and create a "best fit" at all locations. Some error between the SCADA and model simulations is expected; however, limits to the amount of allowable error must be made to ensure the calibrated model accurately represents the existing potable water distribution system. Based upon the size and number of facilities in the developed model, the desired accuracies of the extended period calibration for the hydraulic model are:

- 1. Minimum of twenty-four (24) hours is performed.
- 2 Tank levels must be within five feet (5') between field data and model simulations at least eighty percent (80%) of the time.
- 3. Tank levels must be within eight feet (8') between field data and model simulations the entire time.

A composite time-of-day demand curve was determined for each pressure zone within the potable water system for extended period calibration based on available SCADA data and plant production rates. The time-of-day diurnal demand curve is a series of 24-hour demand factors that define how water usage varies over a day. Each demand factor is defined as the ratio of the hourly demand to the daily average. The composite time-of-day calibration demand curve corresponding to each potable water pressure zone is provided in Chart 6-1.




Chart 6-1: Composite Time-of-Day Demand Curve



The diurnal curves developed for model calibration closely resemble the traditional "double hump" pattern of water use throughout the day, with morning and evening peak demands. The morning peak hour demand, which occurs from 3:00 - 6:00 a.m., was 2.2 - 4.8 times the average use for the day, which represents the peak water use for the day for most of the system, with the exception for Pressure Zone 1900, where peak water use occurs during the evening.

Extended period simulations were performed on the potable water system using the demand curves developed above. In general, the tanks and SCADA points exhibited similar trending patterns in the model compared to the field data collected. Tank and pump station trending graphs resulting from the extended period calibration are included in Appendix B.

Examples of the calibration results are shown in Chart 6-2 and Chart 6-3, illustrating some of the variations between the field data and model simulations. The calibration results for these two tanks are examples of the level of accuracy between actual tank water levels observed and the model predictions throughout the system. In summary, the extended period simulation satisfies the calibration goals discussed with City staff.




Chart 6-2: Calibration Results for 1350 PZ Tank Levels – 1




Chart 6-3: Calibration Results for 1350 PZ Tank Levels – 2

During the extended period model calibration, adjusting valve and pump settings slightly to simulate accurate tank levels was necessary. Table 6-1 includes the calibration results after localized adjustments to improve the model's accuracy. Typically, this information would include pumped flows and discharge pressures. Actual pump flows were estimated based on pump status for all sites except the Country Club Booster pump station, which was not available. The modeled flows are within ten percent (10%) of the total anticipated flow presented in SCADA. Discharge pressures were only provided for this site as well. While they are consistently less than SCADA (approximately 7 - 10%), this could be due to an elevation discrepancy, pump losses, location of the gage, and other factors.

Parameter	Allowable Deviation	Minimum Acceptance Required	Acceptance Level Achieved
Tank Level Differential between field and	2 feet	80%	70%
model			
Tank Level Differential between field and	5 feet	100%	97%
model			

Та	able	6-1:	Model	Calibration Accuracy
	1010	U -1.	model	ounstation Accuracy



6.4 EXISTING SUPPLY ANALYSIS – POTABLE WATER SYSTEM

6.4.1 SCENARIO 1: EXISTING SYSTEM, ADD, EPS, MAX PRESSURE OVER 24 HOURS

This scenario models the average daily demand for the system, primarily looking at the pressure within the system. As described in the design criteria, the preferred pressures will be between forty (40) psi and 150 psi. Figure 6-1 shows the results of the analysis. Most high-pressure areas that exceed the 150 psi pressure limit are in the western portions of each pressure Zone 1570, 1700, 1900, 2100, and 2340 near the zone boundaries, which can be expected. In addition, higher pressure was also identified downstream of booster stations P-2381 and P-2382, which pump water from Ward Way Reservoirs to higher pressure zones.

6.4.2 SCENARIO 2: EXISTING SYSTEM, MDD, EPS, MAX PRESSURE OVER 24 HOURS

This scenario models the maximum daily demand for the system, primarily looking at the pressure within the system. The model as calibrated used the peak day on the maximum month for the year and is therefore considered to be the MDD. The pressure range, less than forty (40) psi and greater than 150 psi, was used to locate areas are of concern. Figure 6-2 shows the results of this analysis, with similar results as Scenario 1—a few areas with high pressure in the western portion of Zone 1900.

6.4.3 SCENARIO 3: EXISTING SYSTEM, MDD, EPS, MAX VELOCITY OVER 24 HOURS

The MDD Scenario was used to analyze the pipe velocities within the system. The maximum velocity design criteria was used to identify pipeline projects for the CIP to alleviate high system velocities. Figure 6-3 shows that very few areas exceed the maximum recommended velocity. The areas with high velocities are near pumping stations, which is expected.

6.4.4 SCENARIO 4: EXISTING SYSTEM, MDD, FIRE FLOW, RESIDUAL PRESSURE DURING FIRE EVENT (Steady State)


This scenario analyzed the residual pressure at fire hydrants during a fire flow event. To provide adequate fire flow pressure, the residual pressure should not fall below twenty (20) psi. The minimum required fire flow was generated utilizing information supplied by the City. Figure 6-4 shows the residual pressures from the fire flow scenario.


6.4.5 SCENARIO 5: EXISTING SYSTEM, PHD, STEADY-STATE SCENARIO, MIN PRESSURE


This scenario analyzed the system pressures under peak hour demand. The maximum day demand and peaking factors were used for the simulation. The pressure range used to determine adequate pressure was between forty (40) psi and 150 psi. Figure 6-5 shows the results of this analysis. The results are similar to results from Scenarios 1 and 2. The high-pressure area is located in the western portion of Zone 1900 and the west portion of the City's service area.


6.4.6 SCENARIO 6: EXISTING SYSTEM, PHD, STEADY-STATE SCENARIO, MAX VELOCITY


This scenario analyzed the velocity conditions under peak hour demand. Although a few isolated areas exceed the maximum recommended velocity, there are no significant areas with excess velocity. Generally, locations with high velocity are near pumping stations which is expected. The results are shown in Figure 6-6.
















6.5 EXISTING SUPPLY ANALYSIS – NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM

6.5.1 ZONE 1 SUPPLY

Zone 1 currently contains a single well and the WWTP that primarily produces water for the SCE Mountain View Power Plant. However, some of this water is blended with the California Street Well to service Zone 1. Typically, the recycled water from the WWTP supplies Zone 1. However, when the power plant needs more water or the WWTP decreases its water production, the California Street Well increases its water production to supply this zone. It should be noted that the system does not have any storage capacity and requires the pumps to turn on and off depending on the current demand of the system. The City is currently engineering two (2) recycled water reservoirs for construction at the WWTP in the future to resolve this issue.

6.5.2 SYSTEM 2 SUPPLY

System 2 is currently supplied by five (5) wells: Well No. 30A, Well No. 31, Well No. 32, Well No. 41, and the New York Street Well, although Well No. 30A and the New York Street Well are the primary supply wells. Well No. 30A is typically the primary yearly source. The New York Street Well supplements production during spring and summer months and decreases production during autumn. It should be noted that the system does not have any storage capacity and requires the pumps to turn on and off depending on the current demand of the system. In addition to on and off control of pumps the pressure is regulated with the use of Cla-Valves. There will be instances where water will be discharged to the storm drain while maintaining the system pressure for end users.

6.5.3 SYSTEM 3 SUPPLY

There are no existing non-potable sources in this system. However, BVMWC does supply some parts of the northern part of this system, which include the University of Redlands and Redlands Sports Park. This is provided through the open-air BVMWC Reservoir at Agate.

6.5.4 DETACHED SYSTEMS

The detached systems typically include a well, a single pipeline, and the end-user. The purpose of these wells is to provide groundwater to a specific single end-user, such as a park or golf course.

6.5.5 SCENARIO 1, EXISTING SYSTEM, ADD, EPS, MAX PRESSURE OVER 24 HOURS

This scenario looks at the pressure of the existing system and the future reservoirs. As Figure 6-7 shows, the existing system operates with some low-pressure areas in the east part of Zone 1. These areas are primarily due to low demand within the system.

6.5.6 SCENARIO 2, EXISTING SYSTEM, MDD, EPS, MAX PIPE VELOCITY OVER 24 HOURS

This scenario looks at the MDD for the existing system modeled with the future reservoirs to check for excess velocity. Velocity below ten (10) fps is acceptable, with a preferred velocity of five (5) fps. As Figure 6-8 shows, four (4) areas exceed ten (10) fps and should be upsized. These projects are shown and explained further in Table 6-2.



	Street	From	То	Existing Material	Length (ft)	Existing Diameter (in)	Proposed Diameter (in)	New Material
	Pioneer Ave	Nevada St	Alabama St	DIP	2608	6	12	DIP
NP-CIP-1	Alabama St	Pioneer Ave	625' South of Pioneer St	DIP/PVC	624	6	12	DIP
Subtotal					3232			
NP-CIP-2	Orange Tree Ln	California St	Oregon St	DIP	1900	6	8	DIP
	Orange Tree Ln	Oregon St	240' East of Plum Ln	PVC	1468	8	10	DIP
Subtotal					3368			
NP-CIP-3	Texonia Park	N//A	N//A	DIP	1006	10 & 12	16	DIP
	W Lugonia Ave	Texas St	Lawton St	PVC	1200	6,8, & 10	12	DIP
Subtotal					2206			
NP-CIP-4	State St	260' West of Center St	New York St	UNK/DW	1217	16 & 20	24	DIP
	New York St	State St	900' South of State St	DW/ACP/ CML	899.95	17 & 20	24	DIP
Subtotal					2117			

Table 6-2: Undersized Non-Potable Water System Pipelines


6.5.7 OTHER AGENCIES


Currently, three (3) other agencies operate non-potable water sources within the City water service area and its sphere of influence. The Crafton Water Company (CWC), BVMWC, and Western Height Water agencies. These water agencies primarily irrigate City-owned agricultural and landscape areas within the City and its sphere of influence. The City has partial ownership of these and several other local water companies. Additional water stock information is available on the City website. The City owns 184 acres of citrus groves divided into twenty-three (23) separate groves. BVMWC provides irrigation water for seven (7) of these groves and some nearby parks. CWC provides irrigation water for two (2) groves and parts of Crafton. These groves and the water providers are listed in Table 6-3.



No.	Name ¹	Water Provider ²	Acres ¹
1	Mullin	Bear Valley	8.5
2	Judson	Bear Valley	13.1
3	Lugonia	Bear Valley	18
4	Pioneer & Judson East	Bear Valley	2.7
5	Pioneer & Judson West	Bear Valley	4.3
6	Dearborn & Pioneer	Bear Valley	8.6
7	Granite	Bear Valley	2.7
	Subtotal		57.9
8	Fifth Ave	C.W.C.	10.6
9	Jacinto Memorial	C.W.C.	4.2
	Subtotal		14.8
10	Riverview	Groves on Wells	5.9
11	University Grove	Groves on Wells	23.5
	Subtotal		29.4
12	Ramirez	Recycled Water	4.6
13	Daniels	Recycled Water	4.9
	Subtotal		9.5
14	Beal Park	City	0.4
15	California	City	4.8
16	Fire Station 262	City	0.04
17	Mountain View	City	13.9
18	Olive	City	3.7
19	Prospect	City	25
20	Texas	City	12.5
21	Wabash	City	1.4
22	West Redlands Gateway	City	6.4
23	West Riverview	City	4.3
	Subtotal		72.44
	Total		184.04
ote: (1) F ty.	From City Owned Citrus Grove Ma	o provided by the City; (2) F	Provided by t

Table 6-3: City-Owned Citrus Groves







7 FUTURE SYSTEM

7.1 GENERAL DESCRIPTION

Several additional potable water system scenarios were analyzed to evaluate future operating conditions and evaluate pressure and pipeline flow velocity under these conditions. The future conditions were selected to represent 2042 projected water demands, assuming that all improvements identified in Section 6 are completed. Five (5) scenarios were analyzed, including ADD, MDD, PHD, and fire flow conditions. The results are summarized in color-coded maps to quickly identify out-of-range pressure nodes and/or undersized pipeline segments. Additional CIP project recommendations were developed based on this analysis.

The City's existing non-potable water system was analyzed to develop a future water system to decrease potable water use and better serve the City's existing recycled/non-potable water system. Scenarios were modeled to evaluate system pressure and velocity under various conditions, and evaluated against the design criteria. Utility billing data was used to identify potential customers for expansion of the system. When possible, meters providing agricultural or landscape irrigation water were read to supplement the utility billing data. New pipelines are assumed to be eight inches (8") in diameter, and the hydraulic model assumed construction of the WWTP recycled water storage reservoirs was complete.

7.2 FUTURE SUPPLY ANALYSIS – POTABLE WATER SYSTEM

7.2.1 SCENARIO 1 FUTURE DEMAND, EXISTING SYSTEM, MDD, FIRE FLOW SCENARIO, RESIDUAL PRESSURE DURING FIRE HOURS.

This scenario used the predicted future MDD of approximately thirty-seven (37) MGD to analyze fire flow and used the minimum of twenty (20) psi of residual pressure for fire hydrants. Figure 7-1 shows areas of concern that appear similar to the existing demand analysis. The pipe sections with deficiencies are included in the CIP list in Table 7-1.

7.2.2 SCENARIO 2 FUTURE DEMAND, EXISTING SYSTEM, MDD, EPS SCENARIO, MAX PRESSURE OVER 24 HOURS.

This scenario used the existing system under the future MDD of approximately thirty-seven (37) MGD to predict the distribution of pressure within the system. Figure 7-2 shows the results of this analysis. Areas of high pressure were identified primarily in the west sized of Zone 1570, portions of Zone 1750, and in the western portions of Zone 2100.

7.2.3 SCENARIO 3 FUTURE DEMAND, ADD, EPS SCENARIO, MAX PRESSURE OVER 24 HOURS

This scenario analyzed the future ADD and the maximum pressure in the system. The simulation identified pressures higher than 150 psi within the western portion of Pressure Zones 1570, 1900, and 2340. The results are shown in Figure 7-3.

7.2.4 SCENARIO 4 FUTURE DEMAND, MDD, EPS SCENARIO, MIN PRESSURE OVER 24 HOURS


This scenario analyzed the future MDD to locate minimum pressures. It shows that the low-pressure system area is primarily in the western portion of Pressure Zone 2100. The western parts of Pressure Zone 1570 and 2340 still have high pressures. The results are shown in Figure 7-4.





7.2.5 SCENARIO 5 FUTURE DEMAND, MDD, EPS SCENARIO, MAX VELOCITY OVER 24 HOURS This scenario analyzed the future MDD velocities within the existing system. It shows isolated areas where velocities are above 10 feet per second. These pipelines are included in the CIP list in Table 7-1. The results are shown in Figure 7-5.


7.2.6 SCENARIO 6 FUTURE DEMAND, FUTURE SYSTEM, MDD, FIRE FLOW SCENARIO, RESIDUAL PRESSURE DURING FIRE HOURS.


This scenario analyzed the future MDD of the system during a fire flow event. The low residual pressures are included in the CIP list in Table 7-1. The results are shown in Figure 7-6.
















7.3 FUTURE SUPPLY ANALYSIS – NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM

7.3.1 SCENARIO 1, FUTURE SYSTEM, ADD, EPS, MAX PRESSURE OVER 24 HOURS

As Figure 7-7 shows, the expanded system is within the forty (40) psi and 150 psi pressure design criteria. This will prevent loud noise and fatigue due to high water pressure, and will provide adequate water pressure to the City's customers.

7.3.2 SCENARIO 2, FUTURE SYSTEM, ADD, EPS, MAX PIPE VELOCITY OVER 24 HOURS


This scenario looks at the ADD for the expanded system to check for high velocities. As Figure 7-8 shows, the developed system will result in a few pipelines that will exceed the maximum acceptable velocity of ten (10) fps.


7.3.3 SCENARIO 3, FUTURE SYSTEM, MDD, EPS, MAX PRESSURE OVER 24 HOURS


The maximum pressure scenario was run to determine the system's pressure during the MDD. Figure 7-9 shows that most of the system will have adequate demand, with a few areas that slightly exceed the recommended pressure range of forty (40) psi and 150 psi.


7.3.4 SCENARIO 4, FUTURE SYSTEM, MDD, EPS, MAX PIPE VELOCITY OVER 24 HOURS

This scenario looks at the PHD for the expanded system to check for high velocities, and assumes a MDD peaking factor of 2.7. As Figure 7-10 shows, the developed system will result in a few pipelines that will exceed the maximum acceptable velocity of ten (10) fps. However, these pipelines are the same as those in the existing system analysis.











7.4 SUMMARY OF DEFICIENCIES

7.4.1 POTABLE WATER SYSTEM

Twelve (12) potable water system deficiencies were identified, and each were recommended a CIP project to resolve the issue. These deficiencies are related to high velocities, low fire flow pressure, and undersized pipelines. The list of deficiencies discovered is shown in Table 7-1.

CIP	P Location Reason Comments			
	Location	Reason	connents	
CIP-1	San Bernardino Ave/Agate	Maximum velocity > 10	Replace with larger pipe	
	Ave	fps		
CIP-2	Mill Creek Rd	Maximum velocity > 10	Dead ends removed from CIP due to no	
		fps	demand. Extended Pipeline replacement	
			to Mill Creek Rd.	
CIP-3	University St/Colton Ave	Fire Flow Pressure	May not be part of the potable water City.	
		Issues	May be removed if so. Looped to	
			Brockton Ave and Colton Ave to fix issues.	
CIP-4	Naples Ave (Jasper Ave	Fire Flow Pressure	Leaning dead and to Nice St to fix issue	
CIP-4	Naples Ave/Jasper Ave	Issues	Looping dead-end to Nice St to fix issue.	
CIP-5	Wabach Ava/6th Ava	Fire Flow Pressure	Complex Project, Changing contingency of	
CIP-5	Wabash Ave/6th Ave	Issues	project from 30% to 40%.	
CIP-6	Pennsylvania Ave/De Anza	Fire Flow Pressure	Replace with larger pipe	
CIP-0	St	Issues	Replace with larger pipe	
CIP-7	Park Ave/Cook St	Pipe Diameter Size too	Replace with larger pipe	
CIP-7	Park Ave/Cook St	small	Replace with larger pipe	
CIP-8	Valencia Dr	Maximum velocity > 10	Assumed to be a Lateral due to the pipe	
CIP-0	Valencia Di	fps	being a dead-end and small diameter	
CIP-9	San Bernardino Ave	Maximum velocity > 10	Small Diameter Size causing high velocity,	
CIP-9		fps	assumed to be error	
CIP-10	Bark Ava/Now Jarsov St	Fire Flow Pressure	Fire flow was determined to be lower	
	Park Ave/New Jersey St	Issues	than assumed	
CIP-11	Emerald Ave/Newport Ave	Fire Flow Pressure	Low pressure due to elevation. A subzone	
	Emeralu Ave/Newport Ave	Issues	may be needed to fix issue	
CIP-12	Suncot Dr/Eairmont Dr	Fire Flow Pressure	Low pressure due to elevation. A subzone	
CIP-12	Sunset Dr/Fairmont Dr	Issues	may be needed to fix issue	

Table 7-1: Potable Water System Deficiencies

7.4.2 NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM

Currently, no storage reservoirs exist within the recycled water system. The City is currently engineering two (2) 1.5 MG recycled water reservoirs for future construction at the WWTP. Additional system storage will be necessary as demand increases. Also, the detached non-potable water systems are not efficient and should be connected in the future. Doing so allows additional connections to be transitioned to the non-potable water system, which will reduce potable water system demand.



7.5 MITIGATION OF DEFICIENCIES

7.5.1 METHODOLOGY

The primary method of correcting high velocity or low pressure associated with fire flow demand is to increase the pipe diameter or loop dead ends, where possible. The issues found in the potable water system modeling can be corrected by increasing pipe diameters or looping in some areas. The non-potable water system and recycled water system can be improved by adding storage capacity and joining disconnected systems.

7.5.2 PROJECTS FOR FUTURE CONDITIONS – POTABLE WATER SYSTEM

Deficient pipeline segments are listed in Table 7-2 along with the recommended replacement pipeline diameter, the segment length, and the estimated cost for each. The cost estimate includes labor, equipment, materials, for each project, and a budget for unanticipated construction issues. The approach to developing cost estimates is explained in Section 10. The total length of all projects is five (5) miles and is estimated to cost approximately \$3.7M. Figure 7-11 shows the locations of each deficient pipeline segment. Figure 7-12 and Figure 7-13 show the anticipated system hydraulic improvements if all deficiencies are resolved.

	New Replacement Length				
CIP	Diameter (in)	Material	(LF)	Cost Estimate	
CIP-1	24	DIP	2046	\$654,720	
CIP-2	8	DIP	203	\$33,000	
CIP-3	8	DIP	242	\$39,000	
CIP-4	8	DIP	649	\$104,000	
CIP-5	12	DIP	11979	\$2,395,800	
CIP-6	8	DIP	1142	\$183,000	
CIP-7	8	DIP	1569	\$251,000	
CIP-8	N/A	DIP	TBD	TBD	
CIP-9	N/A	DIP	TBD	TBD	
CIP-10	N/A	DIP	TBD	TBD	
CIP-11	N/A	DIP	TBD	TBD	
CIP-12	N/A	DIP	TBD	TBD	
	Totals		27,193	\$ 3,660,520	

Table 7-2: Recommended CIP to Correct Deficiencies


7.5.3 PROJECTS FOR FUTURE CONDITIONS – NON-POTABLE WATER SYSTEM & RECYCLED WATER SYSTEM


Currently, no storage reservoirs exist within the recycled water system. The City is currently engineering two (2) 1.5 MG recycled water reservoirs for future construction at the WWTP. It is recommended that another reservoir be constructed in Zone 1. The specific location for this reservoir requires additional analysis. It is recommended that the minimum storage capacity for the expanded system be three (3) MG.


It is also recommended that detached systems be connected where practical. Connecting all detached systems would require approximately sixty (60) miles of eight inch (8") diameter pipelines, and a small amount of twelve inch (12") pipelines, throughout the west and southwest portions of the City.



Connecting the Redlands Country Club, Hillside Memorial Park, and Redlands Dog Park systems would allow additional connection transitions to the Pressure System 2 of the non-potable water system, potentially reducing potable water system demand by 0.9 MGD.









8 WATER QUALITY

8.1 METHODOLOGY

A common water quality concern in potable water distribution systems is water age. Water quality degrades over time and the loss of disinfection residual often leads to customer taste and odor complaints. Though not as strict as the requirements for potable water, the non-potable and recycled water systems must meet specific state and federal regulatory requirements for irrigation, agricultural, and commercial/industrial uses. Due to the lack of storage reservoirs in the existing non-potable water system and recycled water system, water age is not a good indicator of water quality, and should be analyzed when reservoirs are added to the systems.

8.2 REGULATORY REQUIREMENTS

The State of California and the U.S. EPA require potable water to meet rigid water quality standards prior to distribution. The City obtains water from surface and groundwater sources. Groundwater sources typically contain more microbial contaminants, inorganic contaminants, pesticides, herbicides, and industrial chemical byproducts. As a result, wells are closely monitored to make sure that the water being pumped from the Bunker Hill groundwater basin meets all regulatory requirements.

Recycled water regulations are identified in the California Code of Regulations 2018 Title 22 – Division 4 Chapter 3. Because the WWTP process includes tertiary treatment and disinfection, the following recycled water common uses are allowed:

- 1. Irrigation of food crops, including all edible root crops, where the recycled water comes into contact with the edible portion of the crop;
- 2. Irrigation of parks and playgrounds;
- 3. Irrigation of school yards;
- 4. Irrigation of residential landscaping;
- 5. Irrigation of golf courses;
- 6. Any other irrigation uses not specified in this section and not prohibited by different areas of the California Code of Regulations.

Tertiary water is also allowed for industrial and commercial cooling, and is used at the SCE Mountain View Power Plant. Groundwater extracted by the non-potable water wells is typically classified as undisinfected secondary water, and can be used for surface irrigation. However, more rigid water quality standards may apply when this groundwater may be reasonably expected to contact the edible portion of food crops.

8.3 GOALS AND PREFERENCES

The City must not exceed potable water MCL established by the state and federal regulatory agencies for coliform bacteria, turbidity, metals like aluminum and lead, nitrates, fluoride, and other contaminants. State and federal regulatory agencies also establish Primary Drinking Water Standards to regulate other pollutants. Finally, the U.S. EPA has established secondary standards for drinking water aesthetics. The City has not violated any of these regulations or standards. Disinfected tertiary recycled water standards are identified in the State of California Code of Regulations.



8.4 ASBESTOS

The City water distribution systems include approximately 200 miles of asbestos cement pipelines, which can release asbestos fibers into the water supply if the pipeline has deteriorated. Asbestos is a known carcinogen that can cause breathing problems, lung cancer, Mesothelioma, and a host of other health problems when certain exposure conditions exist. State regulatory agencies have established a limit of seven (7) million asbestos fibers per liter of water. It is recommended that these pipelines are evaluated for replacement if they exceed their service life or are found to have integrity issues that could cause asbestos to enter the water system.

8.5 GROUNDWATER QUALITY

The Upper Santa Ana Valley Groundwater Basin is an alluvial groundwater basin fed by multiple tributaries, including the Santa Ana River and Mill Creek, which are located within the City's water service area. The Bunker Hill Sub-basin, also known as the San Bernardino Basin Area (SBBA), lies within a portion of the Upper Santa Ana Valley Groundwater Basin and has a surface area of approximately 89,600 acres and a groundwater storage capacity of 5,976,000 acre-feet.

8.5.1 BUNKER HILL SUBBASIN/SBB

Based on the State's Department of Water Resources, *Upper Santa Ana Valley Groundwater Basin, Bunker Hill Sub-basin Report*, the SBBA is part of the northeastern portion of the Upper Santa Ana Valley Basin. The Santa Ana River, Mill Creek, and Lytle Creek are the main tributaries for this sub-basin, which is bordered by the San Gabriel Mountains, San Bernardino Mountains, and Crafton Hills. The Banning fault, Redlands Fault, San Andrea Fault, San Jacinto Fault, and the Glen Helen fault are located within the SBBA as well. The total dissolved solids (TDS) of the SBBA groundwater is typically 155 mg/l - 1,140 mg/l, and some portions of the SBBA frequently exceed MCL standards for nitrates, perchlorates, volatile organic compounds (VOC), and Synthetic Organic Compounds (SOC).

The City is located in the southern portion of the SBBA, and extracts SBBA groundwater for potable water and non-potable water production. SBBA water meeting state and federal water quality standards does not need additional treatment or disinfection for potable use. Alternatively, extracted groundwater exceeding nitrate or perchlorate MCLs may be distributed for non-potable use.

8.6 SOURCE WATER QUALITY

When available, the Hinckley and Tate raw water influent may be supplemented with SWP water for treatment and potable water distribution. The City has ownership in various private and mutual water companies to supply water to the City's Tate and Hinckley WTP. SWP water is not always available, and is only used as a last resort. SWP water often includes organics and sediment that are difficult to treat, so it is typically blended with raw water influent from other sources prior to treatment.

The quality of non-potable water varies depending on the extraction location. Groundwater extracted from one (1) location may be blended with groundwater extracted from another location to improve water quality within the non-potable water distribution system.

The City WWTP typically produces recycled water with less than five (5) mg/l BOD, five (5) mg/l TSS, ten (10) mg/l total nitrogen, and 0.2 NTU turbidity. This water can be blended with non-potable water to further improve water quality. Constructing recycled water storage reservoirs will create additional opportunities to improve water quality.



8.7 DISINFECTION

The City disinfects water with Sodium Hypochlorite and chlorine gas to prevent microbial contaminant migration into the potable water system. The disinfectant residual typically ranges from 0.8 mg/l -1.2 mg/l.

8.8 WATER AGE

The water age in water supply systems depends primarily on maintaining an efficient demand and supply balance through the use of SCADA, providing adequate water storage volume, and operation and maintenance practices. The potable water system is designed to provide storage reserve to support emergency relief efforts such as fire suppression and earthquake damage.

The Water Industry Database (AWWA and AWWA RF 1992) indicates an average potable water distribution system retention time of 1.3 days and a maximum retention time of twenty-four (24) days based on a survey of more than 800 U.S. utilities. In addition, the literature cites examples of both "short" (less than three days) and "long" (greater than three days) water ages. Several water age recommendations published in the literature are summarized below in Table 8-1.

Table 0-1. Water Age Neconimendations						
Population Served	Water Main Length (mi)	Water Ages (Days)	Method of Determination			
800,000			Hydraulic Model			
300,000	1,100	1 to 3	Fluoride tracer			
80,000	358	More than 16	Chloramine Conversion			
24,000 86 12 to 24 Hydraulic Model						
Note: Source is USEPA Effects of Water Age on Distribution System Water Quality, August 15, 2002						

Table 8-1: Water Age Recommendations

Several smaller cities with populations between 50,000 - 100,000 report water age of three (3) to sixteen (16).

8.9 WATER AGE POTENTIAL HEALTH IMPACTS

Potential health impacts associated with the water age-related chemical and biological issues are identified in Table 8-2.

..

Table 8-2: Potential Water Age Issues					
Chemical Issues	Biological Issues	Physical Issues			
Disinfection By-Product Formation	Disinfection By-Product Biodegradation	Temperature			
		Increase			
Disinfectant Decay	Nitrification	Sediment Deposition			
Corrosion Control Effectiveness	Microbial Regrowth/Recovery/Shielding	Color			
Taste and Odor	Taste and Odor				
Note: (1) The source is USEPA Effects of Water Age on Distribution System Water Quality, August 15, 2002; (2) The					
Chemical Health Effects Tables (U.S. EPA, 2002a) summarizes potential adverse health effects from high/long-term					
exposure to hazardous chemicals in drin	king water.				

The Microbial Health Effects Tables (U.S. EPA, 2002b) summarizes potential health effects from exposure to waterborne pathogens, the most concerning of which are the formation of disinfection by-products, presence of haloacedic acid (HAA5) and trihalomethanes (TTHM), and nitrification and microbial regrowth after disinfectant depletion.



8.10 WATER AGE DETERMINATION

Water age can be predicted by conducting hydraulic modeling and analysis, mathematical modeling and fluid dynamics computations, and tracer studies using fluoride, sodium chloride, calcium chloride, lithium chloride, pulsed chlorine, and coagulants. Mathematical modeling is arguably the least accurate of these methods.

8.11 CITY OF REDLANDS WATER SUPPLY SYSTEM AGE

An ADD potable water age analysis was conducted using the hydraulic model, as shown in Figure 8-1, and indicated typical water age is three (3) days, and increases to twelve (12) days at the edges of the water system and in the potable water storage reservoirs. More specifically, water age within the potable water system distribution system piping is typically one to three (1 - 3) days, and storage reservoir water age is typically seven to twelve (7 - 12) days.

Water age is primarily a function of the system size, operation, SCADA automation, and design. As water demand increases, the amount of residence time in the distribution system decreases. Demand is related to land use patterns, types of commercial-industrial activity present in a community, weather, the general living conditions (pandemic, work from home, etc.), and community water use habits (water conservation practices, reuse practices, etc.). Cities with effective water conservation programs typically experience greater water age when all other factors are constant, due to reduced demands.

The water age analysis, water quality data review, and site visits did not indicate water quality issues within the City potable water supply system. This finding is consistent with the annual Consumer Confidence Report (CCR) prepared and distributed to all potable water customers to provide specific water quality characteristics. The CCR complies with state and federal regulatory agency requirements. The installation of mechanical mixers in potable water storage reservoirs is recommended to prevent water quality issues related to longer retention times. Table 8-3 summarizes the storage reservoir hydraulic model water age evaluation.

Table 8-3: Storage Reservoir Water Age						
Reservoir	Percent Full	Level (ft)	Water Age (days)			
	(%)	()	(00.90)			
5th Ave	53	11.92	11.3			
Agate	72	18.04	7.0			
Arroyo	59	23.74	11.0			
Country Club Reservoirs	66	12.6	11.1			
Crafton	19	5.63	11.7			
Dearborn	31	7.9	11.7			
Highland	68	18.91	11.3			
Margarita	85	11.96	11.7			
Mill Creek	58	11.57	11.2			
Sand Canyon	29	11.37	11.7			
Smiley	32	7.12	10.1			
South Ave	75	19.53	10.7			
Sunset	39	24.5	11.6			


Table 8-3: Storage Reservoir Water Age



Reservoir	Percent Full (%)	Level (ft)	Water Age (days)
Texas Grove	77	15.32	11.4
Texas St	84	29.45	11.5
Ward Way Reservoirs	51	15.92	11.7

8.12 INDICATORS OF HIGH WATER AGE

Aesthetic issues such as discoloration, poor taste, and noxious odors may be caused by water age, deteriorating pipeline materials, treatment and disinfection practices, and turbidity. No aesthetic issues were noted during the site visits and contacts with the Operations staff.





9 WATER SYSTEM OPERATION AND MAINTENANCE

9.1 GENERAL DESCRIPTION

Operations and maintenance practices for all water systems were reviewed to develop improvement recommendations. This included a review of available records and operating procedures during several site visits and MUED staff workshops.

9.2 SCADA

Water Production Operators monitor and operate the water system through a comprehensive SCADA system. SCADA is used to gather and analyze real-time or near real-time sensor data, which is used for monitoring treatment plants, transmission, and distribution processes. The system monitors pressure and flow, storage reservoir levels, and treatment processes. SCADA is also useful for collecting regulatory reporting data, obtaining operational information for planning purposes, optimizing energy and chemical use, identifying water loss, and improving various maintenance practices. The City is developing Standard Operating Procedures (SOP) for the operation, security, and long-term maintenance of the SCADA system.

9.3 WORK ORDER PROCESS

The City is currently implementing an electronic asset management system to improve work order processing efficiency. This system populates a database that will be used to accurately determine operation and maintenance resource needs and associated costs, including labor, equipment, materials, price, date, and location tracking.

9.4 INSPECTION AND MAINTENANCE

The MUED staff inspects water production and distribution facilities routinely and has inspection and maintenance protocols in place for treatment plants, storage reservoirs, wells, booster pumps, and other equipment. Preventive maintenance activities are conducted in accordance with manufacturer recommendations. The CIP project recommendations include regularly scheduled mechanical and electrical equipment maintenance and replacement, storage reservoir inspection and maintenance, and other routine practices to ensure the water systems continue to function efficiently.

9.5 WATER SYSTEM STAFF AND MANAGEMENT

The MUED organization includes Water Distribution (WD), Water Production (WP), and WWTP Divisions to operate and maintain the water systems. The MUED organizational chart is provided in Chart 9-1. The Utilities Operations Manager oversees all water and wastewater production, distribution, operation, and maintenance practices, and is supported by a Regulatory Compliance Officer and an Administrative Assistant.

The WD Division includes Water Distribution System Operators and Field Technicians. The Field Technicians are primarily responsible for servicing and reading water meters for water utility billing. Most water meters are read manually or with an Automated Meter Reader (AMR) system, both of which are labor intensive. This group includes the following staff positions:

- Senior Customer Service Field Technician (1)
- Customer Service Field Technician (1)
- Meter Readers (3)



The Water Distribution Operators maintain the water distribution systems. This group includes the following staff positions:

- Water Distribution Superintendent (1)
- Cross Connection Control Inspector (1)
- Water Distribution Supervisor (1)
- Water Distribution Crew Leaders (4)
- Water Distribution Operators (12)

The Water Production Division operates and maintains all water production facilities, including WTP, storage reservoirs, groundwater wells, pressure reducing valves, and booster pumps. This group includes the following staff positions:

- Water Production Superintendent (1)
- Administrative Assistant (1)
- Water Production Supervisor (1)
- Water Maintenance Supervisor (1)
- Maintenance Foreperson (1)
- Water Treatment Operator (8)
- Water Quality Technician (3)
- Plant Mechanic (3)
- Maintenance Worker (3)
- Electrical & Instrumentation Technician (2)

The WWTP Division is responsible for recycled water production from the City WWTP effluent. This group includes the following staff positions:

- Wastewater Operations Superintendent (1)
- Administrative Assistant (1)
- Wastewater Operations Supervisor (1)
- Wastewater Collections Supervisor (1)
- Maintenance Foreperson (1)
- Wastewater Facilities Operator (6)
- Plant Mechanic (3)
- Maintenance Worker (2)
- Line Maintenance Worker (7)
- Laboratory Manager (1)
- Laboratory Analyst (4)

MUED staffing for operation and maintenance of the potable water system, non-potable water system, and recycled water system is appropriate for the size and complexity of each system, and meets general



guidance provided in the U.S. EPA Public Water System Classification and Staffing Requirements and AWWA M5 manual.

Chart 9-1: Maintenance and Operations Organization Chart (Placeholder – Final Draft will include the finalized organization chart)



10 CAPITAL IMPROVEMENT PROGRAM

10.1 GENERAL DESCRIPTION

This section presents the proposed capital improvements for the next five (5) years and a general description of the improvements recommended through 2042. This section also recommends recurring annual capital expenditures to repair or replace aging and outdated infrastructure, including meter and pipeline replacements. The water systems analysis described in sections 6 and 7 was used as the basis for identifying CIP project recommendations. The CIP project recommendations are based on a review of the existing City CIP, as well as deficiencies predicted by the hydraulic model in the existing infrastructure for current conditions and projected future growth conditions.

The CIP projects were evaluated based on the following:

- Hydraulic analysis of existing and projected water supply systems requirements;
- Condition assessment based on the visual inspection of the Hinckley and Tate WTP, reservoir sites with booster pumps, and associated electrical and mechanical equipment;
- Risk-based asset register database evaluation.

The hierarchy of projects is established using several methodologies. The first methodology employed is a hydraulic analysis of existing and future water supply systems. The highest priority projects are those with hydraulic deficiencies and/or regulatory compliance issues. These are planned for the first five-year period. The following criticality methodology relies on the well and booster pump efficiency analysis and the distribution systems age. The third methodology uses condition assessment based on the site visits.

10.1.1 APPROACH TO PLANNING LEVEL COSTS

Each CIP project recommendation includes an OPC based on planning level quantity estimates. Unit costs are based on vendor quotes and actual bid prices for projects of similar scope and size. In some cases, the OPC was adjusted to account for specific site conditions. Each OPC includes standard mark-ups for contingencies, engineering fees, legal fees, administrative costs, and other soft costs to provide a complete budget level prediction of project costs. Table 10-1 summarizes OPC assumptions for each CIP project recommendation.

OPC Item	Markup Assumption			
Construction Contingency	10%-25% ¹			
Engineering	15%			
Legal & Administration	5%			
TOTAL	1.30x-1.45x Construction Cost ¹			
Note: (1) Varies based on the complexity of the project.				

Table 10-1: CIP Project Recommendation OPC Assumptions

Many of the recommended projects consist of replacing water pipelines, rehabilitation of existing well sites and equipment, booster pump repair or replacement, or rehabilitation of reservoir facilities. Modifications and upgrades to existing pumping facilities tend to be more complex than pipeline replacement projects, and higher contingency and soft cost factors were used for these facilities. All cost



opinions are shown in 2022 dollar values, and should be escalated for project implementation in future years. Each OPC is considered a Class 5 Construction Cost Opinion as defined by the Association for the Advancement of Cost Engineering (AACE) International Recommended Practice No. 18R-97. Table 10-2 below defines the various cost opinion classes defined by AACE International.

	Primary Characteristic	Secondary Characteristic				
COST	Level of Project Definition	End Usage	End Usage Methodology		Preparation Effort	
OPINION CLASS	Expressed as % of Complete Definition	Typical Purpose of Cost Opinion	Typical Estimating Method	Typical Variation in Low and High ranges (a)	Typical Degree of effort relative To Least Cost Index of 1(b)	
Class 5	0% to 2%	Concept Screening	Capacity Factored. Parametric Models. Judgment or Analogy	L: -20% to -50% H: +30% to +100%	1	
Class 4	1% to 15%	Study or Feasibility	Equipment Factored or Parametric Model	L: -15% to -30% H: +20% to +50%	2 to 4	
Class 3	10% to 40%	Budget Authorization , or Control	Semi-Detailed Unit Costs with Assembly Level Line Items	L: -10% to -20% H: +10% to +30%	3 to 10	
Class 2	30% to 70%	Control or Bid/ Tender	Detailed Unit Cost with Forced Detailed Take- Off	L: -5% to -15% H: +5% to +20%	4 to 20	
Class 1	50% to 100%	Check Estimate or Bid/Tender	Detailed Unit Cost with Detailed Take-Off	L: -3% to -10% H: +3% to +15%	5 to 100	

Table 10-2: AACE Construction Cost Classes

Note: (1) The state of process technology and applicable reference cost data availability affects the range markedly. The +/- value represents typical percentage variation of actual costs from the cost estimate after applying contingency (typically at a 50% level of confidence) for a given scope.

(2) If the range index value of "1" represents 0.005% of project costs, then an index value of 100 represents 0.5%. Estimate preparation effort depends on the size of the Project and the quality of estimating data and tools.



10.2 OPINION OF PROBABLE COST

The CIP projects consist of specific project recommendations to repair, replace, or upgrade existing facilities. Recurring consumable replacement and preventive maintenance requirements are generally excluded and not considered a capital improvement. The CIP projects for potable water have been divided into six (6) broad categories, sorted by the facility type. Each category is described below.

10.2.1 CIP ITEM W1: POTABLE WATER DISTRIBUTION SYSTEM

CIP item W1 includes projects that are part of the potable water distribution system, including pipelines, pipeline appurtenances, and metering infrastructure.

The potable water system elements are proposed for replacement because of the 12.8% water loss reported in 2020. The losses include meter inaccuracies and other possible contributors such as unaccounted connections. Reductions in water loss after successfully implementing the proposed CIP could significantly offset the initial investment. The City has replaced aging pipelines annually since 2010, totaling to more than eighty-nine (89) miles of replaced pipeline. In 2015, the City developed a funding plan that included revenue increases to continue this practice annually. Metering of the distribution system is also included in the W1 project list. The potable water distribution system has been fully metered since 2008, and the City has a meter replacement and maintenance plan in place. Meters smaller than 2" are replaced every fifteen to twenty (15 - 20) years, and all meters over two inches (2") are calibrated and repaired if necessary to ensure accuracy. In 2021, the City began a five year project to replace all water meters within its service area.

Additionally, from 2014 to 2015, MUED staff conducted an audit on all commercial properties/accounts to ensure all connections were accounted for in the City's billing system. This allowed the City to decrease unaccounted for water loss and the associated loss in revenue. The City is currently implementing Advanced Metering Infrastructure (AMI) system to improve efficiency in the meter readings.

10.2.2 CIP ITEM W2: HINCKLEY TREATMENT PLANT

CIP item W2 includes projects located at the Hinckley WTP. As Hinckley ages, equipment will need to be repaired, replaced, and upgraded. CIP project recommendations are related to the following:

- Sludge Presses
- Generators
- MCC Installations
- Aging Mechanical Equipment

10.2.3 CIP ITEM W3: TATE TREATMENT PLANT

CIP item W3 includes projects identified at the Tate WTP. As Tate ages, equipment will need to be repaired, replaced, and upgraded. CIP project recommendations are related to the following:

- Raw Water Influent Line
- Clarifier Coating Systems
- Clarifier Covers
- Influent Flash Mixer



- NaOCI Disinfection System
- EIMCO Settlers
- MCC Installations
- Aging Mechanical Equipment

10.2.4 CIP ITEM W4: POTABLE WATER BOOSTER PUMP STATIONS

CIP item W4 includes projects located at the City's potable water booster pump stations. These projects primarily focus on station refurbishment or rehabilitation but may require other capital improvements. Maintaining and improving these booster stations can increase energy and water treatment efficiency. Booster pump stations will require rehabilitation as equipment ages and efficiency declines. CIP project recommendations assume a typical service life of twenty (20) years. Projects should be scheduled on a rotating basis to distribute the financial impact over the planning horizon. Brady completed a condition, seismic, and structural assessment of all water facilities, which should be used to supplement these CIP project recommendations. The executive summary of the assessment can be found in Appendix F.

10.2.5 CIP ITEM W5: POTABLE WATER STORAGE RESERVOIRS

CIP item W5 includes projects related to both the concrete and steel potable water storage reservoirs, including refurbishment and upgrades to meet current standards. Also included are projects to increase facility reliability, correct known deficiencies, and improve water quality within the tank. Brady completed a condition, seismic, and structural assessment of all water facilities, which should be used to supplement these CIP project recommendations. The executive summary of the assessment can be found in Appendix F.

Corrosion is visible on some equipment and steel storage reservoir exterior walls. Although the cathodic protection cabinets at some reservoirs are showing signs of aging, they are still functional and in working condition but are nearing the end of their service life. Steel storage reservoirs should be inspected, maintained, and retrofitted with corrosion protection or replaced. Steel storage reservoirs typically require recoating and corrosion repairs every twenty (20) years. After recoating, the steel tanks must be dewatered, inspected, and minor coating repairs made at regular intervals during the coating life. Concrete storage reservoirs typically require less frequent replacement and maintenance.

10.2.6 CIP ITEM W6: GROUNDWATER WELLS

CIP item W6 includes project recommendations related to groundwater wells. As groundwater wells age, they need to be repaired, replaced, and upgraded. In addition to physical wear, some wells may require improvements to resolve groundwater contaminant issues. Perchlorate has been detected at some groundwater wells, and the City will need to assess the need for perchlorate treatment at several well sites. This evaluation will determine the level and type of treatment necessary at each site. Currently Perchlorate levels at Well No. 38 and Well No. 39 will require design of a wellhead treatment system beginning in 2022.

By 2030 – 2035, additional potable water supply will be needed to meet demands. The use of groundwater wells will be less costly than the expansion of surface WTP. It is recommended that inactive well sites be assessed for rehabilitation, including measures to mitigate groundwater contamination where necessary, and returned to active status to increase potable water supply.



10.2.7 FUTURE WATER SUPPLY PLANNING

The City may need to increase water treatment capacity at Hinckley and/or Tate to meet future demands unless potable water use is decreased, or groundwater wells are refurbished and reactivated. However, to increase capacity at the Tate WTP will require an assessment and improvement to the distribution system to eliminate the bottleneck presently existing at the discharge from the Tate WTP. The extent of these capacity upgrades will be determined based on the expansion of the recycled water system and future demands. The need to increase treatment capacity will also be affected by the future availability of surface water and the number of active groundwater sources. CIP project recommendations that affect water supply and production should be scheduled and implemented before planning year 2035, when potable water demand could exceed available supply.

10.2.8 CIP NP1: NON-POTABLE WATER SYSTEM IMPROVEMENTS

CIP item NP1 includes project recommendations related to the repair, replacement, and improvement of non-potable wells, non-potable meter replacements, and general system deficiencies. Non-potable groundwater well sites should be inspected and maintained regularly, and rehabilitated every ten (10) years. Meters should be inspected and maintained regularly, including periodic accuracy verification, and replaced in accordance with manufacturer recommendations. The non-potable water system could be improved by implementing an AMI system to reduce operating costs. Three (3) CIP project recommendations will improve system hydraulics. These projects are recommended for completion within the next five (5) years.

Also included in NP1 are recommendations to expand and consolidate the non-potable water system at the City's discretion. This would include construction of new pipelines, along with associated booster stations and other necessary equipment.

10.2.9 CIP NP2: RECYCLED WATER SYSTEM IMPROVEMENTS

CIP NP2 includes project recommendations related to the repair, replacement, improvement, and expansion of the recycled water system. This includes the construction of two (2) storage reservoirs and several pipeline additions and replacements, and assumes all pipelines will be replaced within seventy (70) years

Also included in NP2 are recommendations to expand and consolidate the recycled water system at the City's discretion. This would include construction of new pipelines, including a transmission line from the WWTP's proposed storage reservoirs located in System 1 to System 2 at the Texas St. non-potable pumping station. It will also be necessary to construct a new non-potable reservoir or repurpose the existing potable water reservoir at this site. Improvements are also needed for other pipelines, associated booster stations, and other necessary equipment.

10.3 PROJECTS AND COSTS

10.3.1 POTABLE WATER SYSTEM CIP PROJECT RECOMMENDATIONS

Potable water system 5-year CIP project recommendations and estimated costs are provided in Table 10-3, and summarized by category in Chart 10-1.






Chart 10-1: Potable Water System 5-Year CIP Cost Summary

W1	Water Distribution System	FY 2022-23	Water CIP	FY 2024-25	FY 2025-26	FY 2026-27	5-year Total
W1-1	Pipeline Replacement	\$4,500,000	\$4,500,000	\$4,500,000	\$4,500,000	\$4,500,000	\$22,500,000
W1-2	Water Meter Replacements	\$1,815,000	\$1,815,000	\$1,815,000	\$1,815,000	\$1,815,000	\$9,075,000
	CIP W1 Subtotal	\$6,315,000	\$6,315,000	\$6,315,000	\$6,315,000	\$6,315,000	\$31,575,000
W2	Hinckley Treatment Plant	FY 2022-23	FY 2023-24	FY 2024-25	FY 2025-26	FY 2026-27	5-year Total
W2-1	Hinckley Sludge Press	\$355,000	\$345,000	\$0	\$0	\$0	\$700,000
W2-2	Replace Aging Mechanical & MCC Equipment	\$0	\$90,000	\$470,000	\$470,000	\$470,000	\$1,500,000
	CIP W2 Subtotal	\$355,000	\$435,000	\$470,000	\$470,000	\$470,000	\$2,200,000
W3	Tate Treatment Plant	FY 2022-23	FY 2023-24	FY 2024-25	FY 2025-26	FY 2026-27	5-year Total
W3-1	Tate Transmission Line Replacement	\$835,549	\$1,900,000	\$1,900,000	\$0	\$0	\$4,635,549
W3-2	Tate Clarifier Recoating	\$0	\$1,000,000	\$0	\$0	\$0	\$1,000,000
W3-3	Tate Clarifier Covers	\$0	\$1,560,000	\$0	\$0	\$0	\$1,560,000
W3-4	Tate Influent Flash Mixer	\$0	\$0	\$180,000	\$0	\$0	\$180,000
W3-5	Tate NaOCI Disinfection System	\$0	\$0	\$360,000	\$0	\$0	\$360,000
W3-6	Replace Aging Mechanical & MCC Equipment	\$0	\$90,000	\$470,000	\$470,000	\$520,000	\$1,550,000
	CIP W3 Subtotal	\$835,549	\$4,550,000	\$2,910,000	\$470,000	\$520,000	\$9,285,549
W4	Booster Stations	FY 2022-23	FY 2023-24	FY 2024-25	FY 2025-26	FY 2026-27	5-year Total
W4-1	1750 Blend Manifold Replacement	\$120,000	\$0	\$0	\$0	\$0	\$120,000
W4-2	Booster Pump Station Rehabilitation	\$300,000	\$300,000	\$300,000	\$300,000	\$300,000	\$1,500,000
	CIP W4 Subtotal	\$420,000	\$300,000	\$300,000	\$300,000	\$300,000	\$1,620,000
W5	Reservoirs - Potable	FY 2022-23	FY 2023-24	FY 2024-25	FY 2025-26	FY 2026-27	5-year Total
W5-1	Reservoir Sites Fixed Generators	\$0	\$750,000	\$300,000	\$300,000	\$300,000	\$1,650,000
W5-2	Sunset Reservoir Replacement	\$2,000,000	\$6,000,000	\$0	\$0	\$0	\$8,000,000



City of Redlands 2022 Water Systems Master Plan

W5-4	Seismic Assessment Improvements	\$1,000,000	\$2,891,000	\$0	\$1,571,333	\$0	\$5,462,333
W5-5	Texas Grove Reservoir Stair Installation	\$0	\$0	\$0	\$90,000	\$0	\$90,000
	CIP W5 Subtotal		\$9,641,000	\$300,000	\$1,961,333	\$300,000	\$15,202,333
W6	Groundwater Wells	FY 2022-23	FY 2023-24	FY 2024-25	FY 2025-26	FY 2026-27	5-year Total
							e year rotar
W6-1	Groundwater Well Equipping Rehabilitation	\$514,000	\$506,000	\$600,000	\$600,000	\$600,000	\$2,820,000
W6-2	East Lugonia Well 3 Replacement	\$0	\$0	\$3,000,000	\$0	\$0	\$3,000,000
W6-3	Groundwater Contamination Mitigation	\$575,000	\$575,000	\$1,000,000	\$0	\$0	\$2,150,000
W6-4	Entrained Air Treatment Assessment	\$0	\$0	\$600,000	\$0	\$0	\$600,000
	CIP W6 Subtotal	\$1,089,000	\$1,081,000	\$5,200,000	\$600,000	\$600,000	\$8,570,000

Potable water system 20-year CIP project recommendations and estimated costs are provided in Table 10-4, and summarized by category in Chart 10-2. Annually recurring projects are assumed to have the same costs each year. Figure 10-1 provides a map depicting the remaining service life of the potable water system facilities.

Table 10-4. 20- Teal Polable Water CIP Recommendations									
Project	2022-2026	2027-2031	2032-2036	2037-2041	20-year Total				
W1 - Water Distribution System	\$31,575,000	\$31,575,000	\$31,575,000	\$31,575,000	\$126,300,000				
W2 - Hinckley Treatment Plant ¹	\$2,200,00	N/A	N/A	N/A	\$2,200,00				
W3 - Tate Treatment Plant ¹	\$9,285,549	N/A	N/A	N/A	\$9,285,549				
W4 - Booster Stations - Potable	\$1,620,000	\$3,883,690	\$1,620,000	\$1,620,000	\$8,743,690				
W5 - Reservoirs - Potable	\$15,202,333	\$5,198,000	\$180,000	\$180,000	\$20,760,333				
W6 - Groundwater Wells ²	\$8,570,000	\$7,912,500	\$5,487,500	\$6,750,000	\$28,720,000				
Total	\$68,452,882	\$48,569,190	\$38,862,500	\$40,125,000	\$196,009,572				

Table 10-4: 20-Year Potable Water CIP Recommendations

Note: (1) A condition assessment was performed in 2021 on the Hinckley and Tate Treatment Plants based on current conditions. Hinckley is 36-year-old, and Tate is 55 years old. The mechanical and electrical equipment may need to be replaced in the future, but the information is not included and is labeled as Optional. The cost opinion for replacing mechanical and electrical equipment was based on the 2022 economic indices. The potential cost for each plant's electrical and mechanical replacement is estimated at 1-2 million dollars per year in the CIP planning horizon. Therefore, a detailed conditional mechanical and electrical equipment assessment is needed to determine accurate mechanical and electrical CIP elements. (2) The 20-year cost for W6 - Wellhead Treatment is dependent on the Wellhead Evaluation.







Chart 10-2: Potable Water System 20-Year CIP Cost Summary





Remaining Pipe Service Life



NP 2.2

10.3.2 NON-POTABLE WATER SYSTEM CIP PROJECT RECOMMENDATIONS

two & build in phases

Pipeline Replacement and Expansion

CIP NP 2 Subtotal

CIP NP 2 Subtotal

CIP NP Total

Non-potable water system 5-year CIP project recommendations and estimated costs are provided in Table 10-5.

NP 1	Non-potable Water Improvements	FY 2022-23	FY 2023-24	FY 2024-25	FY 2025-26	FY 2026-27	5-year Total
NP 1.1	Pipeline Replacement and Expansion	\$0	\$0	TBD	TBD	TBD	TBD
NP 1.2	Groundwater Well Equipment Rehabilitation	\$267,000	\$136,000	\$375,000	\$375,000	\$375,000	\$1,528,000
CIP NP 1 Subtotal		\$267,000	\$136,000	\$375,000	\$375,000	\$375,000	\$1,528,000
NP 2	Recycled Water Improvements	FY 2022-23	FY 2023-24	FY 2024-25	FY 2025-26	FY 2026-27	5-year Total
NP 2.1	Recycle Water Reservoirs - design	\$734,839	\$0	\$3,000,000	\$0	\$3,000,000	\$6,734,839

\$0

\$0

\$750,000

\$3,750,000

\$750,000

\$750,000

\$3,000,000

\$3,000,000

\$1,000,000

\$3,274,500

\$1,500,000

\$8,234,839

\$11,234,839

\$19,208,739

Table 10-5: 5-Year Non-Potable Water CIP Recommendations

Non-potable water system 20-year CIP project recommendations and estimated costs are provided in Table 10-6. Annually recurring projects are assumed to have the same costs each year. Figure 10-2 provides a map depicting the remaining service life of the non-potable and recycled water systems facilities.

\$0

\$734,839

NP 1	Non-potable Water Improvements	2022-2026	2027-2031	2032-2036	2037-2041	20-year Total
NP 1.1	Pipeline Replacement and Expansion	TBD	\$1,000,000	\$1,000,000	\$1,000,000	\$3,000,000
NP 1.2	Groundwater Well Equipment Rehabilitation	\$1,528,000	1,007,800	\$1,108,600	\$1,219,500	\$4,863,900
NP 1.3	Meter Replacement	\$0	\$0	\$55,000	\$55,000	\$110,000
	CIP NP 1 Subtotal	\$1,528,000	\$2,007,800	\$2,163,600	\$2,274,500	\$7,973,900
NP 2	Recycled Water Improvements	2022-2026	2027-2031	2032-2036	2037-2041	20-year Total
NP 2.1	Recycle Water Reservoirs - design two & build in phases	\$6,734,839	\$0	\$0	\$0	\$6,734,839
NP 2.2	Pipeline Replacement and Expansion	\$1,500,000	\$1,000,000	\$1,000,000	\$1,000,000	\$4,500,000

\$1,000,000

\$3,007,800


\$1,000,000

\$3,163,600

\$8,234,839

\$9,762,839

Table 10-6: 20-Year Non-Potable Water CIP Recommendations



O 0.5 1 Miles Redlands Recycled Water Pipes Remaining Service Life



10.4 THE CAPITAL IMPROVEMENT PROJECTS

The CIP project recommendations assume that projects that meet regulatory compliance requirements and resolve hydraulic deficiencies will be constructed first. Project priorities are likely to change as economic conditions and community demographics change. A comprehensive analysis of each project is necessary prior to implementation. Cost estimates are provided in 2022 dollars, and assume no property acquisition is necessary.

10.4.1 POTABLE WATER SYSTEM CIP PROJECT DESCRIPTIONS

CIP W1-1: Water Pipeline Replacements - Hydraulics

5-Year Budget Allocation: \$22,500,000


Priority: High

It is recommended that the City consider an annual project to replace pipelines to resolve hydraulic deficiencies as provided in Table 10-7. The first three (3) years should focus on replacing existing pipes with deficiencies that create high velocities and/or low pressures within the system. This project replaces approximately 27,193 LF of existing undersized pipelines with new eight inch (8"), twelve inch (12"), and twenty-four inch (24") diameter pipelines at twelve (12) locations.

СІР	New Diameter (in)	Length (ft)	Location	Issue	Budget	Year
CIP-1	24	2046	San Bernardino Ave/Agate Ave	High Velocity	\$654,720	2024
CIP-2	8	203	Mill Creek Rd	High Velocity	\$33,000	2022
CIP-3	8	242	University St/Colton Ave	Fire Flow	\$39,000	2023
CIP-4	8	649	Naples Ave/Jasper Ave	Fire Flow	\$104,000	2023
CIP-5	12	11979	Wabash Ave/6th Ave	Fire Flow	\$2,395,800	2024
CIP-6	8	1142	Pennsylvania Ave/De Anza St	Fire Flow	\$183,000	2022
CIP-7	8	1569	Park Ave/Cook St	Under-Sized	\$251,000	2023
CIP-8	N/A	TBD	Valencia Dr	High Velocity	TBD	TBD
CIP-9	N/A	TBD	San Bernardino Ave	High Velocity	TBD	TBD
CIP-10	N/A	TBD	Park Ave/New Jersey St	Fire Flow	TBD	TBD
CIP-11	N/A	TBD	Emerald Ave/Newport Ave	Fire Flow	TBD	TBD
CIP-12	N/A	TBD	Sunset Dr/Fairmont Dr	Fire Flow	TBD	TBD

Table 10-7: Pipeline Replacement

Approximately 34,320 LF (6.5 miles) of the City's 382 miles of water distribution pipelines are currently beyond the expected service life of the pipe material. It is recommended that the City continue to proactively replace aging pipelines once the material service life is reached. Chart 10-3 shows the service life distribution remaining in the City's pipelines.





Most of the City's pipelines have twenty to fifty (20-50) years of remaining service life, with about seventy (70) miles of pipeline service life ending in the next twenty (20) years. The City should continue to replace a portion of these lines each year, with a replacement goal of approximately 28,000 LF each year, which will replace all pipelines within seventy (70) years. Pipeline segments with hydraulic deficiencies are recommended to be replaced first, followed by aging asbestos-cement pipelines. All new pipelines should a minimum of eight inches (8") in diameter. Replacement pipeline segments should be selected yearly based on age and maintenance history, and coordinated with other projects, such as scheduled street rehabilitation projects.

CIP W1-2: Water Meter Replacement

\$9,075,000 5-year Budget Allocation:

Priority: Medium

In 2021, the City began a five (5) year annual project to replace all water meters. Table 10-8 provides the meter size and number of meters being replaced and Table 10-9 provides the number of meter size and number of meters being retro-fitted. It is recommended that this project be continued to reduce water loss within the system, and significantly increase revenue. After completion of the project, water meter accuracy testing should be conducted annually, meters will be replaced based on the test results, not on a predetermined length of time.

In 2022, the City began to update its meters to Automated Metering Infrastructure (AMI) to maintain accurate billing and analysis data. AMI will encourage water conservation and reap benefits for business and residential customers by allowing them the ability of real time water consumption.

Table 10-8: Meter Replacement				
Meter Size (in)	Number of Meters			
5/8"	117			
3/4"	4,682			
1"	7,415			
1 1/2"	521			



Meter Size (in)	Number of Meters
2"	497
3"	50
4"	30
6"	13
8"	8
12"	1
Total	13,334

Table 10-9: Meter Retro-Fit

60 3,417 4,346
4,346
233
259
27
22
14
6
8,384

CIP W2-1: Hinckley Sludge Press

5-Year Budget Allocation: \$700,000

Priority: Medium

This project engineers and installs a sludge press at Hinckley to reduce labor, equipment, and disposal costs associated with processing sludge residual to the treatment process.

CIP W2-2: Replace Aging Mechanical & MCC Equipment

5-Year Budget Allocation:	\$1,500,000
---------------------------	-------------

Priority: Medium

This project replaces and upgrades electrical and mechanical equipment at Hinckley as necessary. A comprehensive condition assessment should be completed annually to identify the remaining service life of equipment in order to prepare for replacement.

|--|

5-Year Budget Allocation:	\$4,635,549
Priority:	High



A Condition, Structural, & Seismic Assessment completed by Brady identified this as a top-priority project. The City selected a consultant to engineer the replacement of this raw water influent line, with the goal of constructing the project in the near-future.

5-Year Budget Allocation: \$1,000,000

Priority: Medium

The Tate Clarifier Recoating project is on the City's CIP list. Therefore, it is recommended that this project remains in the CIP. The recommended budget for this CIP is \$1,000,000.

CIP W3-3: Tate Clarifier Covers

5-Year Budget Allocation:	\$1,560,000
---------------------------	-------------

Priority: Medium

The Tate Clarifier Covers project is on the City's CIP list. Therefore, it is recommended that this project remains in the CIP. The recommended budget for this CIP is \$1,560,000.

CIP W3-4: Tate Influent Flash Mixers

5-Year Budget Allocation: \$180,000

Priority: Low

The Tate Influent Flash Mixers project is on the City's CIP list. Therefore, it is recommended that this project remains in the CIP. The recommended budget for this CIP is \$180,000.

CIP W3-5: Tate NaOCI Disinfection System

5-Year Budget Allocation:	\$360,000
---------------------------	-----------

Priority: Low

The Tate NaOCI Disinfection System project is on the City's CIP list. Therefore, it is recommended that this project remains in the CIP. The recommended budget for this CIP is \$360,000.

CIP W3-6: Replace Aging Mechanical & MCC Equipment

5-Year Budget Allocation: \$1,550,000

Priority: Medium

This project replaces and upgrades electrical and mechanical equipment at Tate, as necessary. A comprehensive condition assessment should be completed annually to identify the remaining service life of equipment in order to prepare for replacement.

Coating loss and corrosion are present on the EIMCO settlers at the plant. To maintain the equipment from metal loss and eventual failure from corrosion, the ferrous surfaces should be abrasively blasted and recoated.



CIP W4-1: 1750 Blend Manifold Replacement

5-Year Budget Allocation: \$120,000

Priority: High

The 1750 Blend Manifold Replacement project is on the City's CIP list. Therefore, it is recommended that this project remains in the CIP. The recommended budget for this CIP is \$120,000.

CIP W4-2: Booster Pump Station Rehabilitation

5-Year Budget Allocation: \$1,500,000

Priority: Medium

The booster pump stations will need rehabilitation and refurbishment once they approach the end of their service life. Their typical service life is based on 20-year equipment life. It is recommended the City rehabilitate a single pump station each year, and the station refurbishments can be placed on a 15-year cycle. It is recommended the station priority be based on efficiency, condition, and age. Table 10-10 provides a list prioritized on efficiency from SCE pump tests.

Table 10-10: Booster Pump Stations Renabilitation							
Name	Total Num. Pumps	Cumulative HP	Average Efficiency				
South	5	800	49.8				
Fifth Avenue	4	450	59.2				
HAWC	6	975	66.6				
Sand Canyon	2	200	66.7				
Country Club	4	550	68.1				
Agate	3	300	68.7				
Dearborn	2	300	69.9				
Texas	4	1000	73.5				
Smiley Heights	2	80	52.0				
Ford Park	2	N/A	N/A				
Ward Way	2	100	56				
Mill Creek	2	125	56.0				

Table 10-10: Booster Pump Stations Rehabilitation

CIP W5-1: Reservoir Sites Fixed Generators

5-Year Budget Allocation:	\$1,650,000
J-I cal Duaget Anotation.	JI,050,000

Priority: High

The Reservoir Sites Fixed Generators project is on the City's CIP list. Therefore, it is recommended that this project remains in the CIP. The recommended budget for this CIP is \$1,650,000

CIP W5-2: Sunset Reservoir Replacement

5-Year Budget Allocation: \$8,000,000



Priority:

High

This project engineers and replaces a three (3) MG potable water storage reservoir that is seismically deficient.

CIP W5-4: Seismic Assessment Improvements

5-Year Budget Allocation: \$5,462,333

Priority: Medium

The City currently owns and operates eighteen (18) storage tanks ranging from 0.2 to 10.6 MG, provided in Table 10-11. The total budget varies every year based on the recommendations from Brady.

In the first year, the City should conduct a preliminary inspection of each reservoir to assess the interior and exterior coating conditions and determine if additional upgrades are required to meet current seismic design standards and California Division of Occupational Safety and Health Agency (CalOSHA) requirements. The priority of the projects should be based on the recommendations from Brady.

Priority	Name	Capacity (MG)	Туре	Year Constructed
1	Texas Grove	3.9	Steel	2004
2	Ward Way	2	Steel	1958
3	Mill Creek 1	0.2	Steel	1962
4	Smiley	3	Steel	1964
5	South	2	Steel	1964
6	Arroyo	0.5	Steel	1965
7	Sunset	3	Steel	1967
8	Agate	3	Steel	1968
9	Crafton	3.5	Steel	1970
10	Sand Canyon	3.5	Steel	1973
11	Mill Creek 2	0.2	Steel	1987
12	Texas Street	1	Steel	1956
13	Highland	10	Concrete	1976
14	Country Club 1	1	Concrete	1924
15	Country Club 2	2	Concrete	1969
16	Margarita	2.4	Concrete	1964
17	Dearborn	10.6	Concrete	1974
18	Fifth Avenue	5	Concrete	1974

Table 10-11: Storage Tank Reservoirs

Table 10-12 provides the reservoirs proposed to be replaced by Brady.



Priority	Name	Capacity (MG)	Туре	Year Constructed	Seismic Replacement Budget	Replacement Year
1	Sunset	3	Steel	1967	\$8,000,000	2023

Table 10-12: Replacement per Seismic Study

CIP W5-5: Texas Grove Reservoir Stair Installation

5-Year Budget Allocation:	\$90,000

Priority:

The Texas Grove Reservoir Stair project is on the City's CIP list and scheduled for 2022. Therefore, it is recommended that this project remains in the CIP, and the cost be escalated twenty percent (20%) to bring the prices to the year 2022 dollars. The recommended budget in this CIP is \$90,000.

CIP W6-1: Groundwater Well Equipping Rehabilitation

TBD

High

5-Year Budget Allocation: \$2,820,000

Priority:

The groundwater well pumping equipment will need rehabilitation and refurbishment once they approach the end of their service life. Their typical service life is based on 20-year equipment life. It is recommended the City rehabilitate one or more groundwater well-pumping equipment each year, provided in Table 10-13. Once all wells are rehabilitated, the City should evaluate the oldest wells to determine when the next rehabilitation should start. It is recommended the station priority be based on efficiency, condition, and age. The list below is prioritized on efficiency from SCE pump tests. The costs below represent aboveground equipment only and do not include subsurface improvements.

Name	Capacity (GPM)	Status in 2019	Efficiency	НР	Rehab Budget	Rehab Year
Well 10	1400	IDLE	0.27	75	\$120,000	2025
Maguet 2	400	IN USE	0.35	25	\$50,000	2025
Rees	550	IN USE	0.43	250	\$112,640	2024
Lugonia 3	250	IN USE	0.43	25	\$35,010	2022
Madeira	600	IN USE	0.62	150	\$119,058	2023
Crafton	1700	IDLE	0.65	200	\$280,000	2026
Airport 2	1000	IN USE	0.68	300	\$133,760	2024
Airport 1	1500	IN USE	0.70	350	\$124,907	2022
Mentone Acres 2	1600	IN USE	0.71	300	\$138,502	2023
Orange Street	1500	IN USE	0.74	300	\$280,000	2027
North Orange Street 1	2900	IN USE	0.77	350	\$128,460	2022
Church Street	2000	IN USE	0.77	400	\$139,304	2024
Well 39	1250	IN USE	0.78	250	\$133,030	2023
North Orange Street 2	2900	IN USE	0.78	350	\$275,000	2031

Table 10-13: Groundwater Wells



Capacity (GPM)	Status in 2019	Efficiency	HP	Rehab Budget	Rehab Year
1600	IN USE	0.78	300	\$123,230	2023
1750	IDLE	0.79	200	\$175,000	2023
1300	IDLE	UNK	75	\$67,850	2022
2200	IN USE	UNK	300	\$314,000	2022
3300	IDLE	UNK	300	\$120,000	2025
850	IN USE	0.64	75	\$225,000	2025
600	IN USE	.49	50	\$67,200	2024
	1600 1750 1300 2200 3300 850 600	1600 IN USE 1750 IDLE 1300 IDLE 2200 IN USE 3300 IDLE 850 IN USE 600 IN USE	(GPM) 2019 7 1600 IN USE 0.78 1750 IDLE 0.79 1300 IDLE UNK 2200 IN USE UNK 3300 IDLE UNK 850 IN USE 0.64 600 IN USE .49	(GPM)201971600IN USE0.783001750IDLE0.792001300IDLEUNK752200IN USEUNK3003300IDLEUNK300850IN USE0.6475600IN USE.4950	(GPM)2019Image: Constraint of the sector of the sect

Note: (1) UNK-Un known; (2) Mill Creek 2 and 2A are detached potable wells used to deliver water to the Mill Creek Mutual Water System located on Highway 38.

CIP W6-2: East Lugonia Well 3 Replacement

5-Year Budget Allocation:	\$3,000,000
---------------------------	-------------

Priority: Low

The East Lugonia Well 3 Replacement project is on the City's CIP list. Therefore, it is recommended that this project remains in the CIP. The recommended budget for this \$2,600,000.

CIP W6-3: Groundwater Contaminate Mitigation

5-Year Budget Allocation:	\$2,150,000
---------------------------	-------------

Priority: Medium

The City currently has wells with contaminates that exceed or are close to exceeding mandated MCLs. Although these wells are not currently used for potable water production, they will eventually be needed. It is recommended that the City implement a study to determine the water quality and the most appropriate treatment process for the specific contaminants identified, provided in Table 10-14. The project's first phase would be implementing a study, followed by treatment implementation for one set of wells each year. This approach would complete all projects by 2035 to meet future demands. The costs assume blending treatment could not be used to meet MCLs. Typically, SWRCB-DDW no longer permits blending as an alternative, but requires best available technology to achieve MCL regulation limits. Furthermore, many emerging constituents of concern could most likely become regulated as a MCL. Therefore, the budget costs should be revisited once the study is complete.

Table 10-14: Well Study and Treatment

Study and Evaluation	Cost
Wellhead Treatment Design for Wells 38, 39, Church St, and Orange	\$575,000
Wellhead Treatment Design for Agate 1 and 2, Crafton, Wells 10 and 13	\$575,000
Wellhead Treatment and Implementation for Wells 38 and 39	\$1,000,000

CIP W6-4: Entrained Air Treatment Assessment

5-Year Budget Allocation: \$600,000



Priority:

Low

The Entrained Air Treatment Assessment project is on the City's CIP list. Therefore, it is recommended that this project remains in the CIP. The recommended budget for this \$600,000. It is recommended that the City elaborates the entrained air issue further to capture the urgency and cost estimate better.

10.4.2 NON-POTABLE WATER SYSTEM CIP PROJECT DESCRIPTIONS

CIP NP1-1 Pipeline Replacement and Expansion

5-Year Budget Allocation: TBD

Priority: Low

It is recommended that the City budget for hydraulically deficient pipeline replacements, provided in Table 10-15. The NPW CIP should be focused heavily on replacing existing pipes with deficiencies that create high velocities or pressures as predicted by the hydraulic model performed for this Master Plan. The replacement of this pipeline is divided into 4 separate areas, grouped by segments in the exact physical location.

				-	
CIP	New Diameter (in)	Length (ft)	Street	Issue	Budget
NP-CIP-1	12	2,608	Pioneer Ave	High Flow Velocity	\$610,000
	12	624	Alabama St	High Flow Velocity	\$146,000
Subtotal		3,232			\$756,000
NP-CIP-2	8	1,900	Orange Tree Ln	High Flow Velocity	\$296,000
	10	1,468	Orange Tree Ln	High Flow Velocity	\$286,000
Subtotal		3,368			\$582,000
NP-CIP-3	16	1,006	Texonia Park	High Flow Velocity	\$314,000
	12	1,200	W Lugonia Ave	High Flow Velocity	\$281,000
Subtotal		2,206			\$595,000
NP-CIP-4	24	1,217	State St	High Flow Velocity	\$570,000
	24	900	New York St	High Flow Velocity	\$421,000
Subtotal		2,117			\$991,000
Total		10,923			\$2,924,000

Table 10-15: Non-Potable Pipeline Replacement

This NPW CIP includes the expansion of the City's non-potable water system. This would include expanding non-potable water in System 2 and the connection of the Hillside Memorial Park, Ford Park, and Redlands Country Club to the system. This will also leave the potential for the City to connect to the Bear Valley non-potable water system if the City chooses.

<u>CIP NP1-2 Groundwater Well Equipping Rehabilitation</u></u>

5-Year Budget Allocation: \$1,528,000

Priority: Medium



The City has eleven (11) non-potable wells. These wells will need rehabilitation and refurbishment once they approach the end of their service life, provided in Table 10-16. Their typical service life is based on 20-year equipment life. It is recommended the City rehabilitate at least one pump each year. Once all wells are rehabilitated, the City should evaluate the oldest wells to determine when the subsequent rehabilitation should start. It is recommended the stations priority be based on efficiency, condition, and age. The list below is prioritized on efficiency from SCE pumps tests. The cost below represents aboveground equipment only and does not include subsurface improvements.

Name	Capacity (gpm)	Status in 2019	Efficiency	НР	Rehab Budget	NPW CIP Year
Well 31A	850	Idle	31.9%	450	\$195,230	2022
Well 11	300	In Use	47.9%	60	\$64,180	2023
California	500	In Use	52.0%	100	\$100,000	2024
Well 16	1500	In Use	53.2%	150	\$280,000	2025
New York Street	1500	In Use	54.9%	150	\$111,050	2023
Well 41	800	In Use	Unknown	100	\$280,000	2027
Well 14	2200	In Use	Unknown	125	\$280,000	2028/2029
Crafton	1750	idle	59.8%	200	\$280,000	2030/2031
Well 32	1850	In Use	60.5%	200	\$119,122	2022
Well 30A	1500	In Use	61.2%	150	\$280,000	2034/2035
Agate 1	1800	Idle	77.5%	200	\$350,000	2038

Table 10-16: Ground Water Well CIP list with the Cost Opinion

CIP NP2-1: Recycle Water Reservoirs

5-Year Budget Allocation: \$6,734,839

Priority: Medium

This NPW CIP was included in the City's NPW CIP list and focuses on designing two steel reservoirs to improve the management and operation of the City's recycled water system. In addition, the City plans to construct one reservoir near the WWTP to store reclaimed water from the treatment facility. These reservoirs could significantly increase the efficiency of the recycled/non-potable water system.

CIP NP2-2: Pipeline Replacement and Expansion

5-Year Budget Allocation: \$1,500,000

Priority: Medium



Approximately 10,000 LF of the City's recycled/non-potable pipelines are over the service life. Another 9,200 LF of the pipeline will reach the end of their service life within 20 years. There is also another 31,300 LF of pipeline that material or installation data is unknown and may need to be replaced. The figure below shows the remaining service life based on the material and age of the pipe. Chart 10-4 shows the service life distribution remaining in the City's pipelines.




Chart 10-4: Recycled/Non-potable Water Pipeline Remaining Service Life

Most of the City's recycled/non-potable pipelines have a remaining service life of forty to sixty (40-60) years left. To replace all pipelines in 70 years, the City would need to replace approximately 3,100 LF of pipelines. However, due to the number of pipelines with unknown service age, a pipeline over the service life, and pipeline found during the hydraulic modeling, the first five years increase funding to \$1,500,000 to replace these pipelines. For the following 15 years, the funding needed is \$2,000,000. It is recommended that the City first replace the short pipelines identified in CIP NP1-1 and then prioritize replacing aging pipelines. Pipelines less than 8 inches in diameter should be replaced with 8-inch diameter pipelines. Replacement of pipeline segments should be selected yearly based on age breakage history and coordinated with other CIP projects, such as street improvements or pavement replacement. As a result, the City can benefit from upcoming pavement replacement or avoid replacement in freshly paved streets.

This NPW CIP includes the expansion of the City's recycled water system. The construction of the new pipelines in the first five-year period would primarily include the 8-inch pipelines, with a few pipeline segments more significant than 8 inches where needed.



11 LIST OF APPENDICES

APPENDIX A

City of Redlands' Hinckley and Tate Water Treatment Plants, Agate and Sunset reservoirs and site booster pumps, wells and ancillary equipment Condition Assessment

APPENDIX B

Hydraulic Model Calibration Results (Placeholder)

APPENDIX C

CIP Cost Tables (Placeholder – Final Draft will include the finalized Appendix C)

APPENDIX D

Water System Inefficiency Cost Opinion (Placeholder)

APPENDIX E

CIP Projects Remaining After Quality Control (Placeholder – Final Draft will include the finalized Appendix E)

APPENDIX F

Condition, Seismic, and Structural Assessment Executive Summary (Placeholder – Final Draft will include the finalized Executive Summary)



APPENDIX A

Condition Assessment: City of Redlands' Water Treatment Plants

CONDITION ASSESSMENT

City of Redland's Water Treatment Plants

Owner **City of Redlands**

Table of Contents

1	Intro	oduct	tion	4
2	The	Hora	ace P. Hinckley Water Treatment Plant	4
	2.1	Trea	atment Process	4
	2.2	CIP	Recommendations	8
	2.2.	1	CIP 1	8
	2.2.	2	CIP 2	8
	2.2.	3	CIP 3	8
	2.2.	4	CIP 4	8
	2.2.	5	CIP 5	8
	2.3	Hind	ckley Water Treatment Plant Facilities	9
	2.3.	1	Agate Reservoir	19
3	The	Tate	e Water Treatment Plant	30
	3.1	Trea	atment Process	31
	3.2	CIP	Recommendations	32
	3.2.	1	CIP 1	32
	3.2.	2	CIP 2	32
	3.3	Tate	e Water Treatment Plant Facilities	33
4	Sun	iset r	eservoir	49
	4.1	CIP	Recommendations	49
	4.1.	1	CIP 1	49

Figures

) ,
)
)
)
}
ŀ
5
;
,
3
)
)

City of Redlands Water Treatment Plants Figure 15 Cla-Valve Flow Control Valve at Agate Reservoir. 21 Figure 16 Agate Reservoir Seismic Expansion Unit Supported Off the Concrete Slab 22 Figure 17 Agate Reservoir Roof. 23 Figure 18 Agate Access Stairway with Partial Enclosure Safety Cage 24 Figure 19 MCC Center for Agate Reservoir PS 25 Figure 20 Agate Reservoir Pre-Treatment. 26 Figure 21 Disinfectant Storage at Agate Site. 27 Figure 23 Booster PS Discharge Valves and Pressure Gauges 29 Figure 24 Tate WTP SCADA Screen 30 Figure 27 Control Room-Excellent Working Condition 35 Figure 28 Onsite Lab-In Excellent Working Condition 36 Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure. 37 Figure 31 Chlorine Cylinder Stored Onsite 39 Figure 34 Effluent Reservoir Onsite 40 Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition 43 Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment). 44 Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment). 44
Figure 15 Cla-Valve Flow Control Valve at Agate Reservoir. 21 Figure 16 Agate Reservoir Seismic Expansion Unit Supported Off the Concrete Slab 22 Figure 17 Agate Reservoir Roof. 23 Figure 18 Agate Access Stairway with Partial Enclosure Safety Cage 24 Figure 19 MCC Center for Agate Reservoir PS 25 Figure 20 Agate Reservoir Pre-Treatment. 26 Figure 21 Disinfectant Storage at Agate Site. 27 Figure 23 Booster PS Discharge Valves and Pressure Gauges 28 Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century. 33 Figure 26 MCC and Communications Equipment. 34 Figure 30 Safety Enclosure of the Chlorinators. 36 Figure 30 Safety Enclosure of the Chlorinators. 38 Figure 31 Chlorine Cylinders Stored Onsite 39 Figure 32 Standby Diesel Generator Set 41 Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment). 44 Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment). 45 Figure 33 Filter Equipment (Seems to be an Excellent Working Condition). 47
Figure 16 Agate Reservoir Seismic Expansion Unit Supported Off the Concrete Slab 22 Figure 17 Agate Reservoir Roof 23 Figure 18 Agate Access Stairway with Partial Enclosure Safety Cage 24 Figure 19 MCC Center for Agate Reservoir PS 25 Figure 20 Agate Reservoir Pre-Treatment 26 Figure 21 Disinfectant Storage at Agate Site 27 Figure 22 Chemical Storage 28 Figure 23 Booster PS Discharge Valves and Pressure Gauges 29 Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century 33 Figure 26 MCC and Communications Equipment 34 Figure 20 Tootrol Room-Excellent Working Condition 35 Figure 30 Safety Enclosure of the Chlorinators 38 Figure 31 Chlorine Cylinders Stored Onsite 39 Figure 32 Safety Cylinder Operation 40 Figure 33 Standby Diesel Generator Set 41 Figure 36 Emico Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 45 Figure 38 Filter Equipment (Seems to be an Excellent Working Condition) 47
Figure 17 Agate Reservoir Roof 23 Figure 18 Agate Access Stairway with Partial Enclosure Safety Cage 24 Figure 19 MCC Center for Agate Reservoir PS 25 Figure 20 Agate Reservoir Pre-Treatment 26 Figure 21 Disinfectant Storage at Agate Site 27 Figure 22 Chemical Storage. 28 Figure 23 Booster PS Discharge Valves and Pressure Gauges 29 Figure 24 Tate WTP SCADA Screen 30 Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century 33 Figure 27 Control Room-Excellent Working Condition 35 Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure 37 Figure 30 Safety Enclosure of the Chlorinators 38 Figure 32 Safety Cylinder Operation 40 Figure 34 Effluent Reservoir Onsite 42 Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition 43 Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 38 Filter Equipment (Seems to be an Excellent Working Condition) 45 Figure 39 Filter Equipment (Seems to be an Excellent Working Condition) 47 <
Figure 18 Agate Access Stairway with Partial Enclosure Safety Cage 24 Figure 19 MCC Center for Agate Reservoir PS 25 Figure 20 Agate Reservoir Pre-Treatment 26 Figure 21 Disinfectant Storage at Agate Site 27 Figure 22 Chemical Storage 28 Figure 23 Booster PS Discharge Valves and Pressure Gauges 29 Figure 24 Tate WTP SCADA Screen 30 Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century 33 Figure 26 MCC and Communications Equipment 34 Figure 27 Control Room-Excellent Working Condition 35 Figure 30 Safety Enclosure of the Chlorinators 38 Figure 31 Chlorine Cylinders Stored Onsite 39 Figure 32 Safety Cylinder Operation 40 Figure 34 Effluent Reservoir Onsite 42 Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition 43 Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 38 Filter Equipment (Seems to be an Excellent Working Condition) 47
Figure 19 MCC Center for Agate Reservoir PS 25 Figure 20 Agate Reservoir Pre-Treatment. 26 Figure 21 Disinfectant Storage at Agate Site 27 Figure 22 Chemical Storage 28 Figure 23 Booster PS Discharge Valves and Pressure Gauges 29 Figure 24 Tate WTP SCADA Screen 30 Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century 33 Figure 27 Control Room-Excellent Working Condition 35 Figure 30 Safety Enclosure of the Chlorinators 38 Figure 31 Chlorine Cylinders Stored Onsite 39 Figure 33 Standby Diesel Generator Set 41 Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition 43 Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 37 Eimco Settler (Seems to be an Excellent Working Condition) 46 Figure 39 Filter Equipment (Seems to be in Excellent Working Condition) 47
Figure 20 Agate Reservoir Pre-Treatment. 26 Figure 21 Disinfectant Storage at Agate Site. 27 Figure 22 Chemical Storage. 28 Figure 23 Booster PS Discharge Valves and Pressure Gauges 29 Figure 24 Tate WTP SCADA Screen 30 Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century 33 Figure 26 MCC and Communications Equipment. 34 Figure 27 Control Room-Excellent Working Condition 35 Figure 30 Safety Enclosure of the Chlorinators 38 Figure 31 Chlorine Cylinders Stored Onsite 39 Figure 33 Standby Diesel Generator Set 41 Figure 34 Effluent Reservoir Onsite 42 Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition 43 Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 37 Eimco Settler (Seems to be an Excellent Working Condition) 46 Figure 39 Filter Equipment (Seems to be in Excellent Working Condition) 47
Figure 21 Disinfectant Storage at Agate Site. 27 Figure 22 Chemical Storage. 28 Figure 23 Booster PS Discharge Valves and Pressure Gauges 29 Figure 24 Tate WTP SCADA Screen 30 Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century 33 Figure 26 MCC and Communications Equipment. 34 Figure 27 Control Room-Excellent Working Condition 35 Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure 37 Figure 30 Safety Enclosure of the Chlorinators 38 Figure 32 Safety Cylinder Operation 40 Figure 33 Standby Diesel Generator Set 41 Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition 43 Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 37 Eimco Settler (Seems to be an Excellent Working Condition) 46 Figure 39 Filter Equipment (Seems to be an Excellent Working Condition) 47
Figure 22 Chemical Storage28Figure 23 Booster PS Discharge Valves and Pressure Gauges29Figure 24 Tate WTP SCADA Screen30Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century33Figure 26 MCC and Communications Equipment34Figure 27 Control Room-Excellent Working Condition35Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure37Figure 30 Safety Enclosure of the Chlorinators38Figure 32 Safety Cylinder Operation40Figure 33 Standby Diesel Generator Set41Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition43Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)44Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)45Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)47
Figure 23 Booster PS Discharge Valves and Pressure Gauges29Figure 24 Tate WTP SCADA Screen30Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century33Figure 26 MCC and Communications Equipment34Figure 27 Control Room-Excellent Working Condition35Figure 28 Onsite Lab-In Excellent Working Condition36Figure 30 Safety Enclosure of the Chlorinators38Figure 31 Chlorine Cylinders Stored Onsite39Figure 32 Safety Cylinder Operation40Figure 34 Effluent Reservoir Onsite41Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition43Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)44Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)47
Figure 24 Tate WTP SCADA Screen30Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century33Figure 26 MCC and Communications Equipment.34Figure 27 Control Room-Excellent Working Condition35Figure 28 Onsite Lab-In Excellent Working Condition36Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure37Figure 30 Safety Enclosure of the Chlorinators38Figure 31 Chlorine Cylinders Stored Onsite39Figure 32 Safety Cylinder Operation40Figure 34 Effluent Reservoir Onsite42Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition43Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)44Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)47
Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century
Figure 26 MCC and Communications Equipment.34Figure 27 Control Room-Excellent Working Condition35Figure 28 Onsite Lab-In Excellent Working Condition36Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure37Figure 30 Safety Enclosure of the Chlorinators38Figure 31 Chlorine Cylinders Stored Onsite39Figure 32 Safety Cylinder Operation40Figure 33 Standby Diesel Generator Set41Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition43Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)44Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)47
Figure 27 Control Room-Excellent Working Condition35Figure 28 Onsite Lab-In Excellent Working Condition36Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure37Figure 30 Safety Enclosure of the Chlorinators38Figure 31 Chlorine Cylinders Stored Onsite39Figure 32 Safety Cylinder Operation40Figure 33 Standby Diesel Generator Set41Figure 34 Effluent Reservoir Onsite42Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition43Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)44Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)46Figure 39 Filter Equipment (Seems to be in Excellent Working Condition)47
Figure 28 Onsite Lab-In Excellent Working Condition36Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure37Figure 30 Safety Enclosure of the Chlorinators38Figure 31 Chlorine Cylinders Stored Onsite39Figure 32 Safety Cylinder Operation40Figure 33 Standby Diesel Generator Set41Figure 34 Effluent Reservoir Onsite42Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition43Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)44Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)46Figure 39 Filter Equipment (Seems to be in Excellent Working Condition)47
Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure.37Figure 30 Safety Enclosure of the Chlorinators38Figure 31 Chlorine Cylinders Stored Onsite39Figure 32 Safety Cylinder Operation40Figure 33 Standby Diesel Generator Set.41Figure 34 Effluent Reservoir Onsite42Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition43Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)44Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)45Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)46Figure 39 Filter Equipment (Seems to be in Excellent Working Condition)47
Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure.37Figure 30 Safety Enclosure of the Chlorinators38Figure 31 Chlorine Cylinders Stored Onsite39Figure 32 Safety Cylinder Operation40Figure 33 Standby Diesel Generator Set.41Figure 34 Effluent Reservoir Onsite42Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition43Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)44Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)45Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)46Figure 39 Filter Equipment (Seems to be in Excellent Working Condition)47
Figure 30 Safety Enclosure of the Chlorinators
Figure 32 Safety Cylinder Operation40Figure 33 Standby Diesel Generator Set41Figure 34 Effluent Reservoir Onsite42Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition43Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)44Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)45Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)46Figure 39 Filter Equipment (Seems to be in Excellent Working Condition)47
Figure 33 Standby Diesel Generator Set. 41 Figure 34 Effluent Reservoir Onsite 42 Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition 43 Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 45 Figure 38 Filter Equipment (Seems to be an Excellent Working Condition) 46 Figure 39 Filter Equipment (Seems to be in Excellent Working Condition) 47
Figure 34 Effluent Reservoir Onsite 42 Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition 43 Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 45 Figure 38 Filter Equipment (Seems to be an Excellent Working Condition) 46 Figure 39 Filter Equipment (Seems to be in Excellent Working Condition) 47
Figure 34 Effluent Reservoir Onsite 42 Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition 43 Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 44 Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment) 45 Figure 38 Filter Equipment (Seems to be an Excellent Working Condition) 46 Figure 39 Filter Equipment (Seems to be in Excellent Working Condition) 47
Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)
Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)45 Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)46 Figure 39 Filter Equipment (Seems to be in Excellent Working Condition)47
Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)
Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)
Figure 40 Washwater Reservoir (seems to be in excellent working condition)
Figure 41 Signs of Aging and Corrosion are Evident
Figure 42 Communication Antenna of Service Provider Erected Onsite
Figure 43 Steel Shell is Spot Corroded-Attached Ladders are Rusted Beyond Repair
Figure 44 Reservoir Corrosion Protection Cabinet (seems antiquated)
Figure 45 Close-Up of Corrosion Detail
Figure 46 Reservoir Base (surrounding asphalt is cracking and evidence of deterioration)55
Figure 47 Reservoir Control Wires are Dangling on the Side of the Reservoir
Figure 48 Access Manhole Valve is Corroded

Introduction

The City of Redlands Water System utilizes two (2) surface water treatment plants. The Michael Baker International (MBI) team visited two active plants on July 7th,2021.

The total combined capacity of these facilities is approximately 32 million gallons per day (MGD). Below is a plant process summary based on the site visit with an outline of identified CIP projects:

2 The Horace P. Hinckley Water Treatment Plant

The Horace P. Hinckley Water Treatment Plant (Hinckley WTP) is a conventional water

treatment plant (WTP) utilizing rapid mix flocculation, sedimentation, filtration, and disinfection continuously. The nominal plant capacity is 12 MGD. The peak flow rate is limited to 14.5 MGD based on a maximum filtration rate of 6 gallons per minute per square foot (gpm/sq ft) based on the California Department of Public Health (CDPH). The "firm" capacity is 12 MGD with one filter out-of-service. The treatment plant capacity is expandable to a maximum ultimate capacity of 36 MGD.

The Hinckley WTP treats raw water from the Santa Ana River (SAR), Mill Creek, and State Water Project (SWP). Santa Ana River is the primary source for the plant. Up to 100 percent of the plant's raw water can be supplied from the Santa Ana River during the winter. During hot-weather periods in the summer, the source of 20 to 40 percent of the plant's raw water can be SWP.

2.1 Treatment Process

The first step in the conventional water treatment is the pre-treatment. In this stage, the three chemicals injected into the static mixer's first stage are chlorine, aluminum sulfate, and cationic polymer-the aluminum sulfate and cationic polymer act as a coagulant to help the creation of the floc. Chemical dosages are selected based on historical data (water quality versus required chemical dose), operator experience, and jar test data. However, suppose the raw water quality should change to that for which no historical chemical dosage data is available. In that case, the primary coagulant, coagulant aid, and filter aid dosages should be determined by performing jar and filterability index tests on the raw water. The chlorine dosing will start the disinfection process, prevent the bio growth on the filter and pipes, and assist with any taste and odor issues that the plant could have. The influent flow is conveyed and controlled through the off-site piping and valving influent flowmeter, control valve, and influent static mixer. Though part of the influent meter and mixing process, the flow splitter box is not used, as Hinckley WTP has not been expanded. The primary coagulant aluminum chlorohydrate (ACH), coagulant aid cationic polymer (C308), and disinfectant sodium hypochlorite (NaOCI) may be added to the raw water upstream and downstream of the inline mechanical and static mixer before the flocculation/sedimentation basins.

<u>The second step</u> is coagulation, and flocculation is when suspended solids get together to form larger particles called the "floc." Flocculation is achieved through two flocculation basins, each designed for a flow of 9 mgd. Each flocculation basin has three stages and contains vertical shaft flocculation rotated by an external gear reducer powered by electric motors. The electric motors can run at various speeds using six variable frequency drives (VFDs). Cationic polymer C308 can be added to the third-stage flocculation basin, as needed, to increase the efficiency of the flocculation process.

<u>The third step</u> is sedimentation. In this step, larger particulates settle to the floor of the sedimentation basin. The chemicals added in the first step assist the sedimentation process in helping the particulates settle at the floor of the settling tank. Solids separation is achieved through the sedimentation basins located close to the flocculation basins. Each sedimentation basin is designed for a flow of 9 mgd and includes inclined plate settlers and an aluminum-supported fabric cover to reduce the disinfection dose being affected by sunlight.

<u>The fourth step</u> is filtration. The media filtration system consists of three media filters (anthracite over sand and gravel) equipped with an automated backwash system. The individual filters are designed for a 2.4 mgd (6 gpm per sq. ft) flow and are equal-loading, declining-rate, self-backwashing types with an air scour system and a filter-to-waste system. However, usually, backwashes are manually initiated by the operators.

<u>The fifth step is post-disinfection</u>. We add chlorine to treated water to complete disinfection before it is discharged into the distribution system.

The sixth step is the backwash. The particulates and polymer in the filters are attached to media and then clog them up. The backwash process starts by draining the filters to pre-set point and then air scouring for approximately ten minutes, breaking down any particulates stuck in the system. Finally, backwashing is performed to clean the filters to keep their continuous operation and prevent water from overflowing. The recycled wash water system consists of a waste wash water basin, recycle pump station, recycle wash water treatment plant, and a polymer feed room. The recycled wash water system receives flow primarily from the waste wash water discharged during filter backwashing. A smaller fraction of flow is obtained intermittently from the flocculation and sedimentation basins drainage and overflows lines, from chemical feed room drainage lines, sludge decant pond, and water quality sample pump discharge (grab samples from the laboratory sink). Spent filter backwash wash water flows by gravity from each filter to the waste wash water recovery basin located at the west end of the plant site. The waste wash water basin has a concrete bottom with concrete and soil cement sidewall and a capacity of 0.15 MG. The basin can hold wash water from three consecutive filter backwashes (based on a volume per backwash of 46,500 gallons). A sump on the basin floor located at the north end removes the sludge that settles in the basin. The sump pump in the floor of the basin discharges into the sludge drying ponds. Sludge is removed from the wash water recovery basin as needed, and no less than annually, to prevent large amounts of sludge buildup.

The operation of the filtration process determines flows into the wash water basin. When a filter is backwashed, the basin receives the backwash flow. Decanted supernatant water from the sludge lagoons is pumped from the decant structures to the wash water recovery basin. On occasions when the wash water package treatment plant is out of service, the wash water is sent to a series of percolation ponds located to the north of the sludge drying ponds.

The recycle treatment plant system can treat 1,000 gpm (1.5 mgd) if the influent flow rate permits. The recycle treatment plant system consists of a single-impeller flash mixer first stage and a twinimpeller second stage flocculation mixer followed by an incline plate settler to enhance sludge removal. Anionic polymer A6320 (A6320) is used as the primary coagulant. Anionic polymer A210 (A210) is used for the dewatering of sludge. Anionic polymer is stored and prepared in the utility building. Jar tests are performed to set the optimum dose. Typical dose rates of 0.5 to 2.0 milligrams per liter (mg/L) for the primary coagulant A6320. The SCADA system sends an alarm to the operator when effluent turbidity from the recycle wash water treatment plant is 2.0 nephelometric turbidity units (NTU) or higher. Flow and turbidity are monitored and recorded continuously.




Figure 1 The Wash Water Recycled Water Treatment Plant

The recycle treatment plant effluent is continually monitored by SCADA and grab samples are pulled daily for comparison. The effluent of the recycling plant is returned to the influent structure ahead of the chemical feed application. The recycle treatment plant is shown in the above Figure. The SCADA system enables the operator to:

- Adjust the operating condition of the three washwater return pumps.
- Control and monitor the recycle flow rate.
- Control and monitor the flocculator (mixer) drive.
- Control and monitor the polymer feed system.
- · Control and monitor the waste discharge valve and related instrumentation monitoring
- and online analysis results.

The chlorine is injected after combined filter effluent before going to the Agate storage reservoir. Solids removed from the sedimentation basin flow by gravity to four sludge lagoons located at the northwest end of the plant site. Each lagoon has a capacity of 40,000 cubic feet and provides one hundred thirty-one days of sludge storage at a nominal plant capacity of 12 MGD. Sludge production at a plant flow rate of 12 MGD is estimated to be approximately 305 cu ft of dry sludge per day. On a monthly basis, the sludge in each lagoon is dried and removed by mechanical means for off-site disposal to a landfill. The supernatant from the sludge ponds flows by gravity to a collection box.

From the collection box, the supernatant is pumped to the wash water basin influent. A process schematic of the Hinckley WTP is presented in *Figure 2*.




Figure 2 Hinckley WTP

2.2 CIP Recommendations

2.2.1 CIP 1

The package wash water treatment plant is installed to treat the filter wash water effluent. The operator shared the concern with the age of installed equipment, the installed capacity, and operation complexity. The replacement unit (s) may be furnished with the new technology to provide adequate capacity. The operator thought that a dissolved air flotation or filter technology might be applicable. The cost of the proposed replacement technology could be \$2M for the 1.5 mgd capacity. The final capacity would be 4.5 mgd with a refurbishment price tag of \$6 M.

2.2.2 CIP 2

Capacity upgrade. The current plant capacity is sufficient for the current demand. However, with the population increase in the future, the demand increase would require additional plant capacity. Therefore, the capacity could be increased in 12 mgd increments in phases 1 and Phase 2. The Phase 1 increase could cost \$25M, with a similar estimate for Phase 2.

2.2.3 CIP 3

Remove provisional support of seismic flex tend at the reservoir and provide permanent support. The cost of this upgrade maybe \$25,000.

2.2.4 CIP 4

Upgrade MCC and replace dated electrical equipment at the cost of \$500,000.

2.2.5 CIP 5

Replace dated mechanical equipment at the cost of \$1M.

2.3 Hinckley Water Treatment Plant Facilities




Figure 3 The City of Redlands Hinckley WTP SCADA




Figure 4 The City of Redlands Water Supply System Supervisory and Data Control System




Figure 5 Hinckley WTP Flocculation and Sedimentation Basin Inlet



Figure 6 Hinckley WTP Filters



Figure 7 Hinckley WTP Filters Layout




Figure 8 Hinckley WTP Flocculation/Sedimentation/Settling




Figure 9 Hinckley WTP Flocculation/Sedimentation/Settling



Figure 10 Settler Sludge Lagoons




Figure 11 Hinckley WTP Filter Backwash Basin



Figure 12 Hinckley WTP Generator Building

2.3.1 Agate Reservoir

Filtered water is discharged to the 3-million-gallon (MG) Agate Reservoir before entering the utility distribution system. The Agate Reservoir includes a baffle system to increase detention time. An engineered blending plan was added to blend three wells' water with the Hinckley WTP effluent. These blending wells are Agate No. 1, Agate No. 2, and the Crafton, well as combining sources. Agate reservoir is a 3 mg steel tank with an average detention time of 7.2 hrs, a nominal detention time of 5 hours, and an ultimate detention time of 3.6 hrs.




Figure 13 Agate Reservoir SCADA Layout




Figure 14 Agate Reservoir and Booster PS




Figure 15 Cla-Valve Flow Control Valve at Agate Reservoir



Figure 16 Agate Reservoir Seismic Expansion Unit Supported Off the Concrete Slab




Figure 17 Agate Reservoir Roof




Figure 18 Agate Access Stairway with Partial Enclosure Safety Cage



Figure 19 MCC Center for Agate Reservoir PS




Figure 20 Agate Reservoir Pre-Treatment



Figure 21 Disinfectant Storage at Agate Site



Figure 22 Chemical Storage



Figure 23 Booster PS Discharge Valves and Pressure Gauges

3 The Tate Water Treatment Plant

The Tate Water Treatment Plant (Tate WTP) was initially commissioned in 1967 to treat surface water from Mill Creek. Since then, several process upgrades have been implemented, with the latest being completed in June 2005. Tate WTP consists of chemical treatment, chemical mixing through an inline static mixer, flocculation, and sedimentation through two EIMCO reactor clarifiers (each equipped with four adjustable speed, vertical turbine flocculation), filtration with four dual media gravity filters (anthracite over sand), and chlorine disinfection. The maximum plant flow rate is 20 MGD with all filters online and 14.9 MGD with one filter offline for backwashing.

A process schematic of the Tate WTP is presented on a SCADA screen in the Figure below.




Figure 24 Tate WTP SCADA Screen

Historically, Tate WTP had received its raw water supply exclusively from Mill Creek. However, the availability of the Mill Creek supply had been reduced during drought periods and is subject to interruptions during high turbidity events. To increase the raw water supply reliability, the City obtained a permit amendment from the CDPH to treat State Water Project (SWP) and Santa Ana River (SAR) water at Tate WTP.

3.1 Treatment Process

<u>The first step</u> in the conventional water treatment is the pre-treatment. Flow is conveyed and controlled through off-site piping and valving, influent flowmeter and control valve, influent sampling system, influent static mixer, and flow splitter box. Chemical mixing of primary coagulant, aluminum chlorohydrate (ACH), and coagulant aid (C-308P) are achieved by the static mixer before reactor clarifiers. Chlorine is also added for disinfection.

<u>The second step</u> is coagulation, and flocculation is when suspended solids get together to form larger particles called the "floc." Flocculation and sedimentation are achieved through two EIMCO reactor clarifiers, each equipped with four adjustable speed vertical turbine flocculation that operates in a continuous operation mode.

<u>The third step</u> is sedimentation. In this step, larger particulates settle to the floor of the sedimentation basin. The chemicals added in the first step assist the sedimentation process in helping the particulates settle at the floor of the settling tank. Solids separation is achieved through the sedimentation basins located close to the flocculation basins. There are two settlers, ten mgd in capacity each, 106 ft in dia, four flocculation, vertical turbine type, adjustable frequency drive, 5 HP motor, 30 min detention time, 50 ft in dia with 3.2 hr detention time.

<u>The fourth step</u> is filtration. The media filtration system consists of dual media filters (anthracite over sand), a filter backwash system, and an air scour system operated continuously. During normal operations, the total flow rate is equally distributed across the four online filters, and filters are only taken offline for backwash and maintenance. The filtered air scours system and backwash system operate during the filter backwash process. ClariFloc A-6320 anionic polymer (filter aid) is added upstream of dual media filters and chlorine for disinfection as needed. There are four filters, each five mgd in capacity, with a six mgd design loading rate, 13.75x41.8 ft with 9.5 side water depth. Media surface area is 575 sqft, with 30 inches of anthracite and 8 inches of sand depth.

<u>The fifth step</u> is post-disinfection. Again, the chlorine is added to treated water to complete disinfection before discharge into the distribution system.

<u>The sixth step</u> is the backwash. The particulates and polymer in the filters are attached to media and then clog them up. The backwash process starts by draining the filters to pre-set point and then air scouring for approximately ten minutes, breaking down any particulates stuck in the system. Finally, backwashing is performed to clean the filters to keep their continuous operation and prevent water from overflowing. The recycled wash water system consists of a waste wash water basin, recycle pump station, recycle wash water treatment plant, and a polymer feed room. The recycled wash water system receives flow primarily from the waste wash water discharged during filter backwashing.

3.2 CIP Recommendations

3.2.1 CIP 1

EIMCO settlers could be refurbished, and corrosion of the mechanical equipment could be addressed. Just sandblasting and repainting both using would be appx \$50,000. The replacement cost would be \$1M.

3.2.2 CIP 2

Capacity upgrade. The current plant capacity is sufficient for the current demand. However, with the population increase in the future, the demand increase would require additional plant capacity. Therefore, the capacity could be increased in 10 mgd increments in phases 1 and Phase 2. The Phase 1 increase could cost \$20M, with a similar estimate for Phase 2.

3.3 Tate Water Treatment Plant Facilities



Figure 25 Historical Artifact Wooden Pipeline Used at the District in the 19th Century



Figure 26 MCC and Communications Equipment




Figure 27 Control Room-Excellent Working Condition



Figure 28 Onsite Lab-In Excellent Working Condition




Figure 29 Two Chlorinators in Duty Mode, With Safety Enclosure



Figure 30 Safety Enclosure of the Chlorinators



Figure 31 Chlorine Cylinders Stored Onsite




Figure 32 Safety Cylinder Operation




Figure 33 Standby Diesel Generator Set




Figure 34 Effluent Reservoir Onsite



Figure 35 Chemical Storage Area with Concrete Containment-In Good Working Condition



Figure 36 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)




Figure 37 Eimco Settler (Signs of Aging and Corrosion of Mechanical Equipment)




Figure 38 Filter Equipment (Seems to be an Excellent Working Condition)




Figure 39 Filter Equipment (Seems to be in Excellent Working Condition)



Figure 40 Washwater Reservoir (seems to be in excellent working condition)

4 Sunset reservoir

The reservoir is located in a remote location on the southwest side of the City. The reservoir does not have a backup, and it has not been Inspected since it was erected in the 1970s. The reservoir is of welded steel construction; it is 60 ft tall and 90 ft in diameter and has 3 mg capacity. The seismic safety provisions are not visible and likely not provided. Also, corrosion is visible on equipment and reservoir shells. The corrosion protection cabinet is antiquated but is functional and in working condition. The inspection of the tank inside is not possible since the reservoir does not have a backup capacity. However, the diver could inspect by completing the videotaping and establishing the condition baseline without the reservoir operation interruption.

4.1 CIP Recommendations

4.1.1 CIP 1

Increase water supply system reliability by providing reservoirs with redundancy. Depending on the system hydraulic analysis, the pool may be replaced with a reservoir of the same volume at the exact location or similar location. The replacement cost is estimated at \$6M.




Figure 41 Signs of Aging and Corrosion are Evident



Figure 42 Communication Antenna of Service Provider Erected Onsite



Figure 43 Steel Shell is Spot Corroded-Attached Ladders are Rusted Beyond Repair



Figure 44 Reservoir Corrosion Protection Cabinet (seems antiquated)




Figure 45 Close-Up of Corrosion Detail




Figure 46 Reservoir Base (surrounding asphalt is cracking and evidence of deterioration)



Figure 47 Reservoir Control Wires are Dangling on the Side of the Reservoir



Figure 48 Access Manhole Valve is Corroded



APPENDIX B

Hydraulic Model Calibration Results



APPENDIX C

CIP Cost Tables



APPENDIX D

Water System Inefficiency Cost Opinion

			Interp	oulation						
2020	2022	2025	2027	2030	2032	2035	2037	2040	2042	2045
18.90	19.10	19.40	19.72	20.20	20.48	20.90	21.14	21.50	21.78	22.20

1 mg

	2022*	2027	2032	2037	2042
Projected ADD	18.90	19.72	20.48	21.14	21.78
Projected MDD	32.13	33.52	34.82	35.94	37.03
Projected PHD	51.98	54.23	56.32	58.14	59.90
Expected Inefficiencies (%)	12.8	8	6	4	3
Projected ADD production	21.32	21.30	21.71	21.99	22.43
Delta inefficiencies	2.42	1.58	1.23	0.85	0.65
Delta inefficiencies (afy)	2,710	1,767	1,376	947	732
inEfficiencies Monetization					
Delta inefficiencies Lost Billing Charges (\$)	2,333,439	1,521,674	1,185,239	815,623	630,237
Delta inefficiencies Lost Purchase Charges (\$), based on \$500 \$/(afy)well water price	1,354,752	883,456	688,128	473,536	365,904
Delta inefficiencies Power Use (\$) 60% of Billing charges	1,400,063	913,004	711,143	489,374	378,142
Delta inefficiencies O&M (\$) 30% of B illing charges	700,032	456,502	355,572	244,687	189,071
Delta inefficiencies New Capacity Planning (\$) 30% of B illing charges	700,032	456,502	355,572	244,687	189,071
TOTAL Monatized Inefficienices	6,488,318	4,231,139	3,295,654	2,267,907	1,752,425
AVERAGE Monatized Inefficienices	3,607,089				
Reduction in inefficiencies (\$)	-	2,257,179	3,192,664	4,220,411	4,735,893
AVERAGE Monatized Reduction in Inefficienices	\$ 2,881,229				

Where

* 2020 Urban water management plan water supply data was used to approximate the 2022 base line level

1,000,000 gpd

1,120 afyr

City of Redlands 2021 Water use rate

City of Redlands 2021 MP Data	ADD	PDD
	(mgd)	(mgd)
2022	18.9	32.13
2042	21.78	37.026

The City of Redlands

CIP implementation and Water Supply Inefficiencies reduction 2022 to 2042

	2022*	2027	2032	2037	2042
Projected ADD	18.90	19.72	20.48	21.14	21.78
Projected MDD	32.13	33.52	34.82	35.94	37.03
Projected PHD	51.98	54.23	56.32	58.14	59.90
Expected Inefficiencies (%)	12.8	10	8	6	4
Projected ADD production	21.32	21.69	22.12	22.41	22.65
Delta inefficiencies	2.42	1.97	1.64	1.27	0.87
Delta inefficiencies (afy)	2,710	2,209	1,835	1,421	976
inEfficiencies Monetization					
Delta inefficiencies Lost Billing Charges (\$)	2,333,439	1,902,092	1,580,319	1,223,435	840,316
Delta inefficiencies Lost Purchase Charges (\$), based on \$500 \$/(afy)well water price	1,354,752	1,104,320	917,504	710,304	487,872
Delta inefficiencies Power Use (\$) 60% of Billing charges	1,400,063	1,141,255	948,191	734,061	504,190
Delta inefficiencies O&M (\$) 30% of B illing charges	700,032	570,628	474,096	367,031	252,095
Delta inefficiencies New Capacity Planning (\$) 30% of B illing charges	700,032	570,628	474,096	367,031	252,095
TOTAL Monatized Inefficienices	6,488,318	5,288,923	4,394,205	3,401,861	2,336,567
AVERAGE Monatized Inefficienices	4,381,975				
Reduction in inefficiencies (\$)	-	1,199,395	2,094,113	3,086,457	4,151,751
AVERAGE Monatized Reduction in Inefficienices	\$ 2,106,343				

Where

* 2020 urban water management plan water supply data was used to approximate the 2022 base line level

City of Redlands 2021 Water use rate

(\$)					-
1.46	100	cft	748	gal	1,952
1.78			748		2,380
2.69			748		3,596
Average					2,643

1,000,000 gpd

1,120 afyr

	ADD	PDD
	(mgd)	(mgd)
2022	18.9	32.13
2042	22.17	37.689



APPENDIX E

CIP Projects Remaining After Quality Control



APPENDIX F

Condition, Seismic, and Structural Assessment Executive Summary



12 REFERENCES

AAWA Distribution Systems. (2008). M31 Distribution System Requirements for Fire Protection, Fourth Edition

AAWA Distribution Systems. (2013). M42 Steel Water Storage Tanks, Revised Edition

- AAWA Distribution Systems. (2014). M22 Sizing Water Service Lines and Meters, Third Edition
- California State Water Resource Control Board. Table 1: Typical Equipment Life Expectancy.
- California Department of Water Resources. (2004). Upper Santa Ana Valley Groundwater Basin, Bunker Hill Subbasin.
- California Department of Water Resources. (2004). Upper Santa Ana Valley Groundwater Basin, Yucaipa Hill Subbasin.
- California Office of Administrative Law. (2018). Code of Regulations Title 22 Division 4 Chapter 3.
- California State Water Resource Control Board. (2018). Maximum Contaminant Levels and Regulatory Dates for Drinking Water U.S. EPA vs. California.
- The City of Redlands. (2017). City of Redlands General Plan 2035.
- The City of Redlands. (2020). City Owned Citrus Groves
- The City of Redlands. (2021). Fire Code Table, Fire Flow Requirements Table.
- The City of Redlands. (2021). Consumer Confidence Report.
- The City of Redlands. (2021). City of Redlands Draft Water Shortage Contingency Plan.
- The City of Redlands. (2021). 2020 IRUWMP Part 2 Chapter 4 Redlands 2020 UWMP.
- Eastern Municipal Water District. (2007). Water System Planning & Design.
- Environmental Finance Center New Mexico Tech. (2006). Asset Management: A Guide for Water and Wastewater Systems.
- MASC. (2016). Life Expectancy of Water Distribution Lines.
- U.S. EPA. (2002) Effect of Water Age on Distribution System Water Quality.
- Western Municipal Water District. (2011). Design Criteria for Water Distribution Systems.